



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**PWGSC/TPSGC Acquisitions Bid Receiving**

**Box/Boîte de Réception des Soumissions**

**Bid Receiving Box/Boîte de Récepti**

**1st Floor/1<sup>ère</sup> étage, Suite 1212**

**100-1045 Main Street**

**Moncton**

**New Brunswick**

**E1C 1H1**

**Bid Fax: (506) 851-6759**

**SOLICITATION AMENDMENT**

**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Acquisitions NB/PEI (Moncton Office) – Bureau

d'acquisitions N.-B./Î.-P.-É. (Moncton)

1045 Main Street / 1045, rue Main

Moncton

New Bruns

E1C 1H1

|   |  |
|---|--|
| <b>Title - Sujet</b><br>Portable Restroom Trailers  |  |
| <b>Solicitation No. - N° de l'invitation</b><br>5P119-180791/A  | <b>Amendment No. - N° modif.</b><br>003      |
| <b>Client Reference No. - N° de référence du client</b><br>5P119-180791   | <b>Date</b><br>2018-12-18                    |
| <b>GETS Reference No. - N° de référence de SEAG</b><br>PW-\$MCT-033-5481  |  |
| <b>File No. - N° de dossier</b><br>MCT-8-41091 (033)  | <b>CCC No./N° CCC - FMS No./N° VME</b>       |
| <b>Solicitation Closes - L'invitation prend fin</b><br><b>at - à 02:00 PM</b><br><b>on - le 2019-01-11</b>  |  |
| <b>Time Zone</b><br><b>Fuseau horaire</b><br>Atlantic Standard Time<br>AST  |  |
| <b>F.O.B. - F.A.B.</b><br><b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/> |  |
| <b>Address Enquiries to: - Adresser toutes questions à:</b><br>Young (MCT), Leesa   | <b>Buyer Id - Id de l'acheteur</b><br>mct033 |
| <b>Telephone No. - N° de téléphone</b><br>(506) 871-1716 ( )  | <b>FAX No. - N° de FAX</b><br>(506) 851-6759 |
| <b>Destination - of Goods, Services, and Construction:</b><br><b>Destination - des biens, services et construction:</b>   |  |

**Instructions: See Herein**

**Instructions: Voir aux présentes**

|  |  |
|--|--|
| <b>Delivery Required - Livraison exigée</b>  | <b>Delivery Offered - Livraison proposée</b> |
| <b>Vendor/Firm Name and Address</b><br><b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>   |  |
| <b>Telephone No. - N° de téléphone</b><br><b>Facsimile No. - N° de télécopieur</b>   |  |
| <b>Name and title of person authorized to sign on behalf of Vendor/Firm</b><br><b>(type or print)</b><br><b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b><br><b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b> |  |
| <b>Signature</b>   | <b>Date</b>                                  |

## **Solicitation Amendment No. 003**

### **Title: Portable Restroom Trailer**

(1) This solicitation is hereby amended to provide the following questions and answers:

#### **Question #4:**

Q4: The fresh water tanks are located in the mechanical room and are made of a translucent plastic material. It is very clear what the fresh water level is just from looking at the tank. Is a monitor really needed?

A4 : When fresh water tanks are translucent no external level indicator is required.

#### **Question #5:**

Q5: Copper hose fittings are requested. We utilize pex tubing and braided vinyl water lines. We find copper to be difficult to work with and most likely to freeze and break. Will you accept pex and pvc fittings?

A5: yes

#### **Question #6:**

Q6: External level indicator for waste tank requested. Is a digital monitoring system located in the mechanical room acceptable?

A6: Yes, as long as it can be operated by a 12-volt solar power system.

#### **Question #7:**

Q7: Black steel wheels requested. Silver steel wheels are in stock. Black wheels must be custom ordered and will be more expensive. Will you accept silver?

A7 : yes

#### **Question #8:**

Q8: 32" steel doors requested. Are aluminum frame doors with a fiberglass face/body acceptable?

A8: Yes

**Question #9:**

Q9: Motion activated interior and exterior lights requested. We currently utilize LED lights that have an extremely long life expectancy. Motion sensors can be problematic and a simple on/off switch for lighting is recommended. With LED lights the lights can be left on. Is this acceptable?

A9: Interior LED lighting activated by motion sensors is required. Exterior LED lighting activated by programmable timer is required. Refer to sections 2.33 and 2.34.

**Question #10:**

Q10: Regarding Mandatory Specification Criteria, Section 2.10. Specifications call for One (1) vented waste water reservoir with a minimum capacity of 370 US Gallons (1,400 L) to include visual external level indicator and external 3" twist-connect drain fitting and shut-off valve. Due to the size of the trailer would it be acceptable to have the 2 tanks with a combined capacity of minimum 370 US Gallons and have them located under the trailer? These tanks would have a level indicator and alarm located on the side of the trailer (exterior) and would also have the external 3" twist-connect drain fitting and shut-off valve.

A10: Two separate waste tanks with a combined minimum capacity of 370 US Gallons will be accepted as long as each individual tank is connected to service one individual restroom. In other words, the tanks are completely separated and not connected together, with one tank servicing the sink and toilet of unit A and the other tank servicing the sink, toilet and urinal of unit B. Each tank would have its own level indicator and alarm, as well as its own shut off valve and twist-connect drain fitting. Tanks will need to be operable under three-season conditions.

**Question #11:**

Q10: Section 2.6 to 2.10 Plumbing Specifications do not call for a hot water heater, is one required?

A10: A hot water heater is not required.

If your bid has already been forwarded and you wish to revise same, this revision should be sent either in a sealed envelope and mailed to the below noted address or by facsimile (506) 851-6759 and reach the undersigned before the appropriate closing date. The solicitation number and the closing date are to be shown on the outside of the sealed envelope or on the facsimile transmission.

All other terms and conditions of the solicitation document remain unchanged remain unchanged.

Solicitation No. - N° de l'invitation  
5P119-190791/A  
Client Ref. No. - N° de réf. du client  
5P119-190791

Amd. No. - N° de la modif.  
003  
File No. - N° du dossier  
MCT-8-41091

Buyer ID - Id de l'acheteur  
MCT033  
CCC No./N° CCC - FMS No./N° VME

---

All enquiries concerning this amendment are to be forwarded to:

Name: Leesa Young  
1045 Main Street,  
Moncton, NB  
E1C 1H1

Telephone No: (506) 871-1716  
Facsimile No: (506-851-6759  
Email: leesa.young@pwgsc-tpsgc.gc.ca