

CONCRETE FORMING AND ACCESSORIES**1 GENERAL****1.01 RELATED REQUIREMENTS**

- .1 Section 03 20 00 - Concrete Reinforcing
- .2 Section 03 30 00 - Cast-In-Place Concrete

1.02 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA-A23.1-14/A23.2-14, Concrete Materials and Methods of Concrete Construction/Methods of Test and Standard Practices for Concrete
 - .2 CSA-O86S1-05, Supplement No. 1 to CAN/CSA-O86-01, Engineering Design in Wood
 - .3 CSA O151-04, Canadian Softwood Plywood
 - .4 CSA S269.1-1975(R2003), Falsework for Construction Purposes
 - .5 CAN/CSA-S269.3-M92(R2003), Concrete Formwork, National Standard of Canada
- .2 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S701-05, Standard for Thermal Insulation, Polystyrene, Boards and Pipe Covering

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings for formwork and falsework.
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Ontario, Canada.
- .3 Submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 01 33 00 - Submittal Procedures.
- .4 Indicate method and schedule of construction, materials, arrangement of joints, ties, and liners. Comply with CSA S269.1, for falsework drawings. Comply with CAN/CSA-S269.3 for formwork drawings.
- .5 Indicate formwork design data: permissible rate of concrete placement, and temperature of concrete, in forms.

1.04 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 PRODUCTS

2.01 MATERIALS

- .1 Formwork materials:
 - .1 For concrete without special architectural features, use wood and wood product formwork materials to CAN/CSA-O86.
- .2 Form ties:
 - .1 Use removable or snap-off metal ties, fixed or adjustable length, free of devices leaving holes larger than 25 mm diameter in concrete surface.
- .3 Form release agent: non-toxic, biodegradable, low VOC.
- .4 Form stripping agent: colourless mineral oil, non-toxic, biodegradable, low VOC, free of kerosene, with viscosity between 15 to 24 mm²/s at 40 degrees C, flashpoint minimum 150 degrees C, open cup.
- .5 Falsework materials: to CSA-S269.1.

3 EXECUTION

3.01 FABRICATION AND ERECTION

- .1 Verify lines, levels and centres before proceeding with formwork/falsework and ensure dimensions agree with drawings.
- .2 Align form joints and make watertight.
- .3 Keep form joints to minimum.
- .4 Clean formwork in accordance with CSA-A23.1/A23.2, before placing concrete.

3.02 REMOVAL AND RESHORING

- .1 Leave formwork in place for a minimum of 7 days after placing concrete.
- .2 Remove formwork when concrete has reached 80% of its design strength or minimum period noted above, whichever comes later.

END OF SECTION

CONCRETE REINFORCING**1 GENERAL****1.01 RELATED REQUIREMENTS**

- .1 Section 03 10 00 Concrete Forming And Accessories
- .2 Section 03 30 00 Cast-In-Place Concrete

1.02 REFERENCES

- .1 CSA International
 - .1 CSA-A23.1-14/A23.2-14, Concrete Materials and Methods of Concrete Construction/Test Methods and Standard Practices for Concrete
 - .2 CAN/CSA-A23.3-14, Design of Concrete Structures
 - .3 CSA-G30.18-09, Carbon Steel Bars for Concrete Reinforcement
 - .4 CSA-G40.20/G40.21-04(R2009), General Requirements for Rolled or Welded Structural Quality Steel/Structural Quality Steel
- .2 Reinforcing Steel Institute of Canada (RSIC)
 - .1 RSIC-[2004], Reinforcing Steel Manual of Standard Practice

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Prepare reinforcement drawings in accordance with RSIC Manual of Standard Practice.
- .3 Shop Drawings:
 - .1 Indicate placing of reinforcement and:
 - .1 Lists.
 - .2 Quantities of reinforcement.
 - .3 Sizes, spacings, locations of reinforcement
 - .2 Detail lap lengths and bar development lengths to CAN/CSA-A23.3, unless otherwise indicated.
 - .1 Provide type B tension lap splices where indicated, unless otherwise indicated.

1.04 QUALITY ASSURANCE

- .1 Submit in accordance with Section 01 45 00 - Quality Control and as described in PART 2 - SOURCE QUALITY CONTROL.
 - .1 Mill Test Report: upon request, provide Departmental Representative with certified copy of mill test report of reinforcing steel.
 - .2 Upon request submit in writing to Departmental Representative proposed source of reinforcement material to be supplied.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Storage and Handling Requirements:

CONCRETE REINFORCING

- .1 Store materials in clean, dry, well-ventilated area.
- .2 Replace defective or damaged materials with new.

2 PRODUCTS**2.01 MATERIALS**

- .1 Substitute different size bars only if permitted in writing by Departmental Representative.
- .2 Reinforcing steel: billet steel, grade 400, deformed bars to CSA-G30.18, unless indicated otherwise.
- .3 Chairs, bolsters, bar supports, spacers: to CSA-A23.1/A23.2.

2.02 FABRICATION

- .1 Fabricate reinforcing steel in accordance with CSA-A23.1/A23.2 and Reinforcing Steel Manual of Standard Practice by the Reinforcing Steel Institute of Canada.
- .2 Ship bundles of bar reinforcement, clearly identified in accordance with bar lists.

2.03 SOURCE QUALITY CONTROL

- .1 Upon request, provide Departmental Representative with certified copy of mill test report of reinforcing steel, showing physical and chemical analysis,
- .2 Upon request inform Departmental Representative of proposed source of material to be supplied.

3 EXECUTION**3.01 PLACING REINFORCEMENT**

- .1 Place reinforcing steel as indicated on placing drawings and in accordance with CSA-A23.1/A23.2.
- .2 Prior to placing concrete, obtain Departmental Representative's approval of reinforcing material and placement.
- .3 Ensure cover to reinforcement is maintained during concrete pour.

3.02 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance

with Section 01 74 21 - Construction/Demolition Waste Management and Disposal

END OF SECTION

1 GENERAL**1.01 RELATED REQUIREMENTS**

- .1 Section 03 10 00 Concrete Forming and Accessories
- .2 Section 03 20 00 Concrete Reinforcing

1.02 REFERENCES

- .1 Abbreviations and Acronyms:
 - .1 Portland Cement:
 - .1 Type GU - General use cement
- .2 Reference Standards:
 - .1 ASTM International
 - .1 ASTM C 260/C 260M-10a, Standard Specification for Air-Entraining Admixtures for Concrete
 - .2 CSA International
 - .1 CSA A23.1/A23.2-14, Concrete Materials and Methods of Concrete Construction/Methods of Test and Standard Practices for Concrete
 - .2 CSA A283-06, Qualification Code for Concrete Testing Laboratories
 - .3 CSA A3000-13, Cementitious Materials Compendium (Consists of A3001, A3002, A3003, A3004 and A3005)

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Provide copies of WHMIS MSDS in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.04 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Provide Departmental Representative, minimum 2 weeks prior to starting concrete work, with valid and recognized certificate from plant delivering concrete.
- .3 Minimum 2 weeks prior to starting concrete work, provide proposed documents for review by Departmental Representative on following items:
 - .1 Concrete mix design
- .4 Quality Control Plan: provide written report to Departmental Representative verifying compliance that concrete in place meets performance requirements of concrete as established in PART 2 - PRODUCTS.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Delivery and Acceptance Requirements:
 - .1 Concrete hauling time: deliver to site of Work and discharged within 120 minutes maximum after batching.

CAST-IN-PLACE CONCRETE

- .1 Do not modify maximum time limit without receipt of prior written agreement from Departmental Representative and concrete producer as described in CSA A23.1/A23.2.
- .2 Deviations to be submitted for review by Departmental Representative.
- .2 Concrete delivery: ensure continuous concrete delivery from plant meets CSA A23.1/A23.2.

2 PRODUCTS**2.01 DESIGN CRITERIA**

- .1 Performance: to CSA A23.1/A23.2, and as described in MIXES of PART 2 - PRODUCTS.

2.02 MATERIALS

- .1 Portland Cement: to CSA A3001, Type GU.
- .2 Water: to CSA A23.1.
- .3 Aggregates: to CSA A23.1/A23.2.
- .4 Admixtures:
 - .1 Air entraining admixture: to ASTM C 260.
 - .2 Chemical admixture: to ASTM C 494 Departmental Representative to approve accelerating or set retarding admixtures during cold and hot weather placing.

2.03 MIXES

- .1 Prescriptive Method for specifying concrete: concrete mix to CSA A23.1, Type F-2
 - .1 Ensure materials used in concrete mix have been submitted for testing and meet requirements of CSA A23.1.

3 EXECUTION**3.01 PREPARATION**

- .1 Obtain Departmental Representative's written approval before placing concrete.
 - .1 Provide 24 hours minimum notice prior to placing of concrete.
- .2 Place concrete reinforcing in accordance with Section 03 20 00 - Concrete Reinforcing.
- .3 During concreting operations:
 - .1 Development of cold joints not allowed.
 - .2 Ensure concrete delivery and handling facilitates placing with minimum of re-handling, and without damage to existing structure or Work.
- .4 Pumping of concrete is permitted only after approval of equipment and mix.
- .5 Ensure reinforcement and inserts are not disturbed during concrete placement.

CAST-IN-PLACE CONCRETE

- .6 Prior to placing of concrete obtain Departmental Representative's approval of proposed method for protection of concrete during placing and curing.
- .7 Protect existing surfaces from staining.
- .8 Clean and remove stains prior to application for concrete finishes.
- .9 Maintain accurate records of poured concrete items to indicate date, location of pour, quality, air temperature and test samples taken.
- .10 In locations where new concrete is dowelled to existing work, drill holes in existing concrete.
 - .1 Place steel dowels and pack solidly with adhesive to anchor and hold dowels in positions as indicated.
- .11 Do not place load upon new concrete until authorized by Departmental Representative.

3.02 INSTALLATION/ APPLICATION

- .1 Do cast-in-place concrete work to CSA A23.1/A23.2.
- .2 Finishing and curing:
 - .1 Finish concrete to CSA A23.1/A23.2.

3.03 FIELD QUALITY CONTROL

- .1 Site tests: conduct tests as follows in accordance with Section 01 45 00 - Quality Control and submit report.
 - .1 Concrete pours.
 - .2 Slump.
 - .3 Air content.
 - .4 Compressive strength at 7 and 28 days.
 - .5 Air and concrete temperature.
- .2 Inspection and testing of concrete and concrete materials will be carried out by testing laboratory designated by Departmental Representative for review to CSA A23.1/A23.2.
 - .1 Ensure testing laboratory is certified to CSA A283.
- .3 Departmental Representative will pay for costs of tests as specified in Section 01 00 10 – General Instructions.
- .4 Departmental Representative will take additional test cylinders during cold weather concreting. Cure cylinders on job site under same conditions as concrete which they represent.
- .5 Non-Destructive Methods for Testing Concrete: to CSA A23.1/A23.2.
- .6 Inspection or testing by consultants will not augment or replace contractor quality control nor relieve Contractor of his contractual responsibility.

3.04 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION