



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:
 Parks Canada Agency
 220 4 Ave SE, Suite 720
 Calgary, AB T2G 4X3

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency
 We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
220 4 Ave SE, Suite 720
Calgary, AB T2G 4X3

Title-Sujet Miette Hot Springs Generator Replacement – Jasper National Park		
Solicitation No. - No. de l'invitation 5P420-18-0454/A	Date: December 20, 2018	
GETS Reference No. – No de reference de SEAG PW-18-00854051	Amendment No. - N° de la modif. 2	
Solicitation Closes:		
at – á 02:00 PM	on – le January 10, 2019	Time Zone - Fuseau horaire MST - HNR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Rebecca Chen rebecca.chen2@canada.ca		
Telephone No. - No de téléphone (587) 439-3529	Fax No. – No de FAX: 1-866-246-6893	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 02

This amendment is being raised to distribute information from the site visit and to distribute questions and answers.

A) SITE VISIT ATTENDEES

Vendor	Representative's Name
Jasper Concrete Ltd.	Steven Colbath Merle Murphy

Contact information for the attendees are available upon request and approval from the vendors.

B) TENDER PACKAGE REVISIONS

ADD: DSP2_18-0454: 181-13597-15 - Electrical Addendum E001 2018-12-17

CHANGE TO DRAWING E100 – SITE PLAN AND ELECTRICAL LEGEND. Refer to the clouded areas on the attached drawing E100 for changes to the site plan.

CHANGE TO DRAWING E101 – LOWER LEVEL ELECTRICAL DEMOLITION AND CONSTRUCTION PLANS. Refer to the clouded areas on the attached drawing E101 for changes existing device locations.

ADD: DSP2_18-0454:
electrical room.JPG
generator room.JPG
Genset proposed location.JPG
transfer switch.JPG

C) SPECIFICATIONS

SECTION 26 32 13 – ENGINE GENERATORS

DELETE: 2.6.4.1 – "Fuel tank base to be twenty-four (24) hour capacity..."

REPLACE WITH: "Fuel tank base to be forty-eight (48) hour capacity..."

ADD: Section 2.8 - Generator manufacturer to provide an external load bank for the generator. This load bank is to maintain a minimum load of 30% for the generator when it is operating. If the building load is above 30%, the load bank is to turn off. This load bank is to ensure the generator has a minimum load at all times while running to ensure it does not get damaged during colder temperatures.

ADD: Article 2.1.1.6 – MTU Onsite Energy is an acceptable manufacturer. Please note, it is still a requirement of the manufacturer and the contractor to ensure the generator being supplied meets the requirements in the specifications.

ADD: Article 2.1.1.7 – Generac is an acceptable manufacturer. Please note, it is still a requirement of the manufacturer and the contractor to ensure the generator being supplied meets the requirements in the specifications.

D) QUESTIONS & ANSWERS

Q1 Is the concrete pad part of this tender package?

A1 No, the concrete pad as well as some other minor structural and mechanical will be tendered separately early in the New Year.

Q2 Is the road cleared of snow in winter?

A2 Parks Canada highways department is responsible for snow clearing on the Miette road during the winter. The Miette road is lower priority than nearby major highways and snow clearing may be delayed after a big snowfall.

Q3 What is access for removing the existing generator?

A3 There are double doors into the Generator room and a garage bay door directly adjacent.

All other terms and conditions remain unchanged.