

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

PART 2 - PRODUCTS

2.1 RECEPTACLES

- .1 Receptacles, plugs, and similar wiring devices to: CSA C22.2 #42M-1984.
- .2 Duplex receptacles, marine grade, flush mounted CSA type 5-15 R, 125 V, 15 A, U ground, with following features:
 - .1 Yellow urea moulded housing.
 - .2 Suitable for No. 10 AWG for back and side wiring.
 - .3 Break-off links for use as split receptacles.
 - .4 Eight back wired entrances, four side wiring screws.
 - .5 Double wipe contacts and riveted grounding contacts.
- .3 All receptacles shall be marine grade and of one manufacturer throughout project.
- .4 Supply and install other marine grade receptacles as indicated on drawings.

2.2 COVERPLATES

- .1 PVC marine grade cover plates for wiring devices unless otherwise indicated on plans.
- .2 Cover plates from one

manufacturer throughout project.

- .3 PVC cover plates for wiring devices mounted in surface mounted FS or FD type unless otherwise indicated on plans.
- .4 Weatherproof cover plates as indicated.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Receptacles:
 - 1. Install receptacles in gang type outlet box when more than one receptacle is required in one location.
 - 2. Mount receptacles at height specified in Section 26 05 01 - Common Work Results - Electrical or as indicated.
- .2 Cover plates:
 - 1. Protect cover plate finish with paper or plastic film until painting and other Work is finished.
 - 2. Install suitable common cover plates where wiring devices are grouped.
 - 3. Do not use cover plates meant for flush outlet boxes on surface-mounted boxes.
 - 4. Contractor to run separate neutral for each circuit.

END OF SECTION