

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 PRODUCT DATA

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Include time-current characteristic curves for breakers with ampacity of 300 Amp and over with interrupting capacity of 10,000 Amp symmetrical (rms) and over at system voltage.

PART 2 - PRODUCTS

2.1 BREAKERS -
GENERAL

- .1 Bolt-on moulded case circuit breaker: quick-make, quick-break type, for manual and automatic operation with temperature compensation for 40°C ambient.
- .2 Common-trip breakers: with single handle for multi-pole applications.
- .3 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting. Trip settings on breakers with adjustable trips to range from 3 to 8 times current rating.
- .4 Circuit breakers with interchangeable trips as

indicated.

- .5 Interrupting capacity to match existing. Coordinate on site.

2.2 THERMAL MAGNETIC
BREAKERS - DESIGN A

- .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install circuit breakers in existing panels as indicated.

END OF SECTION