

PART 1 - GENERAL

- 1.1 SECTION INCLUDES .1 Materials and installation for Wire and Box Connectors (0 - 1000 V).
- 1.2 RELATED SECTIONS .1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

PART 2 - PRODUCTS

- 2.1 MATERIALS .1 Pressure type wire connectors: with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors: with current carrying parts of copper sized to fit copper conductors 10 AWG or less.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Remove insulation carefully from ends of conductors and:
- .1 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2 No. 65.

END OF SECTION