



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Portable DC Load Bank	
Solicitation No. - N° de l'invitation W355B-192865/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client W355B-19-2865	Date 2019-01-03
GETS Reference No. - N° de référence de SEAG PW-\$HAL-219-10553	
File No. - N° de dossier HAL-8-81110 (219)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-01-11	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Richard, Linda K.	Buyer Id - Id de l'acheteur hal219
Telephone No. - N° de téléphone (902) 402-9059 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

AMENDMENT 3

This amendment is issued to reflect the following :

1. Bid Closing Date

Delete: January 8, 2019 2:00 pm AST

Insert: January 11, 2019 2:00 pm AST

2. In response to the following bidder questions

Question 1:

For the installation aspect of the new load bank can we have layout drawings or pictures showing where all of the existing services (air, electrical, water) are in relation to where the load bank will be secured. This is necessary in order to know sizing to tie in points and accurate distances.

Answer 1:

This is a portable load bank we are requesting. The SOR state the unit must have one or multiple 35m cables to connect the auxiliary power.

Question 2:

Is there time to schedule a site visit and/or possibly take pictures if information requested in Item # 1 is not available.

Answer 2:

The load bank is meant to be portable, and therefore does not have a specific location where it will be secured.

Question 3:

Can you provide any additional information on the core hole requirement, thickness of concrete etc.

Answer 3:

Unless the equipment they are proposing requires air or water connections, no core drilling will be required as the electrical outlets are already positioned outside of building throughout the dockyard.

Question 4:

As part of the turn key aspect does DND require an engineered stamped drawing that shows the final tie-ins from your existing services to the new DC load bank?

Answer 4:

No. The only connection that was been requested in the SOR is for the equipment to come equipped with one or multiple 35m cables to provide power to the unit.

Please note: No further questions will be addressed prior to bid closing.

All other terms and conditions remain unchanged.