



RETURN BIDS TO:
 RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
 Mailroom
 30 Victoria Street
 Gatineau, Quebec, J8X 0B3**

Amendment #5

INVITATION TO TENDER
 APPEL D'OFFRES

Tender To: Parks Canada Agency
 We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
 Mailroom
 30 Victoria Street
 Gatineau, Quebec, J8X 0B3**

Title-Sujet Replacement of Horseshoe Lake Dam and Twelve Mile Lake Dam, Trent-Severn Waterway National Historic Site		Date 7 January , 2019
Solicitation No. - No. de l'invitation 5P201-18-0092/B	Client Ref. No. - No. de réf du client. 352 and 1361	
GETS Reference No. - No de reference de SEAG PW-18-00835782		
Solicitation Closes L'invitation prend fin - at - à 02:00 PM on - le 2019-01-08	Time Zone Fuseau horaire - Eastern Standard Time (EST)	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Patrick Sullivan at Patrick.Sullivan2@canada.ca		
Telephone No. - No de téléphone (819) 420-9557	Fax No. - No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature	Date	



AMENDMENT #5

THIS ADDENDUM IS TO POST QUESTIONS AND ANSWERS

Question 41. 12 Mile Lake Dam: Sheet piles Upstream crossing underneath the power line (Drawing 104) is impossible to be erected safely. The Powerline has to be relocated. Please clarify.

Answer 41. As per the note on drawing 101 and Section 01 14 00 1.4.13 of the specifications, the Contractor is responsible for protecting existing overhead lines in coordination with the utility provider. The Contractor is also responsible for designing a cofferdam that can be erected safely.

ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED