

ADDENDUM NUMBER: ONE (01)

ADDENDUM DATE: JANUARY 8, 2019

ISSUED BY: EXP SERVICES INC.
40 Henri Dunant Street, Moncton, NB E1E 1E5
PH. (506) 857-8889

PROJECT: Supply and Install Fire Alarm System
GOCB Public Safety Cambridge Bay, NU

This Addendum forms part of the Contract Documents and amends the original Drawings and Specifications dated 2018-11-26, previous Addenda if applicable, and as noted below.

This Addendum consists of 2 pages.

Ensure that all parties are aware of all items included in this Addendum.

The following revised or additional Drawings accompany and form an integral part of this Addendum:

Dwg. No.	Title	Date of Issue
N/A		

ELECTRICAL

E-1-2 ELECTRICAL QUESTIONS

- .1 Q: Will the use of strobes set to 15 Candela be permitted? CAN/ULC S524-06 Table 5 "Light output for wall-mounted visible signal devices for various room sizes" the table only starts at 15 Candela.
- A: Yes, the use of 15 candela strobes and horn/strobes is permitted. Please note intensity of devices shall be field adjustable, minimum 15 candela.

E-1-3 ELECTRICAL REQUESTS FOR EQUALS

- .1 The following products and / or equipment and / or systems have been reviewed as equal to the products and / or equipment and / or systems specified. Acceptance shall be provided that functionality, particulars, accessories and / or other adjustments required or specified are included and met.

Specification Section	Specified Product	Approved Equivalent	Not Approved Equivalent
28 31 00 – FIRE DETECTION AND ALARM			Kidde

END OF ADDENDUM No. 1