
ADDENDUM NO. 2

Q & A

Question No.

1.	<p>Q: Section 01 00 11 (page 1) of the specifications indicates that a 3mm protection board is part of the new roof system. However Section 07 52 00 (page 11) and the drawings mention a 6mm protection board. Please confirm the thickness.</p> <p>A: The correct thickness is a 6 mm protection board and has been addressed by item 2.4 of Addendum 2.</p>
2.	<p>Q: Section 07 52 00, page 11, art. 2.9 – polystyrene insulation: It is mentioned “Where indicated, provide drainage grooves on underside of board”. We don’t see any indication on the drawings. Where is it required? Or can we supply standard XPS insulation only?</p> <p>A: You can supply standard XPS only. Item 2.9 of Addendum 2 addresses this change.</p>