



AMENDMENT / MODIFICATION

006

**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit
National Contracting Services
220 - 4 Avenue S.E., suite 720
Calgary, AB T2G 4X3

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Issuing Office - Bureau de distribution

Parks Canada Agency
National Contracting Services
220 - 4 Avenue S.E., suite 720
Calgary, AB T2G 4X3

Title-Sujet Lake Louise Water Infrastructure Upgrades – Banff National Park		
Solicitation No. - No. de l'invitation 5P420-18-0432/A		Date: January 16, 2019
GETS Reference No. – No de reference de SEAG PW-18-00854687		Amendment No. - N° de la modif. 006
Solicitation Closes:		
at – á 02:00 PM	on – le January 22, 2019	Time Zone - Fuseau horaire MST - HNR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Jen Maheu jennifer.maheu@canada.ca		
Telephone No. - No de téléphone (587) 432-8458		Fax No. – No de FAX: (866) 246-6893
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 06

This amendment is being raised to distribute questions and answers.

A) QUESTIONS AND ANSWERS

Q66 Husky sign and tourist information sign to be demolished, are these to be put up again or disposed of?

A66 See response to Q51 in Amendment 5. No replacement is required.

Q67 Are we responsible to take down and re-erect street lights at Lake Louise Drive and at Husky Gas Station?

A67 Yes.

Q68 Does the fire hydrant on visitor centre entrance have to be connected to new 30mm line? (Drawing states 50mm connection, assume it is at least 150mm) If it connects to this line or fed from elsewhere?

A68 The existing hydrant located at approximately 1 + 610 is to be connected to the new 300 mm main. Assume the existing hydrant lead is 150 mm diameter.

Q69 The 200mm valve to be installed on Samson Mall service, is this in sod/landscaping area to determine reinstatement. (Has this valve been accounted for in unit price table or just 200mm valve at Hector Road?)

A69 See the response to Q58 in Amendment 5. Change Estimated Quantity in Price Table Item E4.2.2 from 1 to 2.

Q70 Is there any extra process piping or equipment to demolish prior to installing the processed process piping?

A70 All demolition is shown on the drawings or stipulated in the Specifications.

Q71 Has work to be carried out to isolate and remove or relocate existing underground electrical at reservoir site (abandoned reservoir)?

A71 The Contractor will be required to confirm the existing service has been terminated.

Q72 Are private locates required for site locations 1 & 2?

A72 The Contractor is responsible for locating of existing utilities at all Locations.

All other terms and conditions remain unchanged.