



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

| | |
|---|--|
| Title - Sujet Generator Package | |
| Solicitation No. - N° de l'invitation 5P426-181671/B | Amendment No. - N° modif. 002 |
| Client Reference No. - N° de référence du client 5P426-181671 | Date 2019-01-21 |
| GETS Reference No. - N° de référence de SEAG PW-\$EDM-206-11509 | |
| File No. - N° de dossier EDM-8-41072 (206) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-01-31 | Time Zone Fuseau horaire Mountain Standard Time MST |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Brent Peters | Buyer Id - Id de l'acheteur edm206 |
| Telephone No. - N° de téléphone (780) 235-8279 () | FAX No. - N° de FAX (780) 497-3510 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation
5P426-181671/B
Client Ref. No. - N° de réf. du client
5P426-181671

Amd. No. - N° de la modif.
002
File No. - N° du dossier
EDM-8-41072

Buyer ID - Id de l'acheteur
edm206
CCC No. /N° CCC - FMS No./N° VME

This amendment is issued to extend the solicitation closing date to that which is indicated on the cover page of this amendment and to answer the following questions received:

Q1: Please advise if 3" pintle ring is acceptable instead of ball hitch?

A1: Yes a 3" pintle ring would be acceptable as well as a ball hitch as specified.

Q2: Does the end user have the female end as that will be the end that will be on the generator or do we have to include the connector as well as the cabling?

A2: No we do not have either end and the proponent will have to supply the connections installed on the cable.

Q3: Does the end user require 3 runs of 50 feet or does 50 ft. include 3 runs?

R3: As per the specs we require a single 50 ft. cable to connect the generator to our lift station panel.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME