



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**

PWGSC/TPSGC Acquisitions Bid  
Receiving/Réception des Soumissions  
Sherwood Business Centre  
161 St. Peters Road/rue St. Peters  
2nd Floor, Suite 204/  
2ième étage, pièce 204  
Charlottetown  
Prince Edward Island  
C1A 5P7  
Bid Fax: (902) 566-7514

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

All enquiries are to be submitted in writing to the Contracting Authority, Darlene Reay, either by facsimile or by e-mail at:  
darlene.reay@pwgsc.gc.ca.

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
Sherwood Business Centre  
161 St. Peters Road/  
161, rue St. Peters  
2nd Floor, Suite 204/  
2ième étage, pièce 204  
Charlottetown  
Prince Ed  
C1A 5P7

<b>Title - Sujet</b> Ardgowan NHSC Landscape	
<b>Solicitation No. - N° de l'invitation</b> ED001-192363/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> ED001-192363	<b>Date</b> 2019-01-24
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-008-4392	
<b>File No. - N° de dossier</b> PWC-8-41082 (008)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-01-30</b>	
<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Reay, D (PWC)	<b>Buyer Id - Id de l'acheteur</b> pwc008
<b>Telephone No. - N° de téléphone</b> (902) 314-7957 ( )	<b>FAX No. - N° de FAX</b> (902) 566-7514
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

## **TENDER CLOSING**

Notice is hereby given that the closing date for tenders has been extended from Tuesday, January 29, 2019 to:

**Wednesday, January 30, 2019 at 2:00pm**

## **TENDER CLOSING**

## **REMINDER – CHANGE OF OFFICE ADDRESS**

Contractors are reminded that Public Services & Procurement Canada, Charlottetown office has moved to:

Sherwood Business Centre  
161 St. Peters Road  
2<sup>nd</sup> Floor, Suite 204  
Charlottetown, PEI  
C1A 5P7

## **This Addendum is raised to provide the following answers to questions provided by bidders.**

### **Q1**

How would you scarify the gravel paths and wouldn't that contaminate the gravel with the subsoil. Which spots will need gravel where it is holding gravel. maybe just pick a number of inches of gravel to top up the existing paths and avoid scarifying.

### **A1**

Scarifying is necessary to permit reshaping of the path profile and maintaining the character of the cultural landscape. Pathways/trails were built with sufficient base material to allow for scarifying without contamination of subsoil.