



6 EXISTING POWER DISTRIBUTION SINGLE LINE DIAGRAM
E6
SCALE: N.T.S.

GENERAL NOTES:

- ALL WORK THAT AFFECTS SITE OPERATIONS TO TAKE PLACE BETWEEN THE HOURS OF 10:00AM SATURDAY AND 11:00PM SUNDAY.
- ENSURE ALL NEW AND EXISTING ELECTRICAL DISTRIBUTION EQUIPMENT MODIFIED IN THIS CONTRACT IS IDENTIFIED IN ACCORDANCE WITH THE FACILITIES MAINTENANCE PROGRAM.
- INFORMATION ON THIS DRAWING IS FROM AN EXISTING PWGSC POWER DISTRIBUTION SINGLE LINE AND HAS NOT BEEN FIELD VERIFIED. VERIFY RELEVANT INFORMATION BEFORE COMMENCING WORK.
- 2/PH AND 4N = 2 PER PHASE AND 4 NEUTRALS.

NOTES

- EXISTING P.T.S AND C.T.S AND METERING FOR TOWN OF SUMMERSIDE UTILITY METERING TO REMAIN.
- EXISTING P.T.S AND C.T.S FOR OWNER'S METERING / RELAYING TO BE REMOVED.

0	ISSUED FOR TENDER	OCT 22 2018
revisions		date

project
ELECTRICAL SWITCH GEAR REPLACEMENT SUMMERSIDE TAXATION CENTRE
SUMMERSIDE, PEI

drawing
EXISTING POWER DISTRIBUTION SINGLE LINE DIAGRAM
design

designed R.A.P.	conçu
date OCTOBER 2018	
drawn D.D.	dessiné
date OCTOBER 2018	
approved B.E.T.	approuvé
date OCTOBER 2018	
Tender	Submission
PWGSC Project Manager	Administrateur de projets TPWGC
project	projet
R.097303.001	
drawing no.	no. du dessin
E6 OF 6	