



- NOTES:
- 1- EXISTING VENTILATION SYSTEMS # 1, 2, 3 AND 4 ARE HIGH-PRESSURE NETWORK.
- 2- ALL SUPPLY DUCTS DOWNSTREAM TERMINAL BOXES MUST BE PROVIDED WITH 25mm ACOUSTICAL LINER.
- EXISTING BOXES (MAINTAINED OR RELOCATED): CLEAN, REPAIR, OR REPLACE, AS NEEDED, THE EXISTING LINER.
- NEW BOXES: NEW ACOUSTICAL LINER.