

**Part 1            ADDENDUM NO.5**

**1.1                General**

- .1            This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2            In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

**Part 2            Question**

**Q: Can we use wire mesh in the concrete slabs that we have to build?**

A: Concrete mesh can be added to the slabs but all of the reinforcing steel must remain.

**END OF SECTION**