

Annex A: Specification Addendum

1. REFERENCE: DRAWING E-1

1. Revise breakers for HU-1 and HU-2 to 2P-30A; feeder to 2#10. Revise note 4 to note 2. HU-1 and HU-2 replacement is a separate price, refer to general conditions.

END OF ELECTRICAL ADDENDUM NO. E-1