



**Canadian Mounted Police
Gendarmerie royale du Canada**

RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Groupe de la réception des soumissions

Procurement & Contracting Services / Services d'acquisitions et des marchés.

Royal Canadian Mounted Police
73 Leikin Drive,
Mailstop \$15,
Ottawa, Ontario
K1A 0R2
Attn: Diane Perkins

Telephone No./no de téléphone: (613) 843-5904

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté I Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone: ()

Facsimile No. – No de télécopieur: ()

Title-Sujet Construction of Coaldale Detachment		
Solicitation No. – No. de l'invitation 201904154	Amend. – Modif. No. : 2	Date February 19, 2019
Client Reference No. - No. de Référence du Client 201904154		
GETS Reference No. – No de Référence du SEAG PW-19-00861495		
Solicitation Closes – L'invitation prend fin at – à 2:00 P.M EST (Eastern Standard Time) on – March 8, 2019		
F.O.B. - F.A.B. Destination		
Address Enquiries to: - Adresser toute questions à : Diane Perkins		
Telephone No. - No de telephone 613-843-5904	Fax: 613-825-0082	
Destination of Goods - Destinations des biens: See Herein		
Instructions : See Herein / Voir aux présentes		
Delivery Required – Livraison exigée: See Herein		
Name and Title of person authorized to sign on behalf of Vendor/Firm. Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		



Amendment No. 2

Construction – Coaldale Detachment

SOLICITATION NO. : 201904154

Date: February 19, 2019

Solicitation Amendment: 002

Part 1: Respond to Questions Submitted

Part 2: Addendum #1 – Specifications and drawings have been added to this tender, under the Attachment section.

Part 1 - Question/Answer:

Question #1:

Is the RCMP detachment in Coaldale a concrete or brick building or steel building?

Response #1:

Please review the specifications and construction drawings.

Question #2:

Could you clarify if galvanized reinforcement is a requirement for the RCMP Detachment in Coaldale? The specs call for galvanizing however the drawings call for reinforcing to be grade 400.

Answer #2:

There is no galvanized concrete reinforcing required for the Protective Services Building (RCMP Detachment) in Coaldale.

Question #3:

Would the project require seismic restraint on the sprinkler system as it's considered a post disaster facility?

Answer #3:

Added in mechanical addendum 1.

Question #4:

On the fire protection specification, it noted an alarm valve complete with trim was to be supplied and installed, but the drawings did not show the alarm but (2) zone valves only. Please advise if a alarm is required for this project

Answer #4:

Revised in mechanical addendum 1.

Question #5:

Please request the fire extinguisher cabinet type for FEX-R, FEX-SR and FEX-1

Answer #5:

Added in mechanical addendum

Question #6:

Can we utilize schedule 40 pipe instead of the cast iron ductile pipe for the pipe sleeves



Answer #6:

Clarified in mechanical addendum 1.

Question #7:

I am the Western Canada Representative for a company called Rockfon. Rockfon is a subsidiary of Rockwool, the makers of Roxul Stone Wool Insulation. We've taken that exact same Stone Wool product, added a face to it and made it into a Ceiling product. We also purchased Chicago Metallic Metal and Suspension Systems to provide the whole package; Grid, Specialty Metal Panels and Stone Wool Ceiling Panels. While only being in North America for 6 years now.

Even though this product is Stone Wool fibres, it's important to clarify that we are still classified under ASTM E1264 as a Mineral Fibre product. Stone Wool achieves great Acoustical Values, has a thermal value to it, is Hydrophobic and completely inert to viruses, mould and mildew, requiring no added biocides simply because there is no food source. All Stone Wool Panels are also rated 'Gold' by GreenGuard for low V.O.C.'s.

I am providing you today with a request for approval in regards to section 09 51 13 Acoustical Panel Ceilings, and please see the attached supporting documents:

1. Our Submittal for Approval, with Comparison
2. Data Sheet for the Alaska dB Ceiling Tile
3. Data Sheet for the Cinema Black Ceiling Tile
4. Data Sheet for the 1200 Series Suspension System

Answer #7:

The substitution is acceptable. Section 09 51 13 will be revised by addendum to include this information.

Questions #8:

Security Requirements Questions:

1. Is ERS similar to RRS (RCMP Reliability Status)? ERS is specified in the Special comments of the SRCL PART B Box 10.a) but is not mentioned elsewhere in the Invitation to Tender or security clauses provided.
2. Can you provide estimated processing times for the various levels of personnel security namely ERS and FA-2?
3. Are existing valid PWGSC personnel clearance equivalent to any RCMP issued clearances? If not, do existing valid PWGSC personnel clearances decrease processing times for new RCMP personnel clearance requests?

Answer #8:

1. An ERS security clearance is an Enhanced Reliability Status security clearance and is the same as an RRS, RCMP Reliability Status security clearance.
2. An FA-2 clearance usually takes approximately 2 weeks to obtain once the properly completed security forms have been submitted to the RCMP. An ERS security clearance can take approximately 3 to 6 months to obtain once the properly completed security forms have been submitted to the RCMP. Times may vary depending on the workload.
3. No PWGSC personnel clearances are not equivalent to RCMP security clearances. No, existing valid PWGSC issued personnel clearances do not decrease processing times for new RCMP personnel clearance requests

Questions #9:



**Canadian Mounted Police
Gendarmerie royale du Canada**

As per spec section 09 80 00, 2.1.2.1.2, the fabric finish states "as indicated" however I do not see it anywhere – can I get clarification on this please?

Answer #9:

Clarified in Addendum 1.

Question #10:

Question for metal locker as per spec 10 51 13:

- Type L5, Manufacturer Spacesaver EDHGS10155.15 The model number EDHGS makes sense but the digits

afterwards don't and neither the description. Please clarify.

- Type L7 states 'surface mounted', but then says 'recessed 10 door unit'. Is it to be surface or recessed?
- Type 8 states 'flush installation'. I'm not sure if this means surface or recessed installation.
- Type L1-L4 lists Shanahan's as an acceptable substitution but does not state the preferred manufacturer or

model number

Answer #10:

- L5: Clarification will be provided as to a supplier of the locker system.
- L7: Clarification will be provided in an addendum
- L8: Clarification will be provided in an addendum
- L1-L4 Wording will be changed via addendum to acceptable manufacturer.

Question #11:

Please confirm if the alternate roof system for roof system R1&R3 is acceptable:

As per section 01 62 00-1.7, The system we propose would be as follows:

Fully Adhered system to match/exceed as specified in 07 52 00

60 Mil TPO

HD Iso board or Densdeck prime 1/2"

2 layers flat Insulation (plus EPS/or PolyIso Tapered)

Self Adhered Vapor Barrier and Primer

Densdeck Prime 1/2"

On Metal Deck by others

Answer #11:

The systems described in section 07 52 00 are further broken out into specific materials. If a substitution is requested it must be provided for the specific materials. Requesting an alternate system without product information for comparison does not meet the intent of the substitution requirements. Provide product information for specific materials to be considered for substitution.

Question #12:

The bid closing time is listed as 2:00 pm ET, again since the project is located in Alberta and most GC's are in Alberta on MT is it possible to extend the closing time to 2:00 pm MT to give us the standard time frame to complete our bids?

Answer #12:

No changes to be made.

Question #13:

Will a bid bond be required for the project?

Answer #13:



Canadian Mounted Police
Gendarmerie royale du Canada

The information is included in the ITT.

**R2710T GENERAL INSTRUCTIONS TO BIDDERS - CONSTRUCTION SERVICES - BID SECURITY REQUIREMENTS
(GI) (2018-06-21)**

The following sections of clause R2710T are set out in Web site;

<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R>
GI08 Bid Security Requirements

Part 2 – Addendum #1:

Addendum #1 – Specifications and drawings have been added to this tender, under the Attachment section.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.