

Addendum/Addenda

No./N°

1

Project Description / Description de projet PEN - Electrical upgrade to CART facility		
Solicitation No./ N° de sollicitation RFP 18-22105	Project No./N° de projet PEN-5673	W.O. No./N° d'ordre de travail
Departmental Representative / Représentant Ministériel Kory Phillips	Date 2019-02-28	
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

This Addendum is issued in response to the following questions and information provided during the tender visits.

1. Please see attached pictures which were taken during the installation of the conduit. The current ground conditions are all finished to grade.
2. Contractor must provide manufacturer and model of all equipment supplied by them, in their bid package.
3. Contractor must provide 15kV cable and substation testing companies name and confirm that the test results will be reviewed and sealed by a P.Eng.
4. Contractor must provide the name of the structural engineering firm that will be designing the concrete pad for the unit substation with the bid package.
5. Clarification regarding the note on drawings that the "installation must comply with the requirements of CEC C22.1-18". The electrical installation must comply with the current BC Electrical Code.









