

The following changes to the tender documents are effective immediately and will form part of the contract documents:

Refer to Drawing A5.0 Door Schedule:

1) Change doors 101a, 102, BD100, BD104a, BD104b, BE102 to be 50mm thickness.

Refer to Drawing A4.3 Detail 5/A4.3 and 6/A4.3:

2) Change all reference to aluminum mullions to be steel mullions typical.

Refer to Hardware group 8

3) hardware group #8 to have a new frame and be used on Door 108 for the New Dispensary

END OF ADDENDUM NO. 1