

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 06 40 00 - Architectural Woodwork.
- .2 Section 06 47 00 – Plastic Laminate Finishes.
- .3 Section 08 70 05 – Cabinet and Miscellaneous Hardware.
- .4 Section 09 91 23 - Interior Painting.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)
 - .1 ANSI A208.1-09, Particleboard.
 - .2 ANSI A208.2-09, Medium Density Fibreboard (MDF) for Interior Applications.
 - .3 ANSI/HPVA HP-1-09, American National Standard for Hardwood and Decorative Plywood.
- .2 Architectural Woodwork Manufacturers Association of Canada (AWMAC) and Architectural Woodwork Institute (AWI)
 - .1 Architectural Woodwork Quality Standards, 2nd edition, 2014.
- .3 ASTM International
 - .1 ASTM A123/A123M-15, Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- .4 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-11.3-M87, Hardboard.
- .5 CSA International
 - .1 CSA B111-74(R2003), Wire Nails, Spikes and Staples.
 - .2 CSA O121-08, Douglas Fir Plywood.
 - .3 CSA O141-05(R2014), Softwood Lumber.
 - .4 CSA O151-09(R2014), Canadian Softwood Plywood.
 - .5 CSA O153-13, Poplar Plywood.
- .6 National Lumber Grades Authority (NLGA)
 - .1 Standard Grading Rules for Canadian Lumber 2010.
- .7 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S104-10, Standard Method for Fire Tests of Door Assemblies.
 - .2 CAN/ULC-S105-16, Standard Specification for Fire Door Frames.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:

- .1 Submit manufacturer's instructions, printed product literature and data sheets for plywood, particleboard, OSB, MDF and include product characteristics, performance criteria, physical size, finish and limitations.
- .2 Submit electronic copies of WHMIS MSDS.
- .2 Shop Drawings:
 - .1 Indicate details of construction, profiles, jointing, fastening and other related details.
 - .2 Indicate materials, thicknesses, finishes and hardware.
- .3 Certifications: submit certificates signed by manufacturer certifying materials comply with specified performance characteristics and physical properties.
- .4 Test and Evaluation Reports: submit certified test reports for composite wood from approved independent testing laboratories, indicating compliance with specifications for specified performance characteristics and physical properties.

1.4 QUALITY ASSURANCE

- .1 Lumber by grade stamp of agency certified by Canadian Lumber Standards Accreditation Board (CLSAB).
- .2 Sustainable Standards Certification:
 - .1 Certified Wood: submit listing of wood products and materials used in accordance with CAN/CSA-Z809 or FSC or SFI.
- .3 Plywood, particleboard, OSB and wood based composite panels to CSA and ANSI standards.
- .4 Wood fire rated frames and panels: listed and labelled by an organization accredited by Standards Council of Canada to CAN/ULC-S104 and CAN/ULC-S105.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect wood products from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 LUMBER MATERIAL

- .1 Softwood lumber: unless specified otherwise, S4S, moisture content 19% or less in accordance with following standards:

- .1 CAN/CSA-O141.
- .2 NLGA Standard Grading Rules for Canadian Lumber.
- .3 AWMAC custom premium grade, moisture content as specified.
- .2 Machine stress-rated lumber is acceptable.
- .3 Hardwood lumber: moisture content 10 % or less in accordance with following standards:
 - .1 National Hardwood Lumber Association (NHLA).
 - .2 AWMAC custom grade, moisture content as specified.

2.2 PANEL MATERIAL

- .1 Douglas fir plywood (DFP): to CSA O121, standard construction.
- .2 Canadian softwood plywood (CSP): to CSA O151, standard construction.
- .3 Hardwood plywood: to CSA O115.
- .4 Poplar plywood (PP): to CSA O153, standard construction.
- .5 Hardboard: to CAN/CGSB-11.3.
 - .1 Hardboard must be manufactured such that formaldehyde emissions do not exceed 0.15ppm when tested in accordance with ASTM E1333.
- .6 Medium density fibreboard (MDF): to ANSI A208.2, density 640-800 kg/m³.
 - .1 Medium density fibreboard must be manufactured such that formaldehyde emissions do not exceed 0.15 ppm when tested in accordance with ASTM E1333.
- .7 Decorative overlaid composite panels.
 - .1 Decorative overlay, heat and pressure laminated with suitable resin to 12.7 mm thick particleboard MDF core.
 - .2 Overlay bonded to both faces where exposed two sides, and when panel material require surface on one side only, reverse side to be overlaid with a plain (buff) balancing sheet.
 - .3 Edge finishing: matching melamine and polyester overlay edge strip with self-adhesive.

2.3 ACCESSORIES

- .1 Nails and staples: to CSA B111; galvanized to CAN/CSA-G164 for exterior work, interior humid areas and for treated lumber; plain finish elsewhere.
- .2 Wood screws: plain, type and size to suit application.
- .3 Splines: wood
- .4 Adhesive: recommended by manufacturer.
- .5 Use least toxic sealants, adhesives, sealers, and finishes necessary to comply with requirements of this section.
- .6 Adhesive and Sealants: in accordance with Section 07 92 00 - Joint Sealants.
 - .1 VOC limit 250 g/L maximum.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for wood products installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed.

3.2 INSTALLATION

- .1 Do finish carpentry to Quality Standards of (AWMAC).
- .2 Scribe and cut as required, fit to abutting walls, and surfaces, fit properly into recesses and to accommodate piping, columns, fixtures, outlets, or other projecting, intersecting or penetrating objects.
- .3 Form joints to conceal shrinkage.

3.3 CONSTRUCTION

- .1 Fastening:
 - .1 Position items of finished carpentry work accurately, level, plumb, true and fasten or anchor securely.
 - .2 Design and select fasteners to suit size and nature of components being joined. Use proprietary devices as recommended by manufacturer.
 - .3 Set finishing nails to receive filler. Where screws are used to secure members, countersink screw in round smooth cut hole and plug with wood plug to match material being secured.
 - .4 Replace items of finish carpentry with damage to wood surfaces including hammer and other bruises.
- .2 Standing and running trim:
 - .1 Butt and cope internal joints of baseboards to make snug, tight, joint. Cut right angle joints of casing and base with mitred joints.
 - .2 Fit backs of baseboards and casing snugly to wall surfaces to eliminate cracks at junction of base and casing with walls.
 - .3 Make joints in baseboard, where necessary using a 45 degrees scarf type joint.
 - .4 Install door and window trim in single lengths without splicing.

3.4 CLEANING

- .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.

3.5 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by finish carpentry installation.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 06 20 00 – Finish Carpentry.
- .2 Section 06 47 00 – Plastic Laminate Finishes.
- .3 Section 07 92 00 – Joint Sealants.
- .4 Section 08 70 05 – Cabinet and Miscellaneous Hardware.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)
 - .1 ANSI A208.1-09, Particleboard.
 - .2 ANSI A208.2-09, Medium Density Fiberboard (MDF) for Interior Applications.
 - .3 ANSI/HPVA HP-1-09 Standard for Hardwood and Decorative Plywood.
- .2 ASTM International
 - .1 ASTM E1333-14, Standard Test Method for Determining Formaldehyde Concentrations in Air and Emission Rates From Wood Products Using a Large Chamber.
 - .2 ASTM D2832-92 (R2016), Standard Guide for Determining Volatile and Nonvolatile Content of Paint and Related Coatings.
 - .3 ASTM D5116-10, Standard Guide For Small-Scale Environmental Chamber Determinations of Organic Emissions From Indoor Materials/Products.
- .3 Architectural Woodwork Manufacturers Association of Canada (AWMAC) and Architectural Woodwork Institute (AWI)
 - .1 Architectural Woodwork Standards 2nd Edition.
- .4 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-71.20-M88, Adhesive, Contact, Brushable.
- .5 CSA International
 - .1 CSA B111-74(R2003), Wire Nails, Spikes and Staples.
 - .2 CSA O112.10-08 (R2013), Evaluation of Adhesives for Structural Wood Products (Limited Moisture Exposure).
 - .3 CSA O121-08 (R2013), Douglas Fir Plywood.
 - .4 CSA O141-05(R2014), Softwood Lumber.
 - .5 CSA O151-(R2014), Canadian Softwood Plywood.
 - .6 CSA O153-13, Poplar Plywood.
- .6 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .7 International Organization for Standardization (ISO)

- .8 National Electrical Manufacturers Association (NEMA)
 - .1 ANSI/NEMA LD-3-05, High-Pressure Decorative Laminates (HPDL).
- .9 National Hardwood Lumber Association (NHLA)
 - .1 Rules for the Measurement and Inspection of Hardwood and Cypress 2011.
- .10 National Lumber Grades Authority (NLGA)
 - .1 Standard Grading Rules for Canadian Lumber 2014.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for architectural woodwork and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit electronic copies of WHMIS MSDS.
- .2 Shop Drawings:
 - .1 Indicate details of construction, profiles, jointing, fastening and other related details.
 - .1 Scales: profiles full size, details half full size.
 - .2 Indicate materials, thicknesses, finishes and hardware.
 - .3 Indicate locations of service outlets in casework, typical and special installation conditions, and connections, attachments, anchorage and location of exposed fastenings.
- .3 Certifications: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .4 Submit duplicate colour samples of laminated plastic for colour selection.
- .5 Submit duplicate samples of laminated plastic joints, edging, cutouts, and postformed profiles.
 - .1 Low-Emitting Materials:
 - .1 Submit listing of adhesives, sealants, paints and coatings used in building, comply with VOC and chemical component limits or restrictions requirements.
 - .2 Submit listing of composite wood products used in building, stating that they contain no added urea-formaldehyde resins, laminate adhesives used in building, stating that they contain no urea-formaldehyde.

1.4 QUALITY ASSURANCE

- .1 Lumber by grade stamp of an agency certified by Canadian Lumber Standards Accreditation Board.
- .2 Plywood, particleboard, OSB and wood based composite panels to CSA and ANSI standards.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .1 Protect millwork against dampness and damage during and after delivery.
 - .2 Store millwork in ventilated areas, protected from extreme changes of temperature or humidity.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect architectural woodwork from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 MATERIALS

- .1 Softwood lumber: unless specified otherwise, S4S, moisture content 19 % or less in accordance with following standards:
 - .1 CAN/CSA-O141.
 - .2 NLGA Standard Grading Rules for Canadian Lumber.
 - .3 AWMAC premium grade, moisture content as specified.
- .2 Machine stress-rated lumber is acceptable for all purposes.
- .3 Hardwood lumber: moisture content 10% or less in accordance with following standards:
 - .1 National Hardwood Lumber Association (NHLA).
 - .2 AWMAC premium grade, moisture content as specified.
- .4 Douglas fir plywood (DFP): to CSA O121, standard construction.
 - .1 Urea-formaldehyde free.
- .5 Canadian softwood plywood (CSP): to CSA O151, standard construction.
 - .1 Urea-formaldehyde free.
- .6 Hardwood plywood: to ANSI/HPVA HP-1.
 - .1 Urea-formaldehyde free.
- .7 Poplar plywood (PP): to CSA O153, standard construction.
 - .1 Urea-formaldehyde free.
- .8 Birch plywood: to AWMAC Natural.
 - .1 Urea-formaldehyde free.
- .9 Hardboard: to CAN/CGSB – 11.3.

- .1 Urea-formaldehyde free.
- .10 Medium density fibreboard (MDF): to ANSI A208.2, density 769 kg/m³
 - .1 Urea-formaldehyde free.
 - .2 Must meet the performance requirements of ANSI A208.2
- .11 Laminated plastic: to CAN3-A172, Section 06 47 00 – Plastic Laminate Finishes.
- .12 Thermofused Melamine: to NEMA LD3 Grade VGL.
 - .1 High wear resistant thermofused melamine: equal or exceed 400 cycles (Minimum standard for HPL abrasion test).
- .13 Nails and staples: to CSA B111.
- .14 Wood screws: steel plain, type and size to suit application.
- .15 Splines: wood.
- .16 Sealant: Section 07 92 00 – Joint Sealants.
- .17 Glazing: provide glazing to the requirements of Section 08 80 50 – Glazing.

2.2 MANUFACTURED UNITS

- .1 Casework.
 - .1 Fabricate caseworks to AWMAC premium quality grade.
 - .2 Furring, blocking, nailing strips, grounds and rough bucks and sleepers.
 - .1 S2S is acceptable.
 - .2 Board sizes: "Standard" or better grade.
 - .3 Dimension sizes: "Standard" light framing or better grade.
 - .3 Framing birch or maple species, NHLA premium grade.
 - .4 Premanufactured plastic laminate covered Particle board grade premium 20mm thick.
 - .5 Backs.
 - .1 Premanufactured plastic laminate covered particle board, grade premium 6 mm thick.
 - .6 Shelving.
 - .1 Premanufactured plastic laminate covered particle board, grade premium 20mm thick.
 - .2 Edge banding: provide 10mm thick solid matching wood strip on plywood particleboard edges 12mm or thicker, exposed in final assembly. Strips same width as plywood particleboard.
- .2 Wood Drawers
 - .1 Fabricate drawers to AWMAC premium grade supplemented as follows:
 - .2 Sides and Backs.
 - .1 Hardwood plywood:
 - .1 Thickness: 12mm.
 - .3 Bottoms.

- .1 Preformed plastic laminate covered particle board, grade premium 12 mm thick.
 - .4 Fronts.
 - .1 Hardwood plywood:
 - .1 Thickness: 12 mm.
 - .2 Preformed plastic laminate covered particleboard, grade premium 12mm thick.
- .3 Metal Drawers Sidebox
 - .1 Metal sidebox drawer profiles, heights to suite drawer dimensions, c/w brackets for securing wood drawer front, back and bottom.
 - .2 Provide sliding drawer profiles, length to suite metal sidebox. Sliding drawer profile to provide full drawer extension operation
 - .3 Backs
 - .1 Hardwood plywood:
 - .1 Thickness: 12 mm.
 - .4 Bottoms
 - .1 Preformed plastic laminate covered particle board, grade premium 12 mm thick.
 - .5 Fronts
 - .1 Hardwood plywood:
 - .1 Thickness: 12 mm
 - .2 Preformed plastic laminate covered particleboard, grade premium 12 mm thick.
- .4 Casework Doors
 - .1 Fabricate doors to AWMAC premium grade supplemented as follows:
 - .2 Preformed plastic laminate covered particleboard, grade premium 20 mm thick.
- .5 Hardware
 - .1 Door and Drawer rolls, hinges, slides, locks, pulls, knobs shelf rest, standards, rods track shall be in accordance with CAN/CGSB-69.25-M90/ANSI/BHMA A156.9 and Section 08 70 05 – Cabinet and Miscellaneous Hardware.

2.3 FABRICATION

- .1 Set nails and countersink screws apply stained wood filler to indentations, sand smooth and leave ready to receive finish.
- .2 Shop install cabinet hardware for doors, shelves and drawers. Recess shelf standards unless noted otherwise.
- .3 Shelving to cabinetwork to be adjustable unless otherwise noted.
- .4 Provide cutouts for plumbing fixtures, inserts, appliances, outlet boxes and other fixtures.
- .5 Shop assemble work for delivery to site in size easily handled and to ensure passage through building openings.

- .6 Obtain governing dimensions before fabricating items which are to accommodate or abut appliances, equipment and other materials.
- .7 Ensure adjacent parts of continuous laminate work match in colour and pattern.
- .8 Veneer laminated plastic to core material in accordance with adhesive manufacturer's instructions. Ensure core and laminate profiles coincide to provide continuous support and bond over entire surface. Use continuous lengths up to 3000 mm. Keep joints 600 mm from sink cutouts.
- .9 Form shaped profiles and bends as indicated, using postforming grade laminate to laminate manufacturer's instructions.
- .10 Use straight self-edging laminate strip for flatwork to cover exposed edge of core material. Chamfer exposed edges uniformly at approximately 20 degrees. Do not mitre laminate edges.

2.4 FINISHING

- .1 Section 09 91 23 – Interior Painting

Part 3 EXECUTION

3.1 INSTALLATION

- .1 Do architectural woodwork to Quality Standards of the Architectural Woodwork Manufacturers Association of Canada (AWMAC), except where specified otherwise.
- .2 Install prefinished millwork at locations shown on drawings. Position accurately, level, plumb straight.
- .3 Fasten and anchor millwork securely. Provide heavy duty fixture attachments for wall mounted cabinets.
- .4 Use draw bolts in countertop joints.
- .5 Scribe and cut as required to fit abutting walls and to fit properly into recesses and to accommodate piping, columns, fixtures, outlets or other projecting, intersecting or penetrating objects.
- .6 At junction of plastic laminate counter back splash and adjacent wall finish, apply small bead of sealant.
- .7 Apply bituminous coating over wood framing members in contact with masonry or cementitious construction.
- .8 Fit hardware accurately and securely in accordance with manufacturer's written instructions.

3.2 CLEANING

- .1 Clean millwork and cabinet work inside cupboards and drawers and outside surfaces.
- .2 Remove excess glue from surfaces.

3.3 PROTECTION

- .1 Protect millwork and cabinet work from damage until final inspection.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 01 78 00 - Closeout Submittals.
- .2 Section 06 20 00 - Finish Carpentry.
- .3 Section 06 40 00 - Architectural Woodwork.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)
 - .1 ANSI 208.1-09, Particleboard.
 - .2 ANSI A208.2-2009, Medium Density Fibreboard (MDF) for Interior Applications.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-71.20-M88, Adhesive, Contact, Brushable.
- .3 CSA International
 - .1 CSA O112.10-08 (R2013), Evaluation of Adhesives for Structural Wood Products (Limited Moisture Exposure).
 - .2 CSA O121-08 (R2013), Douglas Fir Plywood.
 - .3 CSA O141-05(R2014), Softwood Lumber.
 - .4 CSA O151-(R2014), Canadian Softwood Plywood.
 - .5 CSA O153-13, Poplar Plywood.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .5 National Electrical Manufacturers Association (NEMA)
 - .1 ANSI/NEMA LD-3-05, High Pressure Decorative Laminates (HPDL).
- .6 Scientific Equipment and Furniture Association (SEFA)
 - .1 SEFA 8-99, Laboratory Furniture.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for laminate, adhesive, and core materials and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit electronic copies of WHMIS MSDS. Indicate VOC's for adhesives in g/L.
- .2 Samples:
 - .1 Submit for review and acceptance of each unit.

- .2 Samples will be returned for inclusion into work.
- .3 Submit duplicate samples of joints, edging, cutouts and postformed profiles.
- .3 Certifications: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for laminate work for incorporation into manual.

1.5 QUALITY ASSURANCE

- .1 Test Reports: certified test reports showing compliance with specified performance characteristics and physical properties.
- .2 Certificates: product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.

1.6 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect laminate, adhesive, and core materials from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 MATERIALS

- .1 Laminated plastic for flatwork: to NEMA LD 3.
 - .1 Type: General purpose.
 - .2 Grade: HGS.
 - .3 Size: 1.6 mm thick.
 - .4 Colour: multilayered.
 - .5 Pattern: solid.
 - .6 Finish: satin.
- .2 Laminated plastic for postforming work: to NEMA LD 3.
 - .1 Type: Postforming.
 - .2 Grade: HGP.
 - .3 Size: 0.75 mm thick.
 - .4 Colour: multilayered.

- .5 Pattern: solid.
- .6 Finish: satin.
- .3 Laminated plastic for backing sheet: to NEMA LD 3.
 - .1 Type: Backer.
 - .2 Grade:BKH.
 - .3 Size: 0.75 mm thick.
 - .4 Colour: white.
- .4 Laminated plastic for liner: to NEMA LD 3.
 - .1 Type: Cabinet Liner.
 - .2 Grade: CLS.
 - .3 Size: 0.75mm thick.
 - .4 Colour: white.
- .5 Plywood core: to CSA O153 solid two sides, Grade Popular Plywood,19 mm thick.
- .6 Particleboard core: to ANSI 208.1, sanded faces, of thickness indicated.
- .7 Laminated plastic adhesive: urea resin adhesive to CSA O112.5 contact adhesive to CAN/CGSB-71.20 resorcinol resin adhesive to CSA O112.7 polyvinyl adhesive to CSA O112.4 two component epoxy thermosetting adhesive.
- .8 Sealer: water resistant sealer on glue acceptable to laminate manufacturer.
- .9 Sealants: Silicone based material to CGSB 19-GP-22M.
- .10 Draw bolts and splines: as recommended by fabricator.

2.2 FABRICATION

- .1 Comply with NEMA LD 3, Annex A.
- .2 Obtain governing dimensions before fabricating items which are to accommodate or abut appliances, equipment and other materials.
- .3 Ensure adjacent parts of continuous laminate work match in colour and pattern.
- .4 Veneer laminated plastic to core material in accordance with adhesive manufacturer's instructions. Ensure core and laminate profiles coincide to provide continuous support and bond over entire surface. Use continuous lengths up to 3000 mm. Keep joints 600 mm from sink cutouts.
- .5 Form shaped profiles and bends as indicated, using postforming grade laminate to laminate manufacturer's instructions.
- .6 Use straight self-edging laminate strip for flatwork to cover exposed edge of core material. Chamfer exposed edges uniformly at approximately 20°. Do not mitre laminate edges.
- .7 Apply laminate backing sheet to reverse side of core of plastic laminate work.
- .8 Apply laminated plastic liner sheet to interior of cabinetry.

Part 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: Comply with manufacturer's written data, including product technical bulletins, product catalogue installation instructions, product carton installation instructions, and data sheets.

3.2 INSTALLATION

- .1 Install work plumb, true and square, neatly scribed to adjoining surfaces.
- .2 Make allowances around perimeter where fixed objects pass through or project into laminated plastic work to permit normal movement without restriction.
- .3 Use draw bolts and splines in countertop joints. Maximum spacing 450 mm oc, 75 mm from edge. Make flush hairline joints.
- .4 Provide cutouts for inserts, grilles, appliances, outlet boxes and other penetrations. Round internal corners, chamfer edges and seal exposed core.
- .5 At junction of laminated plastic counter back splash and adjacent wall finish, apply small bead of sealant.

3.3 CLEANING

- .1 Perform cleaning after installation to remove construction and accumulated environmental dirt.
- .2 Perform care and cleaning with NEMA LD 3, Annex B.
- .3 Remove traces of primer, caulking, epoxy and filler materials; clean doors and frames.

3.4 PROTECTION

- .1 Cover finished laminated veneered surfaces with heavy kraft paper or put in cartons during shipment.
- .2 Protect installed laminated surfaces in accordance with manufacturer's written recommendations.
 - .1 Remove protection only immediately before final inspection.
- .3 Protect installed products and components from damage during construction.
- .4 Repair damage to adjacent materials caused by laminate, adhesive, and core materials installation.

END OF SECTION