

Part 1 ADDENDUM NO.2

1.1 General

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

Part 2 Questions

- .1 In the specifications for the above-noted project, there is a spec section 09 65 16 Resilient Sheet Flooring. I have reviewed the drawing and don't see any sheet flooring to be installed. Is this spec section relevant to this project?

Section 09 65 16 Resilient Sheet Flooring was left in the specification in error. Remove Section 09 65 16 Resilient Sheet Flooring from the specification package as it is not required and there is no sheet flooring in the project.

Part 3 Equals

- 3.1 **I.D. Inspiration Luxury Plank Flooring and Tile is accepted as an equal. See attached**
- 3.2 **ERV Parent Commercial floors and walls Armstrong Vivero flooring is accepted as an equal for a glue down installation. See attached**
- 3.3 **See attached for list of Jones Goodridge equals.**

END OF SECTION



1948 Main Street, Winnipeg, MB R2V 2B4
PHONE: (204)943-7222 FAX: (204)947-5717

PROJECT NAME: RCMP House Repair Lundar, Manitoba MB – 18-072-01-30

SUBMITTED BY: Jones Goodridge

DATE: January 7 2019 PHONE: 204-632-6221

REVIEWED BY: Reid Sitar

The following products have been reviewed in accordance with the General Requirements of the contract documents. It shall be conclusively assumed that the individual or firm, requesting the acceptance of the substitute product, certifies that the substitute will adequately perform the functions called for by the general design drawings and associated specifications, be similar and of equivalent substance to that specified, is suited to the same use and capable of performing the same function as that specified and can be incorporated into the Work, strictly in accordance with the Schedule of Work and Completion Date(s). Furthermore, in the event that the substitute product is accepted, any and all changes required in the applicable Work, and all changes to any other Work, which would become necessary to accommodate the requested substitute, as well as any cost or time impacts that may be associated with the use of the substitute, shall be the responsibility of the individual or firm requesting approval of the substitute product.

Schedule Reference: Plumbing

Equal Granted



JONES GOODRIDGE

REQUEST FOR ACCEPTED PRODUCT EQUIVALENTS

To: Royal Canadian Mounted Police, Procurement Office **Date:** March 5, 2019
Attention: Teresa Hengen teresa.hengen@rcmp-grc.gc.ca Via: e-mail: X FAX:
Project: RCMP Detachment, Interior Renovations - 18 2nd Avenue North Lundar, Manitoba
 Job Number: 18-027-01-30
Close Date: March 12, 2019
Request By: Dan Graham **E-mail:** dgraham@jonesgoodridge.ca

Your consideration is requested of the above project that the following manufacturers be considered as equals to those specified:

Spec. Section	Clause	Specified Product	Proposed Product	Accepted
Drawing M1.1	WC-1	American Standard 2427.500.020 Water Closets	Contrac Cody 4722BEV ; 4721BFV Water Closets	✓
		Centoco 4200 Water Closet Seats	Bemis 1900SS Water Closet Seats	✓
		Non-Specified Water Closet Supplies	Brasscraft KTSCS40BX C ; 1-12DL C Water Closet Supplies	✓
	LAV-1	American Standard 9494.001.020 Lavatories	Contrac Catalina 4140BGW Lavatories	✓
		American Standard 6114.110.002 Faucets and Trim	Delta Commercial 22C351 Faucets and Trim	✓
		Non-Specified P-Traps	Delta Commercial 33T311 P-Traps	✓
		Non-Specified Lavatory Supplies	Brasscraft KTSCS40BX C ; 1-12A C Water Closet Supplies	✓
	S-1	American Standard 9449.301.002 Faucets and Trim	Delta Faucets 9181-DST Faucets and Trim	✓
		McGuire LFHST06LKSB Sink Supplies	Brasscraft KTSCS400AX C Sink Supplies	✓
		Non-Specified P-Traps	Delta Commercial 33T360 P-Traps	✓

We look forward to your reply via e-mail or facsimile. Thank-you in advance for your consideration!



1948 Main Street, Winnipeg, MB R2V 2B4
PHONE: (204)943-7222 FAX: (204)947-5717

PROJECT NAME: RCMP House Repair Lundar, Manitoba MB – 18-072-01-30
SUBMITTED BY: ERV Parent Commercial floors and walls
DATE: March 6, 2019 PHONE: 204-632-6221
REVIEWED BY: Reid Sitar

The following products have been reviewed in accordance with the General Requirements of the contract documents. It shall be conclusively assumed that the individual or firm, requesting the acceptance of the substitute product, certifies that the substitute will adequately perform the functions called for by the general design drawings and associated specifications, be similar and of equivalent substance to that specified, is suited to the same use and capable of performing the same function as that specified and can be incorporated into the Work, strictly in accordance with the Schedule of Work and Completion Date(s). Furthermore, in the event that the substitute product is accepted, any and all changes required in the applicable Work, and all changes to any other Work, which would become necessary to accommodate the requested substitute, as well as any cost or time impacts that may be associated with the use of the substitute, shall be the responsibility of the individual or firm requesting approval of the substitute product.

Schedule Reference: Flooring

Vinyl Plank Flooring

REQUEST FOR APPROVED EQUAL/ALTERNATE



ERV PARENT GROUP LTD.
5 OTTER STREET
WINNIPEG, MANITOBA, R3T 0M7
PHONE:(204) 475-3555
FAX:(204) 452-5826
CELL: (204) 771-3335

To:	Teresa Hengen	From:	Kim Anderson
Company:	RCMP	Date:	March 6, 2019
Fax:	Email: teresa.hengen@rcmp-grc.gc.ca	Pages:	6 (Include this one)
Project:	RCMP Detachment Interior and Exterior Renovations – Lundar, Manitoba	CC:	Gen Close: March 13, 2019

MATERIAL SPECIFIED:

09 64 53: 2.1.1: Armstrong Vivero Best high vinyl tile – 2.5mm - 20mil wear layer lvt

MATERIAL REQUESTED FOR APPROVED EQUAL OR ALTERNATE:

09 64 53: 2.1.1: Tarkett ID55 Inspiration – 2.5mm – 20mil wear layer lvt

See attached comparison sheet as well as a color brochure/tech data sheet

APPROVED AS: EQUAL ALTERNATE

Approvers Signature:

APPROVED

By Reid Sitar at 1:19 pm, Mar 06, 2019