

# Addendum/Addenda

No./N° 2
-------------

Project Description / Description de projet  Electrical Upgrade for CART Compound		
Solicitation No./ N° de sollicitation 18-22105	Project No./N° de projet PEN-5673	W.O. No./N° d'ordre de travail  A1-011352-06-01
Departmental Representative / Représentant Ministériel Kory Phillips	Date Mar 15,2019	
<b>Notice:</b> This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		<b>Nota:</b> Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

1. Question : Any surge arrestors required?  
Answer: No surge arrestors are required.
2. Question: Would a “Thermometer, dial-type, with alarm contacts” be acceptable for “Liquid Temperature Gauge” as stated in the spec?  
Answer: Yes, dial type with alarm contacts is acceptable.

