



SPECIAL NOTE(S)

1. 210 EMPT CONDUIT IN CEILING SPACE COMPLETED AT EACH END BY ONE GANG BOX. ONE BOX IS INSTALLED ABOVE THE CABLE TRAY IN THE CORRIDOR AND THE OTHER ONE ON THE EXTERIOR WALL, NEAR THE MAIN EXIT FROM THE GARAGE.
2. 210 EMPT CONDUIT IN CEILING SPACE IN ONE GANG BOX ON THE EXTERIOR WALL AND ONE IN CEILING SPACE OF ROOM 1028.
3. POWER SUPPLIES BOXES FOR 120V SERVICES AND TELECOMMUNICATIONS, MOUNTED ON EACH SIDE OF THE POLE AT ABOVE 2000MM FROM FINISHED GROUND, MEASURED FROM THE HIGH PART OF THE HOUSINGS BOXES. BOXES FEEDED BY A 270 RIGID STEEL CONDUIT, MOUNTED ON CURBSTONE ON THE POLE AND FROM THE BUILDING THROUGH THE EXISTING 270 PVC CONDUITS. MAKE A OPENING OF 270 IN THE POLE TO CONNECT THE 2 BOXES. BOXES PROVIDED AND INSTALLED BY OTHERS.
4. PROVIDE AND INSTALL A 1502A -125V DUPLEX RECEPTACLE IN THE TELECOM BOX.
5. THE CONDUIT MUST BE INSTALLED ABOVE THE FENCE POST TO THE INSTALLATION HEIGHT OF THE EQUIPMENT INDICATED IN TABLE "C".
6. EQUIPMENT MUST BE INSTALLED IN SOFFIT AT 4 m HEIGHT.

NOM / NAME	HAUTEUR D'INSTALLATION (m) / INSTALLATION HEIGHT (m)	NOM / NAME	HAUTEUR D'INSTALLATION (m) / INSTALLATION HEIGHT (m)
CE-1	3.50m	CE-58	3.25m
CE-2	3.50m	CE-59	3.50m
CE-3	3.50m	CE-60	3.50m
CE-4	3.00m	CE-61	3.50m
CE-5	3.00m	CE-62	3.50m
CE-6	3.00m	CE-63	3.50m
CE-7	4.00m	CE-64	3.10m
CE-8	4.00m	CE-65	3.50m
CE-9	4.00m	CE-66	3.50m
CE-10	4.00m	CE-67	3.50m
CE-11	3.00m	CE-68	3.50m
CE-12	3.00m	CE-69	3.50m
CE-13	3.50m	CE-70	3.50m
CE-14	3.50m	CE-71	3.50m
CE-15	1.80m	CE-72	3.50m
CE-16	1.80m	CE-73	3.50m
CE-17	1.80m	CE-74	3.50m
CE-18	3.50m	CE-75	3.50m
CE-19	3.50m	CE-76	3.50m
CE-20	1.80m	CE-77	3.50m
CE-21	1.80m	CE-78	3.50m
CE-22	3.50m	CE-79	3.50m
CE-23	3.50m	CE-80	3.50m
CE-24	3.50m	CE-81	3.00m
CE-25	3.50m	CE-82	3.50m
CE-26	3.50m	CE-83	3.50m
CE-27	3.50m	CE-84	3.50m
CE-28	3.50m	CE-85	3.50m
CE-29	3.50m	CE-86	3.00m
CE-30	3.50m	CE-87	3.50m
CE-31	3.50m	CE-88	3.50m
CE-32	3.50m	CE-89	3.50m
CE-33	3.50m	CE-90	3.50m
CE-34	3.50m	CE-91	1.80m
CE-35	3.00m	CE-92	3.50m
CE-36	3.50m	CE-93	3.50m
CE-37	3.50m	CE-94	3.50m
CE-38	3.50m	CE-95	3.50m
CE-39	3.50m	CE-96	3.50m
CE-40	3.50m	CE-97	3.50m
CE-41	3.50m	CE-98	3.50m
CE-42	3.50m	CE-99	3.50m
CE-43	3.00m	CE-100	3.50m
CE-44	3.50m	CE-101	3.50m
CE-45	3.50m	CE-102	3.50m
CE-46	3.50m	CE-103	3.50m
CE-47	3.50m	CE-104	3.50m
CE-48	3.50m	CE-105	3.50m
CE-49	3.50m	CE-106	4.00m
CE-50	3.10m	CE-107	4.00m
CE-51	3.50m	CE-108	4.00m
CE-52	3.00m	CE-109	4.00m
CE-53	3.50m	CE-110	3.50m
CE-54	3.50m	CE-111	3.50m
CE-55	3.50m	CE-112	3.00m
CE-56	3.00m	CE-113	3.00m
CE-57	3.50m		