



Parks
Canada

Parcs
Canada



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
220 4 Ave SE, Suite 720
Calgary, AB T2G 4X3

AMENDMENT / MODIFICATION

003

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
220 4 Ave SE, Suite 720
Calgary, AB T2G 4X3

Title-Sujet Administration Building HVAC Upgrades Design-Build Batoche National Historic Site, SK		
Solicitation No. - No. de l'invitation 5P420-18-0468/A		Date: January 28, 2019
GETS Reference No. - No de reference de SEAG PW-18-00856829		Amendment No. - N° de la modif. 003
Solicitation Closes:		
at - à 02:00 PM	on - le January 31, 2019	Time Zone - Fuseau horaire MST - HNR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Jen Maheu jennifer.maheu@canada.ca		
Telephone No. - No de téléphone (587) 432-8458		Fax No. - No de FAX: (866) 246-6893
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 03

This amendment is being raised to distribute questions and answers from the optional site visit on January 15, 2019.

A) SITE VISIT ATTENDEES

Vendor	Representative's Name
Black & McDonald	Nathan Rysavy Tim Edmonds
Ace Plumbing & Heating Inc.	Mike Burks Kirk Simms
Metro Mechanical Inc	Jeremy Putnam
Thorpe Brothers	Colin Thorpe

Contact information for the attendees are available upon request and approval from the vendors.


B) TENDER PACKAGE REVISIONS

ADD: DSP3_18-0468: BNHS Admin Building - Structural

C) QUESTIONS & ANSWERS

Q3 Is the ventilation in the IT closet included in this contract? If so, what is required?

A3 Yes, the ventilation in the IT closet is included. Extend a duct from the supply duct in the staff room to supply air to the IT closet. See sketch below for reference.



Q4 Should the washroom ventilation be revised on the added washroom next to the Wajax storage room?

A4 Re-route washroom ventilation either through the roof or to the nearest exterior wall so that it ventilates outside. This only applies to the washroom immediately adjacent to the Wajax storage room. The other washroom is assumed to be ventilated to the exterior.

Q5 Is an Engineered design required with the submission?

A5 The design of the ductwork extensions is not required to be sealed by an Engineer. The Air Balance report should show that the new layout achieves the goal of providing required heating/cooling/air flow as appropriate to these spaces. If the Air Balance report shows that the design is not successful, this will need to be fixed, and an Engineer may be required at this point depending on the issues.

Q6 Is the roof structure designed to support the 2 units? Can a structural drawing be provided? If additional structure is required, how will it be addressed? Included in this contract through a cash allowance, or maybe done as a separate contract by Parks?

A6 Structural Drawings from the original construction of the building are attached, see DSP3_18-0468: *BNHS Admin Building – Structural* for reference. Parks Canada will be providing a Structural Engineer to review these drawings. The contractual method that Parks will use to address any additional structure is still under review, but is not part of this contract.

All other terms and conditions remain unchanged.