

# **SPECIFICATION**

---

**TYPICAL FURNACE INSTALLATION  
NUNAVUT**

TABLE OF CONTENTS

Pages

Division 00 - Procurement and Contracting Requirements

Section 00 01 10 - Table Of Contents.....1

Division 01 - General Requirements

Section 01 11 00 - Summary Of Work ..... 3
Section 01 14 00 - Work Restrictions ..... 2
Section 01 31 19 - Project Meetings ..... 3
Section 01 32 16.07 - Construction Progress Schedule - Bar (GANTT) Chart..... 3
Section 01 33 00 - Submittal Procedures ..... 4
Section 01 35 29.06 - Health And Safety Requirements ..... 3
Section 01 41 00 - Regulatory Requirements..... 1
Section 01 51 00 - Temporary Utilities..... 2
Section 01 52 00 - Construction Facilities ..... 2
Section 01 56 00 - Temporary Barriers And Enclosures..... 2
Section 01 61 00 - Common Product Requirements..... 5
Section 01 74 11 - Cleaning ..... 3
Section 01 77 00 - Closeout Procedures ..... 2
Section 01 78 00 - Closeout Submittals..... 7
Section 01 78 40 - Maintenance Requirements..... 3
Section 01 79 00 - Demonstration and Training ..... 2
Section 01 91 51 - Building Management Manual (bmm) ..... 4

Division 23 – Heating Ventilation and Air Conditioning

Section 23 05 00 - Common Work Results For HVAC..... 4
Section 23 05 93 – Testing Adjusting and Balancing..... 11
Section 23 07 13 – Duct Insulation..... 5
Section 23 31 00 – Duct Work..... 6
Section 23 33 00 – Duct Work Accessories ..... 5
Section 23 37 00 – Air Inlets and Outlets ..... 3
Section 23 51 00 – Breaching Chimneys and Stacks ..... 3
Section 23 54 10 – Forced Air Furnaces ..... 5

List of Drawings

- M0.0 Title Page
M1.0 Installation Notes
M2.0 Furnace Details
M2.1 Details

END OF TABLE

**Part 1        General****1.1        WORK COVERED BY CONTRACT DOCUMENTS**

- .1        Work of this Contract comprises the typical installation instructions for furnaces for typical houses and detachments in Nunavut. This work includes; labour, materials and shipping of materials, in accordance with the contract documents and as further described herein.

**1.2        SCOPE OF WORK**

- .1        Remove existing furnace and chimney
- .2        Remove existing fuel filter and tiger loop
- .3        Install new chimney and furnace
- .4        Install new fuel filter and new tiger loop
- .5        Install new fuel tubing from existing fuel line.

**1.3        SITE VERIFICATION**

- .1        Upon award of the contract contractor is to schedule a site trip to site verify all sizes and dimensions. No additional fees will be considered for materials brought onto site of the wrong size.

**1.4        WORK SEQUENCE**

- .1        Buildings will remain occupied during the renovation.
- .2        Co-ordinate Progress Schedule with Departmental Representative, Consultant and Local Commander
- .3        Maintain fire access/control at all times.

**1.5        PROTECTION OF REMAINING FIXTURES AND CABINETS**

- .1        The contractor is to document by photos the condition of the existing cabinetry and fixtures at takeover of the area of work and supply a digital copy to the consultant.
- .2        The contractor is responsible for the protection of all damage caused during the construction process and it will be the responsibility of the contractor to make good to the acceptance of the Project Manager and Consultant.

**1.6        CONTRACTOR USE OF PREMISES**

- .1        Limit use of premises for storage, and for access to allow:
  - .1        Owner Occupancy
  - .2        Work by other Contractors
  - .3        Public Usage
- .2        Keep clear products or equipment which may **interfere** with operation of Building or other contractors.
- .3        Assume responsibility for the protection and safekeeping of products under this contract.

- .4 Co-ordinate use of premises under direction of Consultant and Departmental Representative.
- .5 Obtain and pay for use of additional storage or work areas needed for operations under this Contract as required.
- .6 Ensure safe practices and work area to prevent injury or damage to portions of existing work which remain.
- .7 Repair or replace portions of existing work which have been altered during construction operations to match existing or adjoining work, as directed by Consultant.

### **1.7 OWNER OCCUPANCY**

- .1 Residences and facility buildings will be occupied during construction.
- .2 Co-Operate with Owner in scheduling operations to minimize conflict and to facilitate owner usage.

### **1.8 EXISTING SERVICES**

- .1 Notify Consultant and utility companies of intended interruption of services and obtain required permission. Pay fees and obtain certificates and permits required.
- .2 Where Work involves breaking into or connecting to existing services, give 48 hours notice for necessary interruption of mechanical or electrical service throughout course of work. Minimize duration of interruptions. Carry out work at times as directed by governing authorities with minimum disturbance to pedestrian, vehicular traffic and tenant operations.
- .3 Provide alternative routes for personnel and vehicular traffic (if required).
- .4 Establish location and extent of service lines in area of work before starting Work. Notify Consultant of findings.
- .5 Submit schedule to and obtain approval from Consultant and building operations for any shut-down or closure of active service or facility including power and communications services. Adhere to approved schedule and provide notice to affected parties.
- .6 Provide temporary services when directed by Consultant or as required to maintain critical building and tenant systems.
- .7 Provide adequate bridging over trenches which cross sidewalks or roads to permit normal traffic.
- .8 Where unknown services are encountered, immediately advise Consultant and confirm findings in writing.
- .9 Protect, relocate or maintain existing active services. When inactive services are encountered, inform consultant and owner prior to capping off in manner approved by authorities having jurisdiction.
- .10 Record locations on as-built drawings of maintained, re-routed and abandoned service lines.
- .11 Construct barriers in accordance with Section 01 56 00 - Temporary Barriers and Enclosures

### **1.9 DOCUMENTS REQUIRED**

- .1 Maintain at job site, one copy each document as follows:

- .1 Contract Drawings.
- .2 Specifications.
- .3 Addenda.
- .4 Reviewed Shop Drawings.
- .5 List of Outstanding Shop Drawings.
- .6 Change Orders.
- .7 Other Modifications to Contract.
- .8 Field Test Reports.
- .9 Copy of Approved Work Schedule.
- .10 Health and Safety Plan and Other Safety Related Documents.
- .11 Other documents as specified.

**1.10 CODES AND STANDARDS**

- .1 Materials shall be new and work shall conform to the minimum applicable standards of the Canadian General Standards board, the Canadian Standards Association, The National Building Code of Canada 2010, and all applicable Territorial and Municipal codes, and all standards listed below. In the case of conflict or discrepancy the most stringent requirement shall apply.
- .2 Meet or exceed requirements of contract documents, specified standards, codes and referenced documents.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not used.

**END OF SECTION**

**Part 1        General****1.1            ACCESS AND EGRESS**

- .1 Design, construct and maintain temporary "access to" and "egress from" work areas, including stairs, runways, ramps or ladders, independent of finished surfaces and in accordance with relevant municipal, provincial and other regulations.

**1.2            USE OF SITE AND FACILITIES**

- .1 Execute work with least possible interference or disturbance to normal use of premises. Make arrangements with Departmental Representative to facilitate work as stated.
- .2 Maintain existing services to building and provide for personnel and vehicle access.
- .3 Where security is reduced by work provide temporary means to maintain security.
- .4 Closures: protect work temporarily until permanent enclosures are completed.

**1.3            ALTERATIONS, ADDITIONS OR REPAIRS TO EXISTING BUILDING**

- .1 Execute work with least possible interference or disturbance to building operations occupants, public and normal use of premises. Arrange with Departmental Representative to facilitate execution of work.

**1.4            EXISTING SERVICES**

- .1 Notify, utility companies, Consultant, of intended interruption of services and obtain required permission.
- .2 Where Work involves breaking into or connecting to existing services, give Departmental Representative 48 hours of notice for necessary interruption of mechanical or electrical service throughout course of work. Keep duration of interruptions minimum. Carry out interruptions after normal working hours of occupants, preferably on weekends.

**1.5            SPECIAL REQUIREMENTS**

- .1 Submit schedule in accordance with Section 01 32 16.07 - Construction Progress Schedules - Bar (GANTT) Chart.
- .2 Ensure that Contractor personnel employed on site become familiar with and obey regulations including safety, fire, traffic and security regulations.
- .3 Keep within limits of work and avenues of ingress and egress.

**1.6            SECURITY CLEARANCES**

- .1 Personnel employed on this project will be subject to security check. Obtain clearance, as instructed, for each individual who will be required to enter premises.

**1.7 BUILDING SMOKING ENVIRONMENT**

- .1 Comply with smoking restrictions. Smoking is not allowed on the property.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1          General****1.1            ON-SITE DOCUMENTS**

- .1      Contract Documents
- .2      Specifications
- .3      Addenda
- .4      Reviewed shop drawings
- .5      Change orders
- .6      Other modifications in contract
- .7      Field test reports
- .8      Copy of approved Work Schedule
- .9      Manufacturers installation and application instructions
- .10     Labour conditions and wage schedules
- .11     Project Record Documents (for as-built purposes)
- .12     Codes and Standards listed in 01 11 00

**1.2            ADMINISTRATIVE**

- .1      Attend project meetings throughout the progress of the work at the call of Consultant.
- .2      Provide physical space and make arrangements for meetings.
- .3      Consultant will record the meeting minutes. Include significant proceedings and decisions. Identify actions by parties.
- .4      Consultant will reproduce and distribute copies of minutes within three days after meetings and transmit to meeting participants, affected parties not in attendance, Project Manager, and Contractor.
- .5      Representative of Contractor, Subcontractor and suppliers attending meetings will be qualified and authorized to act on behalf of party each represents.

**1.3            PRECONSTRUCTION MEETING**

- .1      After award of Contract, request a meeting of parties in contract to discuss and resolve administrative procedures and responsibilities. Meeting will be held at the location and time designated by the departmental representative



- .2 Departmental Representative, Engineer and Consultant, Contractor, major Subcontractors, will be in attendance. Others may be in attendance at the discretion of the departmental representative or the Contractor. Representatives of the local Building Manager may also be in attendance.
- .3 Establish time and location of meeting and notify parties concerned minimum 2 days before meeting.
- .4 Agenda to include:
  - .1 Appointment of official representative of participants in the Work.
  - .2 Schedule of Work: in accordance with Section 01 32 16.07 - Construction Progress Schedules - Bar (GANTT) Chart.
  - .3 Schedule of submission of shop drawings, samples, colour chips. Submit submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .4 Requirements for temporary facilities, site sign, offices, storage sheds, utilities, fences in accordance with Section 01 52 00 - Construction Facilities.
  - .5 Delivery schedule of specified equipment.
  - .6 Site security in accordance with Section 01 56 00 - Temporary Barriers and Enclosures.
  - .7 Proposed changes, change orders, procedures, approvals required, mark-up percentages permitted, time extensions, overtime, administrative requirements.
  - .8 Owner provided products.
  - .9 Record drawings in accordance with Section 01 33 00 - Submittal Procedures
  - .10 Maintenance manuals in accordance with Section 01 78 00 - Closeout Submittals
  - .11 Take-over procedures, acceptance, warranties in accordance with Section 01 78 00 - Closeout Submittals.
  - .12 Monthly progress claims, administrative procedures, photographs, hold backs.
  - .13 Appointment of inspection and testing agencies or firms.
  - .14 Insurances, transcript of policies.
- .5 Comply with Departmental Representative's allocation of mobilization areas of site; for field offices and sheds, for access, traffic and parking facilities.
- .6 During construction coordinate use of site and facilities through Departmental Representatives procedures for intra-project communications: submittals, reports and records, schedules, coordination of drawings, recommendations, and resolution of ambiguities and conflicts.
- .7 Comply with instruction of consultant for use of Temporary utilities and construction facilities.
- .8 Coordinate field engineering and layout work with consultant.

**1.4****PROGRESS MEETINGS**

- .1 During course of Work at the discretion of the Consultant and Departmental Representative.

- .2 Representatives of the Contractor, major Subcontractors involved in the work and other as required and decided upon by the Departmental Representative or Contractor are to be in attendance. Contractor to notify all sub-contractors.
- .3 Consultant will notify contractor min 5 days prior to meetings
- .4 Consultant to record minutes of meetings and circulate to attending parties and affected parties not in attendance within 5 days after meeting.
- .5 Agenda to include the following:
  - .1 Review, approval of minutes of previous meeting.
  - .2 Review of Work progress since previous meeting.
  - .3 Field observations, problems, conflicts.
  - .4 Problems which impede construction schedule.
  - .5 Review of off-site fabrication delivery schedules.
  - .6 Corrective measures and procedures to regain projected schedule.
  - .7 Revision to construction schedule.
  - .8 Progress schedule, during succeeding work period.
  - .9 Review submittal schedules: expedite as required.
  - .10 Maintenance of quality standards.
  - .11 Review proposed changes for affect on construction schedule and on completion date.
  - .12 Other business.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1          General****1.1            DEFINITIONS**

- .1      Activity: element of Work performed during course of Project. Activity normally has expected duration, and expected cost and expected resource requirements. Activities can be subdivided into tasks.
- .2      Bar Chart (GANTT Chart): graphic display of schedule-related information. In typical bar chart, activities or other Project elements are listed down left side of chart, dates are shown across top, and activity durations are shown as date-placed horizontal bars. Generally Bar Chart should be derived from commercially available computerized project management system.
- .3      Baseline: original approved plan (for project, work package, or activity), plus or minus approved scope changes.
- .4      Construction Work Week: Monday to Friday, inclusive, will provide five day work week and define schedule calendar working days as part of Bar (GANTT) Chart submission.
- .5      Duration: number of work periods (not including holidays or other nonworking periods) required to complete activity or other project element. Usually expressed as workdays or workweeks.
- .6      Master Plan: summary-level schedule that identifies major activities and key milestones.
- .7      Milestone: significant event in project, usually completion of major deliverable.
- .8      Project Schedule: planned dates for performing activities and the planned dates for meeting milestones. Dynamic, detailed record of tasks or activities that must be accomplished to satisfy Project objectives. Monitoring and control process involves using Project Schedule in executing and controlling activities and is used as basis for decision making throughout project life cycle.
- .9      Project Planning, Monitoring and Control System: overall system operated by RCMP to enable monitoring of project work in relation to established milestones.

**1.2            REQUIREMENTS**

- .1      Ensure Master Plan and Detail Schedules are practical and remain within specified Contract duration.
- .2      Construction Progress Schedule to be Completed in Microsoft Project or Similar Software.
- .3      Plan to complete Work in accordance with prescribed milestones and time frame.
- .4      Limit activity durations to maximum of approximately 10 working days, to allow for progress reporting.

- .5 Ensure that it is understood that Award of Contract or time of beginning, rate of progress, Interim Certificate and Final Certificate as defined times of completion are of essence of this contract.

### **1.3 SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures .
- .2 Submit to Consultant within 5 working days of Award of Contract as Master Plan for planning, monitoring and reporting of project progress.
- .3 Submit Project Schedule to Consultant within 5 working days of receipt of acceptance of Master Plan.

### **1.4 PROJECT MILESTONES**

#### **1.5 MASTER PLAN**

- .1 Structure schedule to allow orderly planning, organizing and execution of Work as Bar Chart (GANTT).
- .2 Consultant will review and return revised schedules within 5 working days.
- .3 Revise impractical schedule and resubmit within 5 working days.
- .4 Accepted revised schedule will become Master Plan and be used as baseline for updates.

#### **1.6 PROJECT SCHEDULE**

- .1 Develop detailed Project Schedule derived from Master Plan.

#### **1.7 PROJECT SCHEDULE REPORTING**

- .1 Update Project Schedule on weekly basis reflecting activity changes and completions, as well as activities in progress.
- .2 Include as part of Project Schedule, narrative report identifying Work status to date, comparing current progress to baseline, presenting current forecasts, defining problem areas, anticipated delays and impact with possible mitigation.

#### **1.8 PROJECT MEETINGS**

- .1 Discuss Project Schedule at regular site meetings, identify activities that are behind schedule and provide measures to regain slippage. Activities considered behind schedule are those with projected start or completion dates later than current approved dates shown on baseline schedule.
- .2 Weather related delays with their remedial measures will be discussed and negotiated.

Nunavut

- Part 2**            **Products**
- 2.1**            **NOT USED**
- .1            Not used.

- Part 3**            **Execution**
- 3.1**            **NOT USED**
- .1            Not used.

**END OF SECTION**

**Part 1        General****1.1            ADMINISTRATIVE**

- .1        Submit to Consultant submittals listed for review. Submit promptly and in orderly sequence to not cause delay in Work. Failure to submit in ample time is not considered sufficient reason for extension of Contract Time and no claim for extension by reason of such default will be allowed.
- .2        Do not proceed with Work affected by submittal until review is complete.
- .3        Present shop drawings, product data, samples and mock-ups in imperial units.
- .4        Where items or information is not produced in imperial units converted values are acceptable.
- .5        Review submittals prior to submission to Consultant. This review represents that necessary requirements have been determined and verified, or will be, and that each submittal has been checked and co-ordinated with requirements of Work and Contract Documents. Submittals not stamped, signed, dated and identified as to specific project will be returned without being examined and considered rejected.
- .6        Notify Consultant, in writing at time of submission, identifying deviations from requirements of Contract Documents stating reasons for deviations.
- .7        Verify field measurements and affected adjacent Work are co-ordinated.
- .8        Contractor's responsibility for errors and omissions in submission is not relieved by Engineer's, Consultant's review of submittals.
- .9        Contractor's responsibility for deviations in submission from requirements of Contract Documents is not relieved by Consultant review.
- .10        Keep one reviewed copy of each submission on site.

**1.2            SHOP DRAWINGS AND PRODUCT DATA**

- .1        The term "shop drawings" means drawings, diagrams, illustrations, schedules, performance charts, brochures and other data which are to be provided by Contractor to illustrate details of a portion of Work.
- .2        Indicate materials, methods of construction and attachment or anchorage, erection diagrams, connections, explanatory notes and other information necessary for completion of Work. Where articles or equipment attach or connect to other articles or equipment, indicate that such items have been co-ordinated, regardless of Section under which adjacent items will be supplied and installed. Indicate cross references to design drawings and specifications.
- .3        Allow 14 days for Consultant's review of each submission.

- .4 Adjustments made on shop drawings by Consultant are not intended to change Contract Price. If adjustments affect value of Work, state such in writing to Consultant prior to proceeding with Work.
- .5 Make changes in shop drawings as Consultant may require, consistent with Contract Documents. When resubmitting, notify Consultant in writing of revisions other than those requested.
- .6 Accompany submissions with transmittal letter, containing:
  - .1 Date.
  - .2 Project title and number.
  - .3 Contractor's name and address.
  - .4 Identification and quantity of each shop drawing, product data and sample.
  - .5 Other pertinent data.
- .7 Submissions include:
  - .1 Date and revision dates.
  - .2 Project title and number.
  - .3 Name and address of:
    - .1 Subcontractor.
    - .2 Supplier.
    - .3 Manufacturer.
  - .4 Contractor's stamp, signed by Contractor's authorized representative certifying approval of submissions, verification of field measurements and compliance with Contract Documents.
  - .5 Details of appropriate portions of Work as applicable:
    - .1 Fabrication.
    - .2 Layout, showing dimensions, including identified field dimensions, and clearances.
    - .3 Setting or erection details.
    - .4 Capacities.
    - .5 Performance characteristics.
    - .6 Standards.
    - .7 Operating weight.
    - .8 Wiring diagrams.
    - .9 Single line and schematic diagrams.
    - .10 Relationship to adjacent work.
- .8 After Property Manager's, Engineer's, Consultant's review, distribute copies.
- .9 Submit electronic copy of shop drawings for each requirement requested in specification Sections and as Consultant and Engineer may reasonably request.
- .10 Submit electronic copies of product data sheets or brochures for requirements requested in specification Sections and as requested by Consultant where shop drawings will not be prepared due to standardized manufacture of product.

- .11 Submit electronic copies of test reports for requirements requested in specification Sections and as requested by Consultant and Engineer.
  - .1 Report signed by authorized official of testing laboratory that material, product or system identical to material, product or system to be provided has been tested in accord with specified requirements.
  - .2 Testing must have been within 3 years of date of contract award for project.
- .12 Submit electronic copies of certificates for requirements requested in specification Sections and as requested by Consultant and Engineer
  - .1 Statements printed on manufacturer's letterhead and signed by responsible officials of manufacturer of product, system or material attesting that product, system or material meets specification requirements.
  - .2 Certificates must be dated after award of project contract complete with project name.
- .13 Submit electronic copies of manufacturer's instructions for requirements requested in specification Sections and as requested by Consultant and Engineer.
  - .1 Pre-printed material describing installation of product, system or material, including special notices and Material Safety Data Sheets concerning impedances, hazards and safety precautions.
- .14 Submit electronic copies of Manufacturer's Field Reports for requirements requested in specification Sections and as requested by Consultant and Engineer.
  - .1 Documentation of the testing and verification actions taken by manufacturer's representative to confirm compliance with manufacturer's standards or instructions.
- .15 Submit electronic copies of Operation and Maintenance Data for requirements requested in specification Sections and as requested by Consultant and Engineer
- .16 Delete information not applicable to project.
- .17 Supplement standard information to provide details applicable to project.
- .18 If upon review by Consultant and Engineer, no errors or omissions are discovered or if only minor corrections are made, copies will be returned and fabrication and installation of Work may proceed. If shop drawings are rejected, noted copy will be returned and resubmission of corrected shop drawings, through same procedure indicated above, must be performed before fabrication and installation of Work may proceed.
- .19 The review of shop drawings by Project Manager and Consultant is for sole purpose of ascertaining conformance with general concept.
  - .1 This review shall not mean that Consultant approves detail design inherent in shop drawings, responsibility for which shall remain with Contractor submitting same, and such review shall not relieve Contractor of responsibility for errors or omissions in shop drawings or of responsibility for meeting requirements of construction and Contract Documents.
  - .2 Without restricting generality of foregoing, Contractor is responsible for dimensions to be confirmed and correlated at job site, for information that pertains



solely to fabrication processes or to techniques of construction and installation and for co-ordination of Work of sub-trades.

**1.3 SAMPLES**

- .1 Submit for review samples in duplicate as requested in respective specification Sections. Label samples with origin and intended use.
- .2 Deliver samples prepaid to Consultants business address.
- .3 Notify Consultant in writing, at time of submission of deviations in samples from requirements of Contract Documents.
- .4 Where colour, pattern or texture is criterion, submit full range of samples.
- .5 Adjustments made on samples by Consultant are not intended to change Contract Price. If adjustments affect value of Work, state such in writing to Consultant prior to proceeding with Work.
- .6 Make changes in samples which Consultant may require, consistent with Contract Documents.
- .7 Reviewed and accepted samples will become standard of workmanship and material against which installed Work will be verified.

**1.4 NOT USED**

- .1 Not Used.

**Part 2 Execution**

**2.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1        General**

**1.1        REFERENCES**

- .1        Canada Labour Code, Part 2, Canada Occupational Safety and Health Regulations
- .2        Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1        Material Safety Data Sheets (MSDS).
- .3        Northwest Territories & Nunavut
  - .1        The Workers Compensation Act latest edition.

**1.2        SUBMITTALS**

- .1        Make submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2        Submit site-specific Health and Safety Plan: Within 7 days after date of Notice to Proceed and prior to commencement of Work. Health and Safety Plan must include:
  - .1        Results of site specific safety hazard assessment.
  - .2        Results of safety and health risk or hazard analysis for site tasks and operation found in work plan.
- .3        Submit copies of Contractor's authorized representative's work site health and safety inspection reports to Consultant or authority having jurisdiction, as required.
- .4        Submit copies of reports or directions issued by Federal, Provincial and Territorial health and safety inspectors.
- .5        Submit copies of incident and accident reports.

**1.3        SAFETY ASSESSMENT**

- .1        Perform site specific safety hazard assessment related to project.

**1.4        MEETINGS**

- .1        Schedule and administer Health and Safety meeting with Consultant prior to commencement of Work.

**1.5        REGULATORY REQUIREMENTS**

- .1        Do Work in accordance with Section 01 41 00 - Regulatory Requirements .

**1.6        GENERAL REQUIREMENTS**

- .1        Develop written site-specific Health and Safety Plan based on hazard assessment prior to beginning site Work and continue to implement, maintain, and enforce plan until final demobilization from site. Health and Safety Plan must address project specifications.

- .2 Consultant may respond in writing, where deficiencies or concerns are noted and may request re-submission with correction of deficiencies or concerns.

### 1.7 RESPONSIBILITY

- .1 Be responsible for health and safety of persons on site, safety of property on site and for protection of persons adjacent to site and environment to extent that they may be affected by conduct of Work.
- .2 Comply with and enforce compliance by employees with safety requirements of Contract Documents, applicable federal, provincial, territorial and local statutes, regulations, and ordinances, and with site-specific Health and Safety Plan.

### 1.8 COMPLIANCE REQUIREMENTS

- .1 Comply with The Workers Compensation Act, Workplace Safety Regulation, Northwest Territories and Nunavut WSCC - Workers Safety & Compensation Commission.
- .2 Comply with Canada Labour Code, Canada Occupational Safety and Health Regulations.

### 1.9 UNFORSEEN HAZARDS

- .1 When unforeseen or peculiar safety-related factor, hazard, or condition occur during performance of Work, follow procedures in place for Employee's Right to Refuse Work in accordance with Acts and Regulations of Province having jurisdiction and advise RCMP verbally and in writing.

### 1.10 POSTING OF DOCUMENTS

- .1 Ensure applicable items, articles, notices and orders are posted in conspicuous location on site in accordance with Acts and Regulations of Province having jurisdiction, and in consultation with Consultant.

### 1.11 CORRECTION OF NON-COMPLIANCE

- .1 Immediately address health and safety non-compliance issues identified by authority having jurisdiction or by Consultant.
- .2 Provide Consultant with written report of action taken to correct non-compliance of health and safety issues identified.
- .3 Consultant may stop Work if non-compliance of health and safety regulations is not corrected.

### 1.12 WORK STOPPAGE

- .1 Give precedence to safety and health of public and site personnel and protection of environment over cost and schedule considerations for Work.

Nunavut

**Part 2 Products**

**2.1 NOT USED**

.1 Not used.

**Part 3 Execution**

**3.1 NOT USED**

.1 Not used.

**END OF SECTION**

**Part 1        General****1.1            REFERENCES AND CODES**

- .1        Perform Work in accordance with National Building Code of Canada (NBC) including amendments up to tender closing date and other codes of provincial or local application provided that in case of conflict or discrepancy, more stringent requirements apply.
- .2        Meet or exceed requirements of:
  - .1        Contract documents.
  - .2        Specified standards, codes and referenced documents.

**1.2            HAZARDOUS MATERIAL DISCOVERY**

- .1        There may be Asbestos in the subject buildings
- .2        Asbestos: demolition of spray or trowel-applied asbestos is hazardous to health. Stop work immediately when material resembling spray or trowel-applied asbestos is encountered during demolition work. Notify consultant and Project Manager.
- .3        PCB: Polychlorinated Biphenyl: stop work immediately when material resembling Polychlorinated Biphenyl is encountered during demolition work. Notify Consultant and Project Manager.
- .4        Mould: stop work immediately when material resembling mould is encountered during demolition work. Notify Consultant and Project Manager.

**1.3            BUILDING SMOKING ENVIRONMENT**

- .1        No smoking permitted.

**Part 2        Products****2.1            NOT USED**

- .1        Not Used.

**Part 3        Execution****3.1            NOT USED**

- .1        Not Used.

**END OF SECTION**

**Part 1        General****1.1        SUBMITTALS**

- .1        Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

**1.2        INSTALLATION AND REMOVAL**

- .1        Provide temporary utilities controls in order to execute work expeditiously.
- .2        Remove from site all such work after use.

**1.3        WATER SUPPLY**

- .1        Water is available for use by the contractor provided by the Building Owner

**1.4        TEMPORARY HEATING AND VENTILATION**

- .1        Provide temporary heating as required during construction period, including attendance, maintenance and fuel.
- .2        Construction heaters used inside building must be vented to outside or be non-flameless type. Solid fuel salamanders are not permitted.
- .3        Provide temporary heat and ventilation in enclosed areas as required to:
  - .1        Facilitate progress of Work.
  - .2        Protect Work and products against dampness and cold.
  - .3        Prevent moisture condensation on surfaces.
  - .4        Provide ambient temperatures and humidity levels for storage, installation and curing of materials.
  - .5        Provide adequate ventilation to meet health regulations for safe working environment.
- .4        Maintain temperatures of minimum 21 degrees C in areas where construction is in progress.
- .5        Ventilating:
  - .1        Prevent accumulations of dust, fumes, mists, vapours or gases in areas occupied during construction.
  - .2        Provide local exhaust ventilation to prevent harmful accumulation of hazardous substances into atmosphere of occupied areas.
  - .3        Dispose of exhaust materials in manner that will not result in harmful exposure to persons.
  - .4        Ventilate storage spaces containing hazardous or volatile materials.
  - .5        Ventilate temporary sanitary facilities.
  - .6        Continue operation of ventilation and exhaust system for time after cessation of work process to assure removal of harmful contaminants.

- .6 Permanent heating system of building, to be used when available. Be responsible for damage to heating system if use is permitted.
- .7 On completion of Work for which permanent heating system is used, replace filters, clean furnaces and power vacuum all ductwork inform Consultant of completion.
- .8 Ensure Date of Substantial Performance and Warranties for heating system do not commence until entire system is in as near original condition as possible and is certified by Consultant.
- .9 Maintain strict supervision of operation of temporary heating and ventilating equipment to:
  - .1 Conform with applicable codes and standards.
  - .2 Enforce safe practices.
  - .3 Prevent abuse of services.
  - .4 Prevent damage to finishes.
  - .5 Vent direct-fired combustion units to outside.
- .10 Be responsible for damage to Work due to failure in providing adequate heat and protection during construction.

**1.5 TEMPORARY POWER AND LIGHT**

- .1 Power is available for use by the contractor provided by the Building Owner.
- .2 Electrical power and lighting systems installed under this Contract may be used for construction requirements only with prior approval of consultant provided that guarantees are not affected. Make good damage to electrical system caused by use under this Contract. Replace lamps which have been used for more than 3 months.

**1.6 TEMPORARY COMMUNICATION FACILITIES**

- .1 Contractor to furnish own Temporary phone, Fax and e-mail.

**1.7 FIRE PROTECTION**

- .1 Provide and maintain temporary fire protection equipment during performance of Work required by insurance companies having jurisdiction and governing codes, regulations and bylaws.
- .2 Burning rubbish and construction waste materials is not permitted on site.

**END OF SECTION**

**Part 1 General****1.1 SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

**1.2 INSTALLATION AND REMOVAL**

- .1 Prepare site plan indicating proposed location and dimensions of area to be fenced and used by contractor, number of trailers used, avenues of ingress/egress to fenced area and details of fence installation
- .2 Indicate use of supplemental or other staging area.
- .3 Provide construction facilities in order to execute work expeditiously.
- .4 Remove from site all such work after use.

**1.3 SITE STORAGE/LOADING**

- .1 Confine work and operations of employees by Contract Documents. Do not unreasonably encumber premises with products.
- .2 Do not load or permit to load any part of Work with weight or force that will endanger Work.

**1.4 CONSTRUCTION PARKING**

- .1 Parking will be permitted on site provided it does not disrupt performance of Work or impede the operation of the detachment.
- .2 Adequate parking must be maintained for public and building occupant access. This area is already defined and is not to be used for contractor parking.
- .3 Provide and maintain adequate access to project site.

**1.5 EQUIPMENT, TOOL AND MATERIALS STORAGE**

- .1 Provide and maintain, in clean and orderly condition, lockable weatherproof sheds for storage of tools, equipment and materials.
- .2 Locate materials Required to be stored in weatherproof sheds on site in manner to cause least interference with work activities.

**1.6 SANITARY FACILITIES**

- .1 Provide sanitary facilities for work force in accordance with governing regulations and ordinances.
- .2 Post notices and take precautions as required by local health authorities. Keep area and premises in sanitary condition.



**1.7 CLEAN-UP**

- .1 Remove construction debris, waste materials, packaging material from work site daily.
- .2 Clean dirt or mud tracked onto paved or surfaced roadways.
- .3 Remove materials resulting from demolition as soon as possible from site.
- .4 Stack stored new or salvaged material not in construction facilities.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1        General**

**1.1            INSTALLATION AND REMOVAL**

- .1    Provide temporary controls in order to execute Work expeditiously.
- .2    Remove from site all such work after use.

**1.2            DUST TIGHT SCREENS**

- .1    Provide dust tight screens or insulated partitions to localize dust generating activities, and for protection of workers, finished areas of Work and public.
- .2    Maintain and relocate protection until such work is complete.

**1.3            ACCESS TO SITE**

- .1    Provide and maintain access roads, sidewalk crossings, ramps and construction runways as may be required for access to Work.

**1.4            FIRE ROUTES**

- .1    Maintain access to property including overhead clearances for use by emergency response vehicles

**1.5            PROTECTION OF BUILDING FINISHES**

- .1    Provide protection for finished and partially finished building finishes and equipment during performance of Work.
- .2    Provide necessary screens, covers, and hoardings.
- .3    Confirm with property manager and detachment commander locations and installation schedule 3 days prior to installation.
- .4    Be responsible for damage incurred due to lack of or improper protection.

**Part 2        Products**

**2.1            NOT USED**

- .1    Not Used.

**Part 3        Execution**

**3.1            NOT USED**

- .1    Not Used.

**END OF SECTION**

**Part 1        General****1.1        REFERENCES**

- .1        Within text of each specifications section, reference may be made to reference standards.
- .2        Conform to these reference standards, in whole or in part as specifically requested in specifications.
- .3        If there is question as to whether products or systems are in conformance with applicable standards, Project Manager and/or Consultant reserves right to have such products or systems tested to prove or disprove conformance.
- .4        Cost for such testing will be born by Departmental Representative in event of conformance with Contract Documents or by Contractor in event of non-conformance.

**1.2        QUALITY**

- .1        Products, materials, equipment and articles incorporated in Work shall be new, not damaged or defective, and of best quality for purpose intended. If requested, furnish evidence as to type, source and quality of products provided.
- .2        Procurement policy is to acquire, in cost effective manner, items containing highest percentage of recycled and recovered materials practicable consistent with maintaining satisfactory levels of competition. Make reasonable efforts to use recycled and recovered materials and in otherwise utilizing recycled and recovered materials in execution of work.
- .3        Defective products, whenever identified prior to completion of Work, will be rejected, regardless of previous inspections. Inspection does not relieve responsibility, but is precaution against oversight or error. Remove and replace defective products at own expense and be responsible for delays and expenses caused by rejection.
- .4        Should disputes arise as to quality or fitness of products, decision rests strictly with Project Manager based upon requirements of Contract Documents.
- .5        Unless otherwise indicated in specifications, maintain uniformity of manufacture for any particular or like item throughout building.
- .6        Permanent labels, trademarks and nameplates on products are not acceptable in prominent locations, except where required for operating instructions, or when located in mechanical or electrical rooms.

**1.3        AVAILABILITY**

- .1        Immediately upon signing Contract, review product delivery requirements and anticipate foreseeable supply delays for items. If delays in supply of products are foreseeable, notify Consultant of such, in order that substitutions or other remedial action may be authorized in ample time to prevent delay in performance of Work.

- .2 In event of failure to notify Consultant at commencement of Work and should it subsequently appear that Work may be delayed for such reason, Consultant reserves right to substitute more readily available products of similar character, at no increase in Contract Price or Contract Time.

#### 1.4 STORAGE, HANDLING AND PROTECTION

- .1 Handle and store products in manner to prevent damage, adulteration, deterioration and soiling and in accordance with manufacturer's instructions when applicable.
- .2 Store packaged or bundled products in original and undamaged condition with manufacturer's seal and labels intact. Do not remove from packaging or bundling until required in Work.
- .3 Store products subject to damage from weather in weatherproof enclosures.
- .4 Store cementitious products clear of earth or concrete floors, and away from walls.
- .5 Keep sand, when used for grout or mortar materials, clean and dry. Store sand on wooden platforms and cover with waterproof tarpaulins during inclement weather.
- .6 Store sheet materials, lumber on flat, solid supports and keep clear of ground. Slope to shed moisture.
- .7 Store and mix paints in heated and ventilated room. Remove oily rags and other combustible debris from site daily. Take every precaution necessary to prevent spontaneous combustion.
- .8 Remove and replace damaged products at own expense and to satisfaction of Consultant.
- .9 Touch-up damaged factory finished surfaces to Consultants satisfaction. Use touch-up materials to match original. Do not paint over name plates.

#### 1.5 TRANSPORTATION

- .1 Pay costs of transportation of products required in performance of Work.

#### 1.6 MANUFACTURER'S INSTRUCTIONS

- .1 Unless otherwise indicated in specifications, install or erect products in accordance with manufacturer's instructions. Do not rely on labels or enclosures provided with products. Obtain written instructions directly from manufacturers.
- .2 Notify Consultant in writing, of conflicts between specifications and manufacturer's instructions, so that Project Manager will establish course of action.
- .3 Improper installation or erection of products, due to failure in complying with these requirements, authorizes Consultant to require removal and re-installation at no increase in Contract Price or Contract Time.

**1.7 QUALITY OF WORK**

- .1 Ensure Quality of Work is of highest standard, executed by workers experienced and skilled in respective duties for which they are employed. Immediately notify Consultant if required Work is such as to make it impractical to produce required results.
- .2 Do not employ anyone unskilled in their required duties. Consultant reserves the right to require dismissal from site, workers deemed incompetent or careless.
- .3 Decisions as to standard or fitness of Quality of Work in cases of dispute rest solely with the Consultant, whose decision is final.

**1.8 CO-ORDINATION**

- .1 Ensure co-operation of workers in laying out Work. Maintain efficient and continuous supervision.
- .2 Be responsible for coordination and placement of openings, sleeves and accessories.

**1.9 CONCEALMENT**

- .1 In finished areas conceal pipes, ducts and wiring in floors, walls and ceilings, except where indicated otherwise.
- .2 Before installation inform Consultant if there is interference. Install as directed by Consultant.

**1.10 REMEDIAL WORK**

- .1 Perform remedial work required to repair or replace parts or portions of Work identified as defective or unacceptable. Co-ordinate adjacent affected Work as required.
- .2 Perform remedial work by specialists familiar with materials affected. Perform in a manner to neither damage nor put at risk any portion of Work.

**1.11 LOCATION OF FIXTURES**

- .1 Consider location of fixtures, outlets, and mechanical and electrical items indicated as approximate.
- .2 Inform Engineer of conflicting installation. Install as directed.

**1.12 FASTENINGS**

- .1 Provide metal fastenings and accessories in same texture, colour and finish as adjacent materials, unless indicated otherwise.
- .2 Prevent electrolytic action between dissimilar metals and materials.
- .3 Use non-corrosive hot dip galvanized steel fasteners and anchors for securing exterior work, unless stainless steel or other material is specifically requested in affected specification Section.

- .4 Space anchors within individual load limit or shear capacity and ensure they provide positive permanent anchorage. Wood, or any other organic material plugs are not acceptable.
- .5 Keep exposed fastenings to a minimum, space evenly and install neatly.
- .6 Fastenings which cause spalling or cracking of material to which anchorage is made are not acceptable.

**1.13 FASTENINGS - EQUIPMENT**

- .1 Use fastenings of standard commercial sizes and patterns with material and finish suitable for service.
- .2 Use heavy hexagon heads, semi-finished unless otherwise specified. Use No. 304 stainless steel for exterior areas.
- .3 Bolts may not project more than one diameter beyond nuts.
- .4 Use plain type washers on equipment, sheet metal and soft gasket lock type washers where vibrations occur. Use resilient washers with stainless steel.

**1.14 PROTECTION OF WORK IN PROGRESS**

- .1 Prevent overloading of parts of building. Do not cut, drill or sleeve load bearing structural member, unless specifically indicated without written approval of Engineer.

**1.15 EXISTING UTILITIES**

- .1 When breaking into or connecting to existing services or utilities, execute Work at times directed by local governing authorities, with minimum of disturbance to Work, and/or building occupants.
- .2 Protect, relocate or maintain existing active services. When services are encountered, cap off in manner approved by authority having jurisdiction. Stake and record location of capped service.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**



**Part 1        General****1.1        PROJECT CLEANLINESS**

- .1        Maintain Work in tidy condition, free from accumulation of waste products and debris, including that caused by Owner or other Contractors.
- .2        Remove waste materials from site at daily regularly scheduled times or dispose of as directed by Consultant. Do not burn waste materials on site, unless approved by Consultant.
- .3        Clear snow and ice from access to building, bank/pile snow in designated areas only.
- .4        Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.
- .5        Dispose of waste materials and debris off site.
- .6        Clean interior areas prior to start of finishing work, and maintain areas free of dust and other contaminants during finishing operations.
- .7        Store volatile waste in covered metal containers, and remove from premises at end of each working day.
- .8        Provide adequate ventilation during use of volatile or noxious substances. Use of building ventilation systems is not permitted for this purpose.
- .9        Use only cleaning materials recommended by manufacturer of surface to be cleaned, and as recommended by cleaning material manufacturer.
- .10        Schedule cleaning operations so that resulting dust, debris and other contaminants will not fall on wet, newly painted surfaces nor contaminate building systems.

**1.2        FINAL CLEANING**

- .1        When Work is Substantially Performed remove surplus products, tools, construction machinery and equipment not required for performance of remaining Work.
- .2        Remove waste products and debris other than that caused by others, and leave Work clean and suitable for occupancy.
- .3        Prior to final review remove surplus products, tools, construction machinery and equipment.
- .4        Remove waste products and debris including that caused by Owner or other Contractors.
- .5        Remove waste materials from site at regularly scheduled times or dispose of as directed by Consultant. Do not burn waste materials on site, unless approved by Consultant.
- .6        Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.

- .7 Remove stains, spots, marks and dirt from mechanical fixtures, walls, and floors.
- .8 Vacuum clean and dust building interiors, behind grilles, louvres and screens.
- .9 Clean roofs of debris.
- .10 Remove debris and surplus materials from crawl areas and other accessible concealed spaces.

**1.3 WASTE MANAGEMENT AND DISPOSAL**

- .1 Dispose of waste and separate waste materials for recycling as per requirements of local authorities.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1        General****1.1            INSPECTION AND DECLARATION**

- .1 Contractor's Inspection: Contractor and Subcontractors: conduct inspection of Work, identify deficiencies and defects, and repair as required to conform to Contract Documents.
  - .1 Notify Consultant in writing of satisfactory completion of Contractor's Inspection and that corrections have been made.
  - .2 Request Inspection.
- .2 Consultant and Contractor will perform inspection of Work to identify obvious defects or deficiencies. Contractor to correct Work accordingly.
- .3 Completion: submit written certificate that following have been performed:
  - .1 Work has been completed and inspected for compliance with Contract Documents.
  - .2 Defects have been corrected and deficiencies have been completed.
  - .3 Equipment and systems have been tested, adjusted and balanced and are fully operational.
  - .4 Certificates required by Fire Commissioner, Utility companies HRDC Labour Programs-Fire Protection, Engineering Services and Local Authorities have been submitted.
  - .5 Operation of systems have been demonstrated to Owner's personnel.
  - .6 Work is complete and ready for final inspection.
- .4 Final Inspection: when items noted above are completed, request final inspection of Work by Consultant and Contractor. If Work is deemed incomplete by Consultant, complete outstanding items and request reinspection.

**1.2            CLEANING**

- .1 In accordance with Section 01 74 11 -- Cleaning.
- .2 Remove waste and surplus materials, rubbish and construction facilities from the site in accordance with local authorities.

**Part 2        Products****2.1            NOT USED**

- .1 Not Used.

<b>Part 3</b>	<b>Execution</b>
<b>3.1</b>	<b>Not Used</b>
.1	Not Used.

**END OF SECTION**

**Part 1          General****1.1            SUBMITTALS**

- .1      Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2      Prepare instructions and data using personnel experienced in maintenance and operation of described products.
- .3      Copy will be returned after final inspection, with Consultant comments.
- .4      Revise content of documents as required prior to final submittal.
- .5      Two weeks prior to Substantial Performance of the Work, submit to the Consultant, four final copies of operating and maintenance manuals in English.
- .6      Ensure spare parts, maintenance materials and special tools provided are new, undamaged or defective, and of same quality and manufacture as products provided in Work.
- .7      Furnish evidence, if requested, for type, source and quality of products provided.
- .8      Defective products will be rejected, regardless of previous inspections. Replace products at own expense.
- .9      Pay costs of transportation.
- .10     Supply one electronic and 5 copies of equipment manuals for all new items installed under this project

**1.2            FORMAT**

- .1      Organize data as instructional manual.
- .2      Binders: vinyl, hard covered, 1 'D' ring, loose leaf 219 x 279 mm with spine and face pockets.
- .3      When multiple binders are used correlate data into related consistent groupings. Identify contents of each binder on spine.
- .4      Cover: identify each binder with type or printed title 'Project Record Documents'; list title of project and identify subject matter of contents.
- .5      Arrange content by systems, under Section numbers and sequence of Table of Contents.
- .6      Provide tabbed fly leaf for each separate product and system, with typed description of product and major component parts of equipment.
- .7      Text: manufacturer's printed data, or typewritten data.
- .8      Drawings: provide with reinforced punched binder tab. Bind in with text; fold larger drawings to size of text pages.

- .9 Provide scaled CAD files in dwg format on CD.

### 1.3 CONTENTS - EACH VOLUME

- .1 Table of Contents: provide title of project;
  - .1 Date of submission; names.
  - .2 Addresses, and telephone numbers of Consultant and Contractor with name of responsible parties.
  - .3 Schedule of products and systems, indexed to content of volume.
- .2 For each product or system:
  - .1 List names, addresses and telephone numbers of subcontractors and suppliers, including local source of supplies and replacement parts.
- .3 Product Data: mark each sheet to identify specific products and component parts, and data applicable to installation; delete inapplicable information.
- .4 Drawings: supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams.
- .5 Typewritten Text: as required to supplement product data. Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions specified in Section 01 45 00 - Quality Control.
- .6 Training: refer to Section 01 79 00 - Demonstration and Training.

### 1.4 AS-BUILTS AND SAMPLES

- .1 Maintain, at site for Consultant one record copy of:
  - .1 Contract Drawings.
  - .2 Specifications.
  - .3 Addenda.
  - .4 Change Orders and other modifications to Contract.
  - .5 Reviewed shop drawings, product data, and samples.
  - .6 Field test records.
  - .7 Inspection certificates.
  - .8 Manufacturer's certificates.
- .2 Store record documents and samples in field office apart from documents used for construction. Provide files, racks, and secure storage.
- .3 Label record documents and file in accordance with Section number listings in List of Contents of this Project Manual. Label each document "PROJECT RECORD" in neat, large, printed letters.
- .4 Maintain record documents in clean, dry and legible condition. Do not use record documents for construction purposes.

- .5 All copies of the documents must be turned over to consultant, **NO** copies may be maintained by the General Contractor or Trades.

## 1.5 EQUIPMENT AND SYSTEMS

- .1 Each Item of Equipment and Each System: include description of unit or system, and component parts. Give function, normal operation characteristics, and limiting conditions. Include performance curves, with engineering data and tests, and complete nomenclature and commercial number of replaceable parts.
- .2 Panel board circuit directories: provide electrical service characteristics, controls, and communications.
- .3 Include installed colour coded wiring diagrams.
- .4 Operating Procedures: include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
- .5 Maintenance Requirements: include routine procedures and guide for trouble-shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- .6 Provide servicing and lubrication schedule, and list of lubricants required.
- .7 Include manufacturer's printed operation and maintenance instructions.
- .8 Include sequence of operation by controls manufacturer.
- .9 Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- .10 Provide installed control diagrams by controls manufacturer.
- .11 Provide Contractor's co-ordination drawings, with installed colour coded piping diagrams.
- .12 Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- .13 Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- .14 Include test and balancing reports as specified in Section 01 45 00 - Quality Control.
- .15 Additional requirements: as specified in individual specification sections.

## 1.6 MATERIALS AND FINISHES

- .1 Building Products, Applied Materials, and Finishes: include product data, with catalogue number, size, composition, and colour and texture designations. Provide information for re-ordering custom manufactured products.

- .2 Instructions for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .3 Moisture-Protection and Weather-Exposed Products: include manufacturer's recommendations for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .4 Additional Requirements: as specified in individual specifications sections.

#### **1.7 SPARE PARTS**

- .1 Provide spare parts, in quantities specified in individual specification sections.
- .2 Provide items of same manufacture and quality as items in Work.
- .3 Deliver to site; place and store.
- .4 Receive and catalogue items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.
- .5 Obtain receipt for delivered products and submit prior to final payment.

#### **1.8 SPECIAL TOOLS**

- .1 Provide special tools, in quantities specified in individual specification sections.
- .2 Provide items with tags identifying their associated function and equipment.
- .3 Deliver to site; place and store
- .4 Receive and catalogue items. Submit inventory listing to Consultant. Include approved listing in Maintenance Manual

#### **1.9 MAINTENANCE MATERIALS**

- .1 Provide maintenance and extra materials, in quantities specified in individual specification sections.
- .2 Provide items of same manufacture and quality as items in Work.
- .3 Deliver to site; place and store.
- .4 Receive and catalogue items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.
- .5 Obtain receipt for delivered products and submit prior to final payment.

#### **1.10 SPECIAL TOOLS**

- .1 Provide special tools, in quantities specified in individual specification section.
- .2 Provide items with tags identifying their associated function and equipment.



Nunavut

- .3 Deliver to site; place and store.
- .4 Receive and catalogue items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.

**1.11 STORAGE, HANDLING AND PROTECTION**

- .1 Store spare parts, maintenance materials, and special tools in manner to prevent damage or deterioration.
- .2 Store in original and undamaged condition with manufacturer's seal and labels intact.
- .3 Store components subject to damage from weather in weatherproof enclosures.
- .4 Store paints and freezable materials in a heated and ventilated room.
- .5 Remove and replace damaged products at own expense and to satisfaction of Consultant.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1            General**

**1.1                SECTION INCLUDES**

- .1    Equipment and systems.
- .2    Materials and finishes.
- .3    Spare parts.
- .4    Maintenance manuals.
- .5    Special tools.
- .6    Storage, handling and protection.

**1.2                RELATED SECTIONS**

- .1    Section 017800 - Closeout Submittals.

**1.3                EQUIPMENT AND SYSTEMS**

- .1    Each Item of Equipment and Each System: include description of unit or system, and component parts. Give function, normal operation characteristics, and limiting conditions. Include performance curves, with engineering data and tests, and complete nomenclature and commercial number of replaceable parts.
- .2    Panel board circuit directories: provide electrical service characteristics, controls, and communications.
- .3    Include installed colour coded wiring diagrams.
- .4    Operating Procedures: include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
- .5    Maintenance Requirements: include routine procedures and guide for trouble-shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- .6    Provide servicing and lubrication schedule, and list of lubricants required.
- .7    Include manufacturer's printed operation and maintenance instructions.
- .8    Include sequence of operation by controls manufacturer.
- .9    Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- .10   Provide installed control diagrams by controls manufacturer.

- .11 Provide Contractor's coordination drawings, with installed colour coded piping diagrams.
- .12 Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- .13 Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- .14 Include test and balancing reports.
- .15 Additional requirements: As specified in individual specification sections.

**1.4 MATERIALS AND FINISHES**

- .1 Building Products, Applied Materials, and Finishes: include product data, with catalogue number, size, composition, and colour and texture designations. Provide information for re-ordering custom manufactured products.
- .2 Instructions for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .3 Moisture-protection and Weather-exposed Products: include manufacturer's recommendations for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .4 Building Envelope: include copies of drawings of building envelope components, illustrating the interface with similar or dissimilar items to provide an effective air, vapour and thermal barrier between indoor and outdoor environments. Include an outline of requirements for regular inspections and for regular maintenance to ensure that on-going performance of the building envelope will meet the initial building envelope criteria.
- .5 Additional Requirements: as specified in individual specifications sections.

**1.5 SPARE PARTS**

- .1 Provide spare parts, in quantities specified in individual specification sections.
- .2 Provide items of same manufacture and quality as items in Work.
- .3 Deliver to site; place and store.
- .4 Receive and catalogue all items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.
- .5 Obtain receipt for delivered products and submit prior to final payment.

**1.6 MAINTENANCE MATERIALS**

- .1 Provide maintenance and extra materials, in quantities specified in individual specification sections.
- .2 Provide items of same manufacture and quality as items in Work.

- .3 Deliver to site; place and store.
- .4 Receive and catalogue all items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.
- .5 Obtain receipt for delivered products and submit prior to final payment.

**1.7 SPECIAL TOOLS**

- .1 Provide special tools, in quantities specified in individual specification section.
- .2 Provide items with tags identifying their associated function and equipment.
- .3 Deliver to site; place and store.
- .4 Receive and catalogue all items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.

**1.8 STORAGE, HANDLING AND PROTECTION**

- .1 Store spare parts, maintenance materials, and special tools in manner to prevent damage or deterioration.
- .2 Store in original and undamaged condition with manufacturer's seal and labels intact.
- .3 Store components subject to damage from weather in weatherproof enclosures.
- .4 Store paints and freezable materials in a heated and ventilated room.
- .5 Remove and replace damaged products at own expense and to satisfaction of Consultant.

**END OF SECTION**

**Part 1        General**

**1.1            DESCRIPTION**

- .1     Demonstrate operation and maintenance of equipment and systems to Owner's personnel two weeks prior to date of final inspection.
- .2     Owner will provide list of personnel to receive instructions, and will co-ordinate their attendance at agreed-upon times.

**1.2            QUALITY CONTROL**

- .1     When specified in individual Sections require manufacturer to provide authorized representative to demonstrate operation of equipment and systems, instruct Owner's personnel, and provide written report that demonstration and instructions have been completed.

**1.3            SUBMITTALS**

- .1     Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2     Submit schedule of time and date for demonstration of each item of equipment and each system two weeks prior to designated dates, for Consultant approval.
- .3     Submit reports within one week after completion of demonstration, that demonstration and instructions have been satisfactorily completed.
- .4     Give time and date of each demonstration, with list of persons present.

**1.4            CONDITIONS FOR DEMONSTRATIONS**

- .1     Provide copies of completed operation and maintenance manuals for use in demonstrations and instructions.

**1.5            PREPARATION**

- .1     Verify that conditions for demonstration and instructions comply with requirements.
- .2     Verify that designated personnel are present.

**1.6            DEMONSTRATION AND INSTRUCTIONS**

- .1     Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, and maintenance of each item of equipment at agreed upon times, at the designated location.
- .2     Instruct personnel in phases of operation and maintenance using operation and maintenance manuals as basis of instruction.
- .3     Review contents of manual in detail to explain aspects of operation and maintenance.

- .4 Prepare and insert additional data in operations and maintenance manuals when need for additional data becomes apparent during instructions.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not Used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not Used.

**END OF SECTION**

**Part 1        General****1.1        SUMMARY**

- .1        Section Includes:
  - .1        This section is limited to portions of the Building Management Manual (BMM) provided to Departmental Representative by Contractor.
- .2        Acronyms:
  - .1        BMM - Building Management Manual.
  - .2        HVAC - Heating, Ventilation and Air Conditioning.
  - .3        PI - Product Information.
  - .4        PV - Performance Verification.
  - .5        TAB - Testing, Adjusting and Balancing.
  - .6        WHMIS - Workplace Hazardous Materials Information System.

**1.2        GENERAL REQUIREMENTS**

- .1        Standard letter size paper 216 mm x 279mm.
- .2        Binders: vinyl hard covered, 1” “D” ring,(not “O” ring) loose leaf sized, with spine pocket. Identify contents of each binder on spine
- .3        Methodology used to facilitate updating.
- .4        Drawings, diagrams and schematics to be professionally developed.
- .5        Electronic copy of data to be in a format accepted and approved by Property Manger (PDF).

**1.3        APPROVALS**

- .1        Prior to commencement, co-ordinate requirements for preparation, submission and approval with Property Manager.

**1.4        GENERAL INFORMATION**

- .1        Provide Consultant the following for insertion into appropriate Part and Section of BMM:
  - .1        Complete list of names, addresses, telephone and fax numbers of contractor, sub-contractors that participated in delivery of project - as indicated in Section 1.2 of BMM.
  - .2        Summary of architectural, structural, fire protection, mechanical and electrical systems installed and commissioned - as indicated in Section 1.4 of BMM.
    - .1        Including sequence of operation as finalized after commissioning is complete as indicated in Section 2.0 of BMM.
  - .3        Description of building operation under conditions of heightened security and emergencies as indicated in Section 2.0 of BMM.

- .4 System, equipment and components Maintenance Management System (MMS) identification - Section 2.1 of BMM.
- .5 Information on operation and maintenance of architectural systems and equipment installed and commissioned - Section 2.0 of BMM.
- .6 Information on operation and maintenance of fire protection and life safety systems and equipment installed and commissioned - Section 2.0 of BMM.
- .7 Information on operation and maintenance of mechanical systems and equipment installed and commissioned - Section 2.0 of BMM.
- .8 Operating and maintenance manual - Section 3.2 of BMM.
- .9 Final commissioning plan as actually implemented.
- .10 Completed commissioning checklists.
- .11 Commissioning test procedures employed.
- .12 Completed Product Information (PI) and Performance Verification (PV) report forms, approved and accepted by Property Manager.
- .13 Commissioning reports.

**1.5****CONTENTS OF OPERATING AND MAINTENANCE MANUAL**

- .1 For detailed requirements refer to Section 01 78 00 - Closeout Submittals.
- .2 Consultant to review and approve format and organization within 2 weeks of award of contract.
- .3 Include original manufactures brochures and written information on products and equipment installed on this project.
- .4 Record and organize for easy access and retrieval of information contained in BMM.
- .5 Include completed PI report forms, data and information from other sources as required.
- .6 Inventory directory relating to information on installed systems, equipment and components.
- .7 Approved project shop-drawings, product and maintenance data.
- .8 Manufacturer's data and recommendations relating: manufacturing process, installation, commissioning, start-up, O&M, shutdown and training materials.
- .9 Inventory and location of spare parts, special tools and maintenance materials.
- .10 Warranty information.
- .11 Inspection certificates with expiration dates, which require on-going re-certification inspections.
- .12 Maintenance program supporting information including:
  - .1 Recommended maintenance procedures and schedule.
  - .2 Information to removal and replacement of equipment including, required equipment, points of lift and means of entry and egress.



**1.6 SUPPORTING DOCUMENTATION FOR INSERTION INTO SUPPORTING APPENDICES**

- .1 Provide RCMP supporting documentation relating to installed equipment and system, including:
  - .1 Mechanical:
    - .1 Installation permits, inspection certificates, inspection reports.

**1.7 LANGUAGE**

- .1 English.

**1.8 IDENTIFICATION OF FACILITY**

- .1 When submitting information to Departmental Representative for incorporation into BMM, use following system for identification of documentation:
  - .1 To be supplied to successful contractor.

**1.9 USE OF CURRENT TECHNOLOGY**

- .1 Use current technology for production of documentation. Emphasis on ease of accessibility at all times, maintain in up-to-date state, compatibility with user's requirements.

**Part 2 Products**

**2.1 NOT USED**

- .1 Not used.

**Part 3 Execution**

**3.1 NOT USED**

- .1 Not used.

**END OF SECTION**

**Part 1        General****1.1        SUBMITTALS**

- .1        Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2        Shop drawings; submit drawings stamped and signed by professional engineer registered or licensed in Nunavut, Canada.
- .3        Shop drawings to show:
  - .1        Mounting arrangements.
  - .2        Operating and maintenance clearances.
- .4        Shop drawings and product data accompanied by:
  - .1        Detailed drawings of bases, supports, and anchor bolts.
  - .2        Acoustical sound power data, where applicable.
  - .3        Points of operation on performance curves.
  - .4        Manufacturer to certify current model production.
  - .5        Certification of compliance to applicable codes.
- .5        In addition to transmittal letter referred to in Section 01 33 00 - Submittal Procedures: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
- .6        Closeout Submittals:
  - .1        Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
  - .2        Operation and maintenance manual approved by, and final copies deposited with, Consultant before final inspection.
  - .3        Operation data to include:
    - .1        Control schematics for systems including environmental controls.
    - .2        Description of systems and their controls.
    - .3        Description of operation of systems at various loads together with reset schedules and seasonal variances.
    - .4        Operation instruction for systems and component.
    - .5        Description of actions to be taken in event of equipment failure.
  - .4        Maintenance data to include:
    - .1        Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
    - .2        Data to include schedules of tasks, frequency, tools required and task time.
  - .5        Performance data to include:
    - .1        Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
    - .2        Equipment performance verification test results.

- .3 Special performance data as specified.
- .4 Testing, adjusting and balancing reports as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
- .6 Approvals:
  - .1 Submit 2 copies of draft Operation and Maintenance Manual to Consultant for approval. Submission of individual data will not be accepted unless directed by Consultant.
  - .2 Make changes as required and re-submit as directed by Consultant.
- .7 Additional data:
  - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
- .8 Site records:
  - .1 Consultant will provide 1 set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
  - .2 Transfer information weekly to reproducibles, revising reproducibles to show work as actually installed.
  - .3 Use different colour waterproof ink for each service.
  - .4 Make available for reference purposes and inspection.
- .9 As-built drawings:
  - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
  - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
  - .3 Submit to Consultant for approval and make corrections as directed.
  - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.
  - .5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.
- .10 Submit copies of as-built drawings for inclusion in final TAB report.

## 1.2 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

## 1.3 MAINTENANCE

- .1 Furnish spare parts in accordance with Section 01 78 00 - Closeout Submittals as follows:
  - .1 12 furnace filters

- .2 6 fuel filters
- .2 Provide one set of special tools required to service equipment as recommended by manufacturers and in accordance with Section 01 78 00 - Closeout Submittals.

**1.4 DELIVERY, STORAGE, AND HANDLING**

- .1 Waste Management and Disposal:
  - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 Execution**

**2.1 SECURITY FASTENERS**

- .1 Security screws are required to be used in all secure areas.

**2.2 PAINTING REPAIRS AND RESTORATION**

- .1 Do painting in accordance with Section 09 91 23 - Interior Painting.
- .2 Prime and touch up marred finished paintwork to match original.
- .3 Restore to new condition, finishes which have been damaged.

**2.3 CLEANING**

- .1 Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork and air handling units.

**2.4 DEMONSTRATION**

- .1 Departmental Representative will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
- .2 Trial usage to apply to following equipment and systems:
  - .1 Furnaces.
- .3 Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
- .4 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.
- .5 Instruction duration time requirements as specified in appropriate sections.

**2.5**

**PROTECTION**

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.

**END OF SECTION**

**Part 1          General****1.1            SECTION INCLUDES**

- .1      Testing, adjustment, and balancing of air systems.
- .2      Measurement of final operating condition of HVAC systems.

- .3      **Balancing is only required for Facility Buildings**

**1.2            RELATED SECTIONS**

- .1      Section 01 33 00 - Administrative Requirements.
- .2      Section 01 61 00 - Common Product Requirements.

**1.3            REFERENCES**

- .1      AABC - National Standards for Total System Balance.
- .2      ADC - Test Code for Grilles, Registers, and Diffusers.
- .3      ASHRAE 111 - Practices for Measurement, Testing, Adjusting, and Balancing of Building Heating, Ventilation, Air-conditioning, and Refrigeration Systems.
- .4      NEBB - Procedural Standards for Testing, Adjusting, and Balancing of Environmental Systems.
- .5      SMACNA - HVAC Systems Testing, Adjusting, and Balancing.

**1.4            SUBMITTALS**

- .1      Section 01 33 00: Procedures for submittals.
- .2      Submit name of adjusting and balancing agency for approval within 30 days after award of Contract.
- .3      Section 01 44 00: Procedures for submitting Field Reports.
- .4      Field Reports: Indicate deficiencies in systems that would prevent proper testing, adjusting, and balancing of systems and equipment to achieve specified performance.
- .5      Prior to commencing work, submit report forms or outlines indicating adjusting, balancing, and equipment data required.
- .6      Submit draft copies of report for review prior to final acceptance of Project. Provide final copies for Consultant and for inclusion in operating and maintenance manuals.
- .7      Provide reports in soft cover, letter size, 3-ring binder manuals, complete with index page and indexing tabs, with cover identification at front and side. Include set of reduced

drawings with air outlets and equipment identified to correspond with data sheets, and indicating thermostat locations.

- .8 Include detailed procedures, agenda, sample report forms and copy of AABC National Project Performance Guaranty prior to commencing system balance.
- .9 Test Reports: Indicate data on AABC National Standards for Total System Balance forms. Submit data in S.I. Metric units.

### **1.5 PROJECT RECORD DOCUMENTS**

- .1 Section 01 78 10: Submittals for project closeout.
- .2 Record actual locations of flow measuring stations and balancing valves and rough setting.

### **1.6 QUALITY ASSURANCE**

- .1 Perform total system balance to AABC National Standards for Field Measurement and Instrumentation, Total System Balance.
- .2 Maintain one copy of each document on site.

### **1.7 QUALIFICATIONS**

- .1 Agency: Company specializing in the testing, adjusting, and balancing of systems specified in this Section with minimum three years documented experience certified by AABC/CAABC.
- .2 Perform Work under supervision of CAABC Certified Test and Balance Engineer.

### **1.8 SEQUENCING**

- .1 Sequence work to Section 01 10 13.
- .2 Sequence work to commence after completion of systems and schedule completion of work before Substantial Completion of Project.

### **1.9 SCHEDULING**

- .1 Schedule work to Section 01 33 00.
- .2 Schedule and provide assistance in final adjustment and test of life safety and smoke control system with Fire Authority.

### **Part 2 Products**

- .1 Not used

**Part 3 Execution****3.1 AGENCIES**

- .1 Testing agency must be AABC/CAABC certified balancing company
- .2 Testing by Mechanical contractor will not be accepted unless the contractor is certified by the above agency

**3.2 EXAMINATION**

- .1 Verify that systems are complete and operable before commencing work. Ensure the following conditions:
  - .1 Systems are started and operating in a safe and normal condition.
  - .2 Temperature control systems are installed complete and operable.
  - .3 Final filters are clean and in place. If required, install temporary media in addition to final filters.
  - .4 Duct systems are clean of debris.
  - .5 Fans are rotating correctly.
  - .6 Fire and volume dampers are in place and open.
  - .7 Access doors are closed and duct end caps are in place.
  - .8 Air outlets are installed and connected.
  - .9 Duct system leakage is minimized.
- .2 Submit field reports. Report defects and deficiencies noted during performance of services which prevent system balance.
- .3 Beginning of work means acceptance of existing conditions.

**3.3 PREPARATION**

- .1 Provide instruments required for testing, adjusting, and balancing operations. Make instruments available to Consultant to facilitate spot checks during testing.
- .2 Provide additional balancing devices as required.

**3.4 INSTALLATION TOLERANCES**

- .1 Air Handling Systems: Adjust to within plus or minus 5 percent of design for supply systems and plus or minus 10 percent of design for return and exhaust systems.
- .2 Air Outlets and Inlets: Adjust total to within plus 10 percent and minus 5 percent of design to space. Adjust outlets and inlets in space to within plus or minus 10 percent of design.

**3.5 ADJUSTING**

- .1 Ensure recorded data represents actual measured or observed conditions.



- .2 Permanently mark settings of valves, dampers, and other adjustment devices allowing settings to be restored. Set and lock memory stops.
- .3 After adjustment, take measurements to verify balance has not been disrupted or that such disruption has been rectified.
- .4 Leave systems in proper working order, replacing belt guards, closing access doors, closing doors to electrical switch boxes, and restoring thermostats to specified settings.
- .5 At final inspection, recheck random selections of data recorded in report. Recheck points or areas as selected and witnessed by the Owner.
- .6 Check and adjust systems approximately six months after final acceptance and submit report.

### 3.6 AIR SYSTEM PROCEDURE

- .1 Adjust air handling and distribution systems to provide required or design supply, return, and exhaust air quantities [at site altitude].
- .2 Make air quantity measurements in ducts by Pitot tube traverse of entire cross sectional area of duct.
- .3 Measure air quantities at air inlets and outlets.
- .4 Adjust distribution system to obtain uniform space temperatures free from objectionable drafts and noise.
- .5 Use volume control devices to regulate air quantities only to extend that adjustments do not create objectionable air motion or sound levels. Effect volume control by duct internal devices such as dampers and splitters.
- .6 Vary total system air quantities by adjustment of fan speeds. Provide drive changes required. Vary branch air quantities by damper regulation.
- .7 Provide system schematic with required and actual air quantities recorded at each outlet or inlet.
- .8 Measure static air pressure conditions on air supply units, including filter and coil pressure drops, and total pressure across the fan. Make allowances for 50 percent loading of filters.
- .9 Adjust outside air automatic dampers, outside air, return air, and exhaust dampers for design conditions.
- .10 Measure temperature conditions across outside air, return air, and exhaust dampers to check leakage.
- .11 Where modulating dampers are provided, take measurements and balance at extreme conditions. [Balance variable volume systems at maximum air flow rate, full cooling, and at minimum air flow rate, full heating.]

- .12 Measure building static pressure and adjust supply, return, and exhaust air systems to provide required relationship between each to maintain approximately 12.5 Pa positive static pressure near the building entries.
- .13 Check multi-zone units for motorized damper leakage. Adjust air quantities with mixing dampers set first for cooling, then heating, then modulating.
- .14 For variable air volume system powered units set volume controller to air flow setting indicated. Confirm connections properly made and confirm proper operation for automatic variable air volume temperature control.
- .15 On fan powered VAV boxes, adjust air flow switches for proper operation.

### 3.7

#### SCHEDULES

- .1 Equipment requiring testing, adjusting and balancing:
  - .1 Forced Air Furnaces
  - .2 Air Inlets and Outlets
- .2 Report Forms
  - .1 Title Page:
    - .1 Name of Testing, Adjusting, and Balancing Agency
    - .2 Address of Testing, Adjusting, and Balancing Agency
    - .3 Telephone number of Testing, Adjusting, and Balancing Agency
    - .4 Project name
    - .5 Project location
    - .6 Project Architect
    - .7 Project Engineer
    - .8 Project Contractor
    - .9 Project altitude
    - .10 Report date
  - .2 Summary Comments:
    - .1 Design versus final performance
    - .2 Notable characteristics of system
    - .3 Description of systems operation sequence
    - .4 Summary of outdoor and exhaust flows to indicate amount of building pressurization
    - .5 Nomenclature used throughout report
    - .6 Test conditions
  - .3 Instrument List:
    - .1 Instrument
    - .2 Manufacturer
    - .3 Model number
    - .4 Serial number
    - .5 Range

- .6 Calibration date
- .4 Electric Motors:
  - .1 Manufacturer
  - .2 Model/Frame
  - .3 HP/BHP
  - .4 Phase, voltage, amperage; nameplate, actual, no load
  - .5 RPM
  - .6 Service factor
  - .7 Starter size, rating, heater elements
  - .8 Sheave Make/Size/Bore
- .5 Air Moving Equipment
  - .1 Location
  - .2 Manufacturer
  - .3 Model number
  - .4 Serial number
  - .5 Arrangement/Class/Discharge
  - .6 Air flow, specified and actual
  - .7 Return air flow, specified and actual
  - .8 Outside air flow, specified and actual
  - .9 Total static pressure (total external), specified and actual
  - .10 Inlet pressure
  - .11 Discharge pressure
  - .12 Sheave Make/Size/Bore
  - .13 Number of Belts/Make/Size
  - .14 Fan RPM

**END OF SECTION**

**Part 1        General****1.1        SECTION INCLUDES**

- .1        Duct work insulation.
- .2        Duct Liner.
- .3        Insulation jackets.

**1.2        RELATED SECTIONS**

- .1        Section 01 33 00 - Administrative Requirements.
- .2        Section 01 44 00 - Quality Assurance.
- .3        Section 01 61 00 - Common Product Requirements.
- .4        Section 09 91 10 - Painting: Painting insulation jackets.
- .5        Section 23 05 53 - Mechanical Identification.
- .6        Section 23 31 00 - Duct Work: Glass fibre duct work.
- .7        Section 23 31 00 - Duct Work: Duct liner.

**1.3        REFERENCES**

- .1        Section 01 44 00: Requirements for references and standards.
- .2        ASTM B209 - Aluminum and Aluminum-Alloy Sheet and Plate.
- .3        ASTM C518 - Steady-State Thermal Transmission Properties by Means of the Heat Flow Metre Apparatus.
- .4        ASTM C553 - Standard Specification for Mineral Fibre Blanket Thermal Insulation for Commercial and Industrial Applications.
- .5        ASTM C612 - Standard Specification for Mineral Fibre Block and Board Thermal Insulation.
- .6        ASTM C921 - Properties of Jacketing Materials for Thermal Insulation.
- .7        ASTM C1071 - Fibrous Glass Duct Lining Insulation(Thermal Sound Absorbing Material).
- .8        ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- .9        ASTM E96 - Water Vapour Transmission of Materials.

- .10 ASTM E162 - Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source.
- .11 ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi.
- .12 NAIMA National Insulation Standards.
- .13 NFPA 255 - Standard Method of Test of Surface Burning Characteristics of Building Materials.
- .14 SMACNA - HVAC Duct Construction Standards - Metal and Flexible.
- .15 UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials.

#### **1.4 SUBMITTALS FOR REVIEW**

- .1 Section 01 33 00: Procedures for submittals.
- .2 Product Data: Provide product description, thermal characteristics, list of materials and thickness for each service, and locations.

#### **1.5 SUBMITTALS FOR INFORMATION**

- .1 Section 01 33 00: Procedures for submittals.
- .2 Manufacturer's Instructions: Indicate installation procedures which ensure acceptable workmanship and installation standards will be achieved.

#### **1.6 QUALITY ASSURANCE**

- .1 Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- .2 Applicator Qualifications: Company specializing in performing the work of this section with minimum three years documented experience.

#### **1.7 REGULATORY REQUIREMENTS**

- .1 Materials: Flame spread/smoke developed rating of 25/50 to ASTM E84, NFPA 255, UL 723.

#### **1.8 DELIVERY, STORAGE, AND PROTECTION**

- .1 Section 01 61 00: Transport, handle, store, and protect products.
- .2 Accept materials on site in original factory packaging, labelled with manufacturer's identification, including product density and thickness.
- .3 Protect insulation from weather and construction traffic, dirt, water, chemical, and mechanical damage, by storing in original wrapping.

**1.9 ENVIRONMENTAL REQUIREMENTS**

- .1 Section 01 61 00: Environmental conditions affecting products on site.
- .2 Maintain ambient temperatures and conditions required by manufacturers of adhesives, mastics, and insulation cements.
- .3 Maintain temperature during and after installation for minimum period of 24 hours.

**Part 2 Products****2.1 INSULATION**

- .1 Mineral fibre: as specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 deg C mean temperature when tested in accordance with ASTM C 335
- .3 TIAC Code C-1; Rigid mineral fibre board to ASTM C 612, with or without factory applied vapour retarder jacket to CBSB 51-GP-52Ma
- .4 TIAC Code C-2: Mineral fibre blanket to ASTM C 553 faced with or without factory applied vapour retarder jacket to CGSB 51-GP-52Ma
  - .1 Mineral Fibre to ASTM c 553
  - .2 Jacket: to CGSB 51-gp-52MA
  - .3 Maximum "k" Factor to ASTM C 553

**2.2 JACKETS**

- .1 Canvas:
  - .1 220 gm/m2 cotton. Plain weave, treated with dilute fire retardant lagging adhesive to ASTM C921

**2.3 ACCESSORIES**

- .1 Vapour retarder lap adhesive
  - .1 Water based, fire retardant type, compatible with insulation
- .2 Indoor Vapour Retarder Finish
  - .1 Vinyl emulsion type acrylic, compatible with insulation
- .3 Insulating Cement: hydraulic setting on mineral wool, to ASTM C 449
- .4 ULC Listed Canvas Jacket
- .5 Tape self-adhesive, aluminum reinforced 75mm wide
- .6 Contact adhesive: quick setting
- .7 Canvas adhesive: washable

- .8 Tie wire: 1.5mm stainless steel
- .9 Banding: 12mm wide, 0.5mm thick stainless steel
- .10 Facing: 25mm galvanized steel hexagonal wire mesh stitched on one face of insulation
- .11 Fasteners: 4mm dia pins with 35mm dia clips, length to suit insulation thickness.

### Part 3 Execution

#### 3.1 EXAMINATION

- .1 Section 01 70 00 - Examination and Preparation: Verification of existing conditions before starting work.
- .2 Verify that duct work has been tested before applying insulation materials.
- .3 Verify that surfaces are clean, foreign material removed, and dry.

#### 3.2 INSTALLATION

- .1 Section 01 44 00 - Quality Assurance: Manufacturer's instructions.
- .2 Install to NAIMA National Insulation Standards.
- .3 Insulated duct work conveying air below ambient temperature:
  - .1 Provide insulation with vapour barrier jackets.
  - .2 Finish with tape and vapour barrier jacket.
  - .3 Continue insulation through walls, sleeves, hangers, and other duct penetrations.
  - .4 Insulate entire system including fittings, joints, flanges, fire dampers, flexible connections, and expansion joints.
- .4 Insulated duct work conveying air above ambient temperature:
  - .1 Provide with or without standard vapour barrier jacket.
  - .2 Insulate fittings and joints. Where service access is required, bevel and seal ends of insulation.
- .5 Duct Work Exposed in Mechanical Equipment Rooms or Finished Spaces below 3 metres above finished floor: Finish with canvas jacket sized for finish painting or aluminum jacket.
- .6 Exterior Applications: Provide insulation with vapour barrier jacket. Cover with caulked aluminum jacket with seams located on bottom side of horizontal duct section.
- .7 External Duct Insulation Application:
  - .1 Secure insulation with vapour barrier with wires and seal jacket joints with vapour barrier adhesive or tape to match jacket.

- .2 Secure insulation without vapour barrier with staples, tape, or wires.
- .3 Install without sag on underside of duct work. Use adhesive or mechanical fasteners where necessary to prevent sagging. Lift duct work off trapeze hangers and insert spacers.
- .4 Seal vapour barrier penetrations by mechanical fasteners with vapour barrier adhesive.
- .5 Stop and point insulation around access doors and damper operators to allow operation without disturbing wrapping.
- .8 Duct and Plenum Liner Application:
  - .1 Adhere insulation with adhesive for 90 percent coverage.
  - .2 Secure insulation with mechanical liner fasteners. Refer to SMACNA Standards for spacing.
  - .3 Seal and smooth joints. Seal and coat transverse joints.
  - .4 Seal liner surface penetrations with adhesive.
  - .5 Duct dimensions indicated are net inside dimensions required for air flow. Increase duct size to allow for insulation thickness.

**3.3 SCHEDULES**

<b>Ducts</b>	<b>Insulation</b>
Exhaust Ducts Within 3 m of Exterior Openings	2" foil-faced insulation
Outside Air Intake Ducts and Plenum	2" foil-faced insulation
Supply and Return Ducts and Plenums in Basement	1" foil-faced insulation or to match existing
Supply and Return Ducts and Plenums in Crawlspace	2" foil-faced insulation or to match existing
Supply and Return Ducts and Plenums in Attic space	2" foil-faced insulation
Supply and Return Ducts in Ceiling Space above General offices	Acoustic insulation
Vertical supply and return shafts supplying General offices	Acoustic insulation

**END OF SECTION**



**Part 1            General**

**1.1                SECTION INCLUDES**

- .1     Metal duct work.
- .2     Casing and plenums.
- .3     Duct cleaning.

**1.2                RELATED SECTIONS**

- .1     Section 01 10 00 - Summary of Work:
- .2     Section 01 33 00 - Administrative Requirements.
- .3     Section 01 61 00 - Common Product Requirements.
- .4     Section 01 78 10 - Execution Requirements.
- .5     Section 03 30 00 - Cast-in-place Concrete.
- .6     Section 09 91 10 - Painting: Weld priming, weather resistant, paint or coating.
- .7     Section 11 40 00 - Food Service Equipment: Supply of kitchen range hoods for placement by this Section.
- .8     Section 23 05 29 - Supports And Anchors: Sleeves.
- .9     Section 23 07 13 - Duct Insulation: External insulation and duct liner.
- .10    Section 23 33 00 - Duct Work Accessories.
- .11    Section 23 36 00 - Air Terminal Units.
- .12    Section 23 37 00 - Air Outlets And Inlets.
- .13    Section 23 05 93 - Testing, Adjusting, And Balancing.

**1.3                REFERENCES**

- .1     ASTM A36/A36M - Carbon Structural Steel.
- .2     ASTM A90/A90M - Weight (Mass) of Coating on Iron and Steel Articles with Zinc or Zinc-Alloy Coatings.
- .3     ASTM A167 - Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip.
- .4     ASTM A480/A480M - General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet, and Strip.

- .5 ASTM A568/A568M - General Requirements for Steel Sheet, Carbon, and High-Strength, Low-Alloy, Hot-Rolled and Cold-Rolled.
- .6 ASTM A653/A653M - Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- .7 ASTM A1008/A1008M - Steel, Sheet, Cold-Rolled Carbon, Structural, High-Strength Low-Alloy and High Strength Low-Alloy with Improved Formability.
- .8 ASTM A1011/A1011M - Standard Specification for Steel, Sheet, and Strip Hot-Rolled, Carbon, Structural, High-Strength, Low-Alloy with Improved Formability.
- .9 ASTM B209 - Aluminum and Aluminum-Alloy Sheet and Plate.
- .10 ASTM C14/C14M - Concrete Sewer, Storm Drain, and Culvert Pipe.
- .11 ASTM C443 - Joints for Concrete Pipe and Manholes, Using Rubber Gaskets.
- .12 AWS D9.1 - Sheet Metal Welding Code.
- .13 NBS PS 15 - Voluntary Product Standard for Custom Contact-Moulded Reinforced-Polyester Chemical Resistant Process Equipment.
- .14 NFPA 90A - Installation of Air Conditioning and Ventilating Systems.
- .15 NFPA 90B - Installation of Warm Air Heating and Air-Conditioning Systems.
- .16 NFPA 91 - Exhaust Systems for Air Conveying of Vapours, Gases, Mists, and Noncombustible Particulate Solids.
- .17 NFPA 96 - Ventilation Control and Fire Protection of Commercial Cooking Operations.
- .18 SMACNA - HVAC Air Duct Leakage Test Manual.
- .19 SMACNA - HVAC Duct Construction Standards - Metal and Flexible.
- .20 SMACNA - Fibrous Glass Duct Construction Standards.
- .21 UL 181 - Factory-Made Air Ducts and Connectors.

#### 1.4 PERFORMANCE REQUIREMENTS

- .1 No variation of duct configuration or sizes permitted except by written permission. Size round ducts installed in place of rectangular ducts to ASHRAE table of equivalent rectangular and round ducts.

#### 1.5 SUBMITTALS

- .1 Section 01 33 00: Procedures for submittals.

.2 Shop Drawings: Indicate duct fittings, particulars such as gauges, sizes, welds, and configuration prior to start of work for 1000 kPa pressure class and higher glass fibre duct systems.

.3 Product Data: Provide data for duct materials duct liner duct connectors .

## 1.6 PROJECT RECORD DOCUMENTS

.1 Section 01 78 10: Submittals for project closeout.

.2 Record actual locations of ducts and duct fittings. Record changes in fitting location and type. Show additional fittings used.

## 1.7 QUALITY ASSURANCE

.1 Perform Work to SMACNA - HVAC Duct Construction Standards - Metal and Flexible.

.2 Maintain one copy of document on site.

## 1.8 QUALIFICATIONS

.1 Manufacturer: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.

.2 Installer: Company specializing in performing the work of this section with minimum 3 years documented experience.

## 1.9 REGULATORY REQUIREMENTS

.1 Construct duct work to NFPA 90B standards.

## 1.10 ENVIRONMENTAL REQUIREMENTS

.1 Do not install duct sealants when temperatures are less than those recommended by sealant manufacturers.

.2 Maintain temperatures during and after installation of duct sealants.

## Part 2 Products

### 2.1 MATERIALS

.1 Galvanized Steel Ducts: ASTM A653 galvanized steel sheet, lock-forming quality, having G90 zinc coating of to ASTM A90.

.2 Fasteners: Rivets, bolts, or sheet metal screws.

.3 Sealant:

.1 Manufacturers:

.1 Duro Dyne S-2.

- .2 Foster
- .3 Substitutions: Refer to Section 01 62 00. Not permitted.
- .2 Non-hardening, water resistant, fire resistive, compatible with mating materials; liquid used alone or with tape, or heavy mastic.
- .4 Hanger Rod: ASTM A36; steel, galvanized; threaded both ends, threaded one end, or continuously threaded.

## 2.2 DUCT WORK FABRICATION

- .1 Fabricate and support to SMACNA HVAC Duct Construction Standards - Metal and Flexible, and as indicated. Provide duct material, gauges, reinforcing, and sealing for operating pressures indicated.
- .2 Construct T's, bends, and elbows with radius of not less than 1-1/2 times width of duct on centreline. Where not possible and where rectangular elbows are used, provide air foil turning vanes. Where acoustical lining is indicated, provide turning vanes of perforated metal with glass fibre insulation.
- .3 Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
- .4 Provide standard 45 degree lateral wye takeoffs unless otherwise indicated where 90 degree conical tee connections may be used.

## 2.3 MANUFACTURED DUCT WORK AND FITTINGS

- .1 Manufacture to SMACNA HVAC Duct Construction Standards - Metal and Flexible, and as indicated. Provide duct material, gauges, reinforcing, and sealing for operating pressures indicated.

## 2.4 CASINGS

- .1 Fabricate casings to SMACNA HVAC Duct Construction Standards - Metal and Flexible and construct for operating pressures indicated.
- .2 Mount floor mounted casings on 100 mm high concrete curbs. At floor, rivet panels on 200 mm centres to angles. Where floors are acoustically insulated, provide liner of 1.20 mm galvanized expanded metal mesh supported at 300 mm centres, turned up 300 mm at sides with sheet metal shields.
- .3 Reinforce door frames with steel angles tied to horizontal and vertical plenum supporting angles. Install hinged access doors where indicated or required for access to equipment for cleaning and inspection. Provide clear wire glass observation ports, minimum 150 X 150 mm size.
- .4 Fabricate acoustic casings with reinforcing turned inward. Provide 1.50 mm back facing and 0.80 mm perforated front facing with 2.4 mm diameter holes on 4 mm centres. Construct panels 75 mm thick packed with 72 kg/cu m minimum glass fibre media, on inverted channels of 1.50 mm.

**Part 3 Execution**

**3.1 INSTALLATION**

- .1 Install to manufacturer's instructions.
- .2 Install and seal ducts to SMACNA HVAC Duct Construction Standards - Metal and Flexible.
- .3 Duct Sizes are inside clear dimensions. For lined ducts, maintain sizes inside lining.
- .4 Provide openings in duct work where required to accommodate thermometers and controllers. Provide pilot tube openings where required for testing of systems, complete with metal can with spring device or screw to ensure against air leakage. Where openings are provided in insulated duct work, install insulation material inside a metal ring.
- .5 Locate ducts with sufficient space around equipment to allow normal operating and maintenance activities.
- .6 Use crimp joints with or without bead for joining round duct sizes 200 mm and smaller with crimp in direction of air flow.
- .7 Use double nuts and lock washers on threaded rod supports.
- .8 Connect diffusers or light troffer boots to low pressure ducts directly or with 1.5 m maximum length of flexible duct held in place with strap or clamp.
- .9 Connect flexible ducts to metal ducts with adhesive plus sheet metal screws.
- .10 Set plenum doors 150 to 300 mm above floor. Arrange door swings so that fan static pressure holds door in closed position.
- .11 During construction provide temporary closures of metal or taped polyethylene on open duct work to prevent construction dust from entering duct work system.

**3.2 CLEANING**

- .1 Clean work to 01 78 10.
- .2 Clean duct system and force air at high velocity through duct to remove accumulated dust. To obtain sufficient air, clean half the system at a time. Protect equipment which may be harmed by excessive dirt with temporary filters, or bypass during cleaning.
- .3 Clean duct systems with high power vacuum machines. Protect equipment which may be harmed by excessive dirt with filters, or bypass during cleaning. Provide adequate access into duct work for cleaning purposes.

**3.3 SCHEDULES**

**3.4 DUCT WORK MATERIAL SCHEDULE**

	AIR SYSTEM	MATERIAL
	Low Pressure Supply (Heating Systems)	Steel

	<b>AIR SYSTEM</b>	<b>MATERIAL</b>
	Low Pressure Supply (System with Cooling Coils)	Steel
	Return and Relief	Steel,
	General Exhaust	Steel
	Outside Air Intake	Steel
	Evaporative Condenser Intake and Exhaust	Steel

**3.5 DUCT WORK PRESSURE CLASS SCHEDULE**

	<b>AIR SYSTEM</b>	<b>PRESSURE CLASS</b>
	Supply (Heating Systems)	125 Pa 250 Pa
	Supply (System with Cooling Coils)	125 Pa 250 Pa 500 Pa
	Return and Relief	125 Pa 250 Pa
	General Exhaust	125 Pa 250 Pa
	Outside Air Intake	125 Pa 250 Pa 500 Pa
	Evaporative Condenser	125 Pa
	Intake and Exhaust	250 Pa 500 Pa

**END OF SECTION**

**Part 1            General****1.1            SECTION INCLUDES**

- .1    Air turning devices/extractors.
- .2    Backdraft dampers.
- .3    Combination fire and smoke dampers.
- .4    Duct access doors.
- .5    Duct test holes.
- .6    Fire dampers.
- .7    Flexible duct connections.
- .8    Motorized Control dampers.

**1.2            RELATED SECTIONS**

- .1    Section 01 33 00 - Administrative Requirements.
- .2    Section 01 61 00 - Common Product Requirements.

**1.3            REFERENCES**

- .1    NFPA 90A - Installation of Air Conditioning and Ventilating Systems.
- .2    NFPA 92A - Smoke-Control Systems.
- .3    SMACNA - HVAC Duct Construction Standards - Metal and Flexible.
- .4    UL 33 - Heat Responsive Links for Fire-Protection Service.
- .5    UL 555 - Fire Dampers.
- .6    UL 555S - Smoke Dampers.

**1.4            SUBMITTALS**

- .1    Section 01 33 00: Procedures for submittals.
- .2    Shop Drawings: Indicate for shop fabricated assemblies including volume control dampers duct access doors and duct test holes.
- .3    Product Data: Provide for shop fabricated assemblies including volume control dampers duct access doors duct test holes and hardware used. Include electrical characteristics and connection requirements.

- .4 Manufacturer's Installation Instructions: Indicate for fire dampers and combination fire and smoke dampers.

## 1.5 PROJECT RECORD DOCUMENTS

- .1 Section 01 78 10: Submittals for project closeout.
- .2 Record actual locations of access doors and test holes.

## 1.6 QUALIFICATIONS

- .1 Manufacturer: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.

## 1.7 REGULATORY REQUIREMENTS

- .1 Products Requiring Electrical Connection: Listed and classified by CSA as suitable for the purpose specified and indicated.

## 1.8 DELIVERY, STORAGE, AND HANDLING

- .1 Section 01 61 00: Transport, handle, store, and protect products.
- .2 Protect dampers from damage to operating linkages and blades.

## 1.9 EXTRA MATERIALS

- .1 Section 01 78 10: Submittals for project closeout.
- .2 Provide two of each size and type of fusible link.

## Part 2 Products

### 2.1 BACKDRAFT DAMPERS.

- .1 Manufacturers:
  - .1 Nailor
  - .2 Substitutions: Refer to Section 01 62 00.
- .2 Gravity Backdraft Dampers, Size 450 x 450 mm or Smaller, Provided with Air Moving Equipment: Air moving equipment manufacturers standard construction.
- .3 Multi-Blade, Parallel Action Gravity Balanced Backdraft Dampers: 1.5 mm thick galvanized steel, or extruded aluminum, with centre pivoted blades of maximum 150 mm width, with felt or flexible vinyl sealed edges, linked together in rattle-free manner with 90 degree stop, steel ball bearings, and plated steel pivot pin; adjustment device to permit setting for varying differential static pressure.

### 2.2 COMBINATION FIRE AND SMOKE DAMPERS

- .1 Manufacturers:



- .1 Nailor, EH Price, Ruskin, Metal Fab.
- .2 Substitutions: Refer to Section 01 62 00.
- .2 Fabricate to NFPA 90A, UL 555, UL 555S, and as indicated.
- .3 Provide factory sleeve and collar for each damper.
- .4 Multiple Blade Dampers: Fabricate with 1.5 mm galvanized steel frame and blades, oil-impregnated bronze or stainless steel sleeve bearings and plated steel axles, stainless steel jamb seals, 3.2 x 12.7 mm plated steel concealed linkage, stainless steel closure spring, blade stops, and lock, and 12.7 mm actuator shaft.
- .5 Operators: UL listed and labelled spring return pneumatic type suitable for operation on 0-140 kPa instrument air. electric type suitable for 120 volts, single phase, 60 Hz. Provide end switches to indicate damper position. Locate damper operator on interior exterior of duct and link to damper operating shaft.
- .6 Normally Closed Smoke Responsive Fire Dampers: Curtain type, opening by gravity upon actuation of electro thermal link, flexible stainless steel blade edge seals to provide constant sealing pressure.
- .7 Normally Open Smoke Responsive Fire Dampers: Curtain type, closing upon actuation of electro thermal link, flexible stainless steel blade edge seals to provide constant sealing pressure, stainless steel springs with locking devices to ensure positive closure for units mounted horizontally.
- .8 Electro Thermal Link: Fusible link melting at 74 degrees C; 120 volts, single phase, 60 Hz; UL listed and labeled.

### 2.3 DUCT ACCESS DOORS

- .1 Manufacturers:
  - .1 Acudor, Ruskin
  - .2 Substitutions: Refer to Section 01 62 00.
- .2 Fabricate to SMACNA HVAC Duct Construction Standards - Metal and Flexible, and as indicated.
- .3 Fabrication: Rigid and close-fitting of galvanized steel with sealing gaskets and quick fastening locking devices. For insulated duct work, install minimum 25 mm thick insulation with sheet metal cover.
  - .1 Less Than 300 mm Square: Secure with sash locks.
  - .2 Up to 450 mm Square: Provide two hinges and two sash locks.
  - .3 Up to 600 x 1200 mm: Three hinges and two compression latches with outside and inside handles.
  - .4 Larger Sizes: Provide an additional hinge.
- .4 Access doors with sheet metal screw fasteners are not acceptable.

**2.4 DUCT TEST HOLES**

- .1 Temporary Test Holes: Cut or drill in ducts as required. Cap with neat patches, neoprene plugs, threaded plugs, or threaded or twist-on metal caps.

**2.5 FIRE DAMPERS**

- .1 Manufacturers:
  - .1 Nailor, EH Price, Ruskin, Metal Fab Model Type A or B
  - .2 Substitutions: Refer to Section 01 62 00.
- .2 Fabricate to NFPA 90A and UL 555, and as indicated.
- .3 Dynamic Fire dampers as per UL 555.
- .4 Ceiling Dampers: Galvanized steel, 0.76 mm frame and 1.5 mm flap, two layers 3.2 mm ceramic fibre on top side , and one layer on bottom side for round flaps, with locking clip.
- .5 Horizontal Dampers: Galvanized steel, 0.76 mm frame, stainless steel closure spring, and lightweight, heat retardant non-asbestos fabric blanket.
- .6 Curtain Type Dampers: Galvanized steel with interlocking blades. Provide stainless steel closure springs and latches for horizontal installations closure under air flow conditions. Configure with blades out of air stream except for 250 Pa pressure class ducts up to 300 mm in height.
- .7 Multiple Blade Dampers: 1.5 mm galvanized steel frame and blades, oil-impregnated bronze or stainless steel sleeve bearings and plated steel axles, 3.2 x 12.7 mm plated steel concealed linkage, stainless steel closure spring, blade stops, and lock.
- .8 Fusible Links: UL 33, separate at 71 degrees C with adjustable link straps for combination fire/balancing dampers.

**2.6 FLEXIBLE DUCT CONNECTIONS**

- .1 Manufacturers:
  - .1 Flexmaster
  - .2 Substitutions: Refer to Section 01 62 00.
- .2 Fabricate to SMACNA HVAC Duct Construction Standards - Metal and Flexible, and as indicated.
- .3 Connector: Fabric crimped into metal edging strip.
  - .1 Fabric: UL listed fire-retardant neoprene coated woven glass fibre fabric to NFPA 90A, minimum density 1.0 kg/sq m.
  - .2 Net Fabric Width: Approximately 50 75 150 mm wide.
  - .3 Metal: 75 mm wide, 0.6 mm thick galvanized steel .
- .4 Leaded Vinyl Sheet: Minimum 14 mm thick, 4.2 kg/sq m, 10 dB attenuation in 10 to 10,000 Hz range.

**2.7 MOTORIZED CONTROL DAMPERS**

- .1 Manufacturers:
  - .1 Tamco Series 1000/Belimo
  - .2 Substitutions: Refer to Section 01 62 00.
- .2 Aluminum air foil control damper.
- .3 Flanged to duct.
- .4 With Belimo actuator, NFBUP/NFXUP sized to match damper.
- .5 Sized to match internal dimensions of duct.

**Part 3 Execution****3.1 PREPARATION**

- .1 Verify that electric power is available and of the correct characteristics.

**3.2 INSTALLATION**

- .1 Install accessories to manufacturer's instructions, NFPA 90A, and follow SMACNA HVAC Duct Construction Standards - Metal and Flexible. Refer to Section 23 31 00 for duct construction and pressure class.
- .2 Provide backdraft dampers on exhaust fans or exhaust ducts nearest to outside and where indicated.
- .3 Provide duct access doors for inspection and cleaning before and after filters, coils, fans, automatic dampers, at fire dampers, combination fire and smoke dampers, and elsewhere as indicated. Provide minimum 200 x 200 mm size for hand access, 450 x 450 mm size for shoulder access, and as indicated. Provide 100 x 100 mm for balancing dampers only. Review locations prior to fabrication.
- .4 Provide duct test holes where indicated and required for testing and balancing purposes.
- .5 Provide fire dampers , combination fire and smoke dampers and smoke dampers at locations indicated, where ducts and outlets pass through fire rated components , and where required by authorities having jurisdiction. Install with required perimeter mounting angles, sleeves, breakaway duct connections, corrosion resistant springs, bearings, bushings and hinges.
- .6 Install smoke dampers and combination smoke and fire dampers to NFPA 92A.
- .7 Demonstrate re-setting of fire dampers to Owner's representative.
- .8 Provide flexible connections immediately adjacent to equipment in ducts associated with fans and motorized equipment , and supported by vibration isolators. Refer to Section 23 05 48. For fans developing static pressures of 1250 Pa and over, cover connections with leaded vinyl sheet, held in place with metal straps.

- .9 Use splitter dampers only where indicated.
- .10 Provide balancing dampers on high velocity systems where indicated. Refer to Section 23 36 00.
- .11 Provide balancing dampers on duct take-off to diffusers, grilles, and registers, regardless of whether dampers are specified as part of the diffuser, grille, or register assembly.

**END OF SECTION**

**Part 1            General**

**1.1                SECTION INCLUDES**

- .1        Diffusers.
- .2        Registers/grilles.

**1.2                RELATED SECTIONS**

- .1        Section 01 33 00 - Administrative Requirements.
- .2        Section 01 61 00 - Common Product Requirements.

**1.3                REFERENCES**

- .1        ADC 1062 - Air Distribution and Control Device Test Code.
- .2        AMCA 500 - Method of Testing Louvres for Ratings.
- .3        AMCA 5000 - Method of Testing Dampers for Ratings.
- .4        ARI 650 - Air Outlets and Inlets.
- .5        ASHRAE 70 - Method of Testing for Rating the Performance of Outlets and Inlets.
- .6        SMACNA - HVAC Duct Construction Standard - Metal and Flexible.
- .7        NFPA 90A - Installation of Air Conditioning and Ventilating Systems.

**1.4                SUBMITTALS**

- .1        Section 01 33 00: Procedures for submittals.
- .2        Product Data: Provide data for equipment required for this project. Review outlets and inlets as to size, finish, and type of mounting prior to submission. Submit schedule of outlets and inlets showing type, size, location, application, and noise level.
- .3        Samples: Submit two of each required air outlet and inlet type.

**1.5                PROJECT RECORD DOCUMENTS**

- .1        Section 01 78 10: Submittals for project closeout.
- .2        Record actual locations of air outlets and inlets.

**1.6                QUALITY ASSURANCE**

- .1        Test and rate air outlet and inlet performance to ADC Equipment Test Code 1062 and ASHRAE 70.

- .2 Test and rate louvre performance to AMCA 500.

### 1.7 QUALIFICATIONS

- .1 Manufacturer: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.

### Part 2 Products

- .1 EH Price.

### 2.2 GOOSENECKS

- .1 Fabricate to SMACNA HVAC Duct Construction Standards - Metal and Flexible, of minimum 1.20 mm galvanized steel.
- .2 Mount on minimum 300 mm high curb base where size exceeds 230 x 230 mm. .

### Part 3 Execution

#### 3.1 INSTALLATION

- .1 Install to manufacturer's instructions.
- .2 Check location of outlets and inlets and make necessary adjustments in position to conform with architectural features, symmetry, and lighting arrangement.
- .3 Install diffusers to duct work with air tight connection.
- .4 Provide balancing dampers on duct take-off to diffusers, and grilles and registers, despite whether dampers are specified as part of the diffuser, or grille and register assembly.
- .5 Paint ductwork visible behind air outlets and inlets matte black. Refer to Section 09 91 10.

**END OF SECTION**

**Part 1 General****1.1 REFERENCES**

- .1 Sheet Metal and Air Conditioning Contractors National Association (SMACNA)
- .2 Underwriters' Laboratories of Canada (ULC)

**1.2 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for chimneys and stacks and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
  - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Territory of Nunavut, Canada.
  - .2 Indicate following:
    - .1 Methods of sealing sections.
    - .2 Methods of expansion.
    - .3 Details of thimbles.
    - .4 Bases/Foundations.
    - .5 Supports.
    - .6 Guy details.
    - .7 Rain caps.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

**1.3 QUALITY ASSURANCE**

- .1 Regulatory Requirements: work to be performed in compliance with latest versions of CSA B139 and applicable Provincial/Territorial regulations.
- .2 Certifications:
  - .1 Catalogued or published ratings: obtained from tests carried out by independent testing agency or manufacturer signifying adherence to codes and standards.

**1.4 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:

- .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
- .2 Store and protect chimneys and stacks from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.

## **Part 2 Products**

### **2.1 CHIMNEY AND BREECHING AND VENT**

- .1 Provide Type L venting for the boiler. Provide barometric damper for breeching.

### **2.2 ACCESSORIES**

- .1 Hangers and supports: in accordance with recommendations by SMACNA and L-vent manufacturer.
- .2 Stainless steel flashing, storm collar, and rain cap. All piping above the roofline to be stainless steel jacketed.
- .3 Expansion sleeves with heat resistant caulking, held in place as indicated.
- .4 Firestop, trim collar, attic insulation shield, roof supports: in accordance with recommendations by SMACNA and L-vent manufacturer.

## **Part 3 Execution**

### **3.1 EXAMINATION**

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for chimney and stack installation in accordance with manufacturer's written instructions.
  - .1 Visually inspect substrate in presence of Consultant.
  - .2 Inform Consultant of unacceptable conditions immediately upon discovery.
  - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Consultant.

### **3.2 INSTALLATION - GENERAL**

- .1 Follow manufacturer's and SMACNA installation recommendations for shop fabricated components.
- .2 Suspend breeching at 1.5 m centres and at each joint.
- .3 Support chimneys at bottom, roof and intermediate levels as indicated.
- .4 Install thimbles/firestops where penetrating roof, floor, ceiling and where breeching enters masonry chimney. Pack annular space with heat resistant caulking as recommended by manufacturer.
- .5 Install flashings on chimneys penetrating roofs, as indicated.
- .6 Install rain caps and cleanouts, as indicated.



**3.3 CLEANING**

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

**END OF SECTION**

**Part 1            General**

**1.1                SECTION INCLUDES**

- .1      Forced air furnaces.
- .2      Thermostats.

**1.2                RELATED SECTIONS**

- .1      Section 01 33 00 - Administrative Requirements.
- .2      Section 01 61 00 - Common Product Requirements.
- .3      Section 01 78 10 - Execution Requirements.
- .4      Section 23 05 13 - Motors: Evaporator and condenser fan motors.
- .5      Section 23 05 48 - Vibration Isolation.
- .6      Section 23 07 13 - Duct Insulation: Duct Liner.
- .7      Section 23 40 00 - Air Cleaning Devices.
- .8      Section 25 50 01 - Analog Control Equipment: 25 50 02 - Digital Control Equipment: Thermostats, humidistats, time clocks.
- .9      Section 26 05 80 - Equipment Wiring: Electrical characteristics and wiring connections and installation and wiring of thermostats and other controls components.

**1.3                REFERENCES**

- .1      ARI 210/240 - Unitary Air-Conditioning and Air-Source Heat Pump Equipment.
- .2      ARI 270 - Sound Rating of Outdoor Unitary Equipment.
- .3      ARI 520 - Positive Displacement Condensing Units.
- .4      ARI 610 - Central System Humidifiers for Residential Applications.
- .5      ASHRAE 14 - Methods of Testing for Rating Positive Displacement Condensing Units.
- .6      ASHRAE 15 - Safety Standard for Refrigeration Systems.
- .7      ASHRAE 52 - Method of Testing Air Cleaning Devices Used in General Ventilation for Removing Particulate Matter.
- .8      ASHRAE 90A - Energy Conservation in New Building Design.
- .9      ASHRAE 103 - Method of Testing for Annual Fuel Utilization Efficiency of Residential Central Furnaces and Boilers.

- .10 NFPA 31 - Installation of Oil-Burning Equipment.
- .11 NFPA 54 (AGA Z223.1) - National Fuel Gas Code.
- .12 NFPA 90A - Installation of Air Conditioning and Ventilating Systems.
- .13 NFPA 90B - Installation of Warm Air Heating and Air-Conditioning Systems.
- .14 NFPA 211 - Chimneys, Fireplaces, Vents, and Solid Fuel Burning Appliances.
- .15 UL 207 - Refrigerant-Containing Components and Accessories, Non-electrical.
- .16 UL 303 - Refrigeration and Air-Conditioning Condensing and Compressor Units.
- .17 UL 727 - Oil-Fired Central Furnaces.
- .18 UL 729 - Oil-Fired Floor Furnaces.

**1.4 SUBMITTALS FOR REVIEW**

- .1 Section 01 33 00: Procedures for submittals.
- .2 Product Data: Provide rated capacities, weights, accessories, electrical nameplate data, and wiring diagrams.
- .3 Shop Drawings: Indicate assembly, required clearances, and location and size of field connections.

**1.5 SUBMITTALS FOR INFORMATION**

- .1 Section 01 33 00: Procedures for submittals.
- .2 Design Data: Indicate refrigerant pipe sizing.
- .3 Manufacturer's Instructions: Indicate rigging, assembly, and installation instructions.

**1.6 SUBMITTALS AT PROJECT CLOSEOUT**

- .1 Section 01 78 10: Submittals for project closeout.
- .2 Project Record Documents: Record actual locations of components and connections.
- .3 Operation and Maintenance Data: Include manufacturer's descriptive literature, operating instructions, installation instructions, maintenance and repair data, and parts listing.
- .4 Warranty: Submit manufacturers warranty and ensure forms have been filled out in Owners name and registered with manufacturer.

**1.7 QUALITY ASSURANCE**

- .1 Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.

- .2 Installer Qualifications: Company specializing in performing the work of this section with minimum three years documented experience.

### **1.8 REGULATORY REQUIREMENTS**

- .1 Products Requiring Electrical Connection: Listed and classified by CSA as suitable for the purpose specified and indicated.

### **1.9 WARRANTY**

- .1 Section 01 78 10: Submittals for project closeout.
- .2 Provide ten year manufacturer's warranty for heat exchangers.
- .3 Provide three year manufacturer's warranty for solid state ignition modules.
- .4 Provide five year manufacturer's warranty for condensing units and compressors.

### **1.10 EXTRA MATERIALS**

- .1 Section 01 78 10: Submittals for project closeout.
- .2 Substitutions: Refer to Section 01 62 00.

## **Part 2 Products**

### **2.1 OIL FIRED FURNACES, F-1**

- .1 Manufacturer: Olsen Model UML.
  - .1 Substitutions: Refer to Section 01 62 00.
  - .2 Units: Self-contained, packaged, factory assembled, pre-wired unit consisting of cabinet, supply fan, heating element, controls, air filter, humidifier, and accessories; wired for single power connection with control transformer.
    - .1 Air Flow Configuration: Upflow, Downflow, Horizontal.
    - .2 Heating: Oil fired, No. 2 oil.
  - .3 Cabinet: Steel with baked enamel finish, easily removed and secured access doors, glass fibre insulation and reflective liner and welded steel base.
  - .4 Supply Fan: Centrifugal type rubber mounted with direct or belt drive, adjustable variable pitch motor pulley.
  - .5 Motor: Refer to Section 23 05 13; 1750 rpm ECM, permanently lubricated.
  - .6 Combustion Chamber: welded stainless steel with precast refractory.
  - .7 Oil Burner: High pressure atomizing type, rubber mounted, adjustable combustion air blower, integrated fuel pump, hinged flame inspection port, cadmium sulphide flame sensor, electrodes, ignition transformer, oil nozzle. Four firing rates.

- .1 Barometric draft regulator in flue.
- .2 Non-corrosive combustion air blower with permanently lubricated motor.
- .8 Oil Burner Safety Controls:
  - .1 Time delay relay limits time for establishment of main flame.
  - .2 Flame sensor monitors flame continuously during burner operation and stops burner on flame failure with manual reset.
  - .3 Solenoid operated oil delay valve opens after burner motor is energized and closes instantly when burner motor is de-energized.
  - .4 Limit Control: Fixed stop at maximum permissible setting, de-energizes burner on excessive bonnet temperature, automatic resets.
- .9 Burner Operating Controls
  - .1 Room Thermostat: Cycles burner to maintain room temperature setting.
  - .2 Supply Fan Control: Energize from bonnet temperature independent of burner controls, with fixed timed on delay, with manual switch for continuous fan operation. Provide continuous low speed fan operation.
- .10 Air Filters: 1 inch urethane, washable type arranged for easy replacement.
- .11 Performance:
  - .1 Ratings: Energy Efficiency Rating (EER) not less than requirements of ASHRAE 90A; seasonal efficiency to ASHRAE 103.
  - .2 Air Handling:
    - .1 Air flow: 1200 cfm.
    - .2 External static pressure: 0.4 inch wg.
    - .3 ECM motor.
  - .3 Heating Capacity:
    - .1 Heating output: 76,000 – 99,000Btuh.
    - .2 Heating input: 0.65-0.85 gph No. 2 oil.
    - .3 Annual fuel utilization efficiency (AFUE): 84-87 percent.

## 2.2 THERMOSTATS

- .1 Manufacturer: Honeywell Model 6025 RiteTemp Universal 7 Day Programmable Thermostat.
  - .1 Other acceptable manufacturers offering equivalent products.
    - .1 Trane.
    - .2 Carrier.
  - .2 Substitutions: Refer to Section 01 62 00.
- .2 Adjustable Room Thermostat: Low voltage, to control burner operation, heater stages in sequence with delay between stages, and supply fan to maintain temperature setting. Include system selector switch (heat-off-cool) and fan control switch (auto-on).
- .3 Electric solid state microcomputer based room thermostat with remote sensor:

- .1 Automatic switching from heating to cooling.
- .2 Preferential rate control to minimize overshoot and deviation from setpoint.
- .3 Set-up for four separate temperatures per day.
- .4 Instant override of setpoint for continuous or timed period from one hour to 31 days.
- .5 Short cycle protection.
- .6 Programming based on every day of the week.
- .7 Selection features including degree F or degree C display, 12 or 24 hour clock, keyboard disable, remote sensor, fan on-auto.
- .8 Battery replacement without program loss.
- .9 Thermostat display:
  - .1 Time of day.
  - .2 Actual room temperature.
  - .3 Programmed temperature.
  - .4 Programmed time.
  - .5 Duration of timed override.
  - .6 Day of week.
  - .7 System mode indication: heating, auto, off, fan auto, fan on.

### **Part 3 Execution**

#### **3.1 EXAMINATION**

- .1 Section 01 10 13: Verification of existing conditions before starting work.
- .2 Verify that floors are ready for installation of units and openings are as indicated on shop drawings.
- .3 Verify that proper power supply is available for furnace.
- .4 Verify that proper fuel supply is available for connection.

#### **3.2 INSTALLATION**

- .1 Install to CSA B139.2 2015.
- .2 Mount counterflow furnaces installed on combustible floors on additive base or as per manufacturer's instructions.

**END OF SECTION**