

**Pedestal Upgrade -Canadian Coast Guard (CCG) – Southside Base (SSB), St. John’s, NL  
F6879-189232/A**

**AMENDMENT # 1  
ADDENDUM #1**

\*\*\*\*\*  
THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.  
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.  
\*\*\*\*\*

**ADDENDUM NO. 1**

**DRAWINGS**

1. Reference Drawing 01N1001A522E02 Electrical Power Pedestal Modifications
  - .1 Revise Note 17 as follows: New Eaton 400A, 600V, 3P Nema 4x, 316 stainless steel enclosed circuit breaker
  - .2 Revise Note 18 as follows: New Eaton 800A, 600V, 3P Nema 4x, 316 stainless steel enclosed circuit breaker.
  
2. Reference Drawing 01N1001A522E03 Electrical Power Pedestal Modifications
  - .1 Revise Note 5 as follows: New Eaton 400A, 600V, 3P Nema 4x, 316 stainless steel enclosed circuit breaker
  
3. Reference Drawing 01N1001A522E04 Electrical Riser Diagrams
  - .1 Pedestal #4: 400A double throw switch is existing
  - .2 Pedestal #6: New 600V, 400A disconnect to be revised to new 600V 400A enclosed circuit breaker
  - .3 Pedestal #7: 600V, 60A enclosed circuit breaker is existing

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

**All other terms & conditions remain unchanged.**

\*\*\*\*\*