



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC

1550, Avenue d'Estimauville

1550, D'Estimauville Avenue

Québec

Québec

G1J 0C7

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

TPSGC-PWGSC

601-1550, Avenue d'Estimauville

Québec

Québec

G1J 0C7

Title - Sujet Réfection brise-lames nord	
Solicitation No. - N° de l'invitation EE517-192500/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2019-04-02
GETS Reference No. - N° de référence de SEAG PW-\$QCM-017-17638	
File No. - N° de dossier QCM-8-41238 (017)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-04-16	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Cloutier, Annabelle	Buyer Id - Id de l'acheteur qcm017
Telephone No. - N° de téléphone (418) 649-2768 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Repair of northern breakwater – Port of Gros Cacouna Port of Gros Cacouna, Cacouna

Amendment 002

Included in the present amendment:

1. Solicitation closing date extension
2. Questions and answers 2 to 9

SOLICITATION CLOSING DATE EXTENSION

Solicitation closing date is postponed from April 8, 2019 to **April 16, 2019**.

QUESTIONS AND ANSWERS

Question 2

The consulted laboratory services are of the opinion that it is impossible to obtain a sandstone with a density of 2.75. Can you accept the sandstone present at the site according to the criteria already established in the specifications for other sandstones, i.e. a density of 2.65 to 2.85?

Answer: The sandstone present on site that does not meet the requirements of the tender documents is not accepted.

Question 3

Is there a power line near the area authorized to the contractor? If yes, can this line be used to power the construction facilities?

Answer: No.

Question 4

Item 3 – Toes formation and levelling

Can you provide your definition for the toes or provide a typical cross-section?

Answer: The term “toe” for this project corresponds to the perimeter of the areas to repair, i.e. the junction of the new armour stone with the existing armour stone. The toe has no other requirements than those already in the tender documents.

Question 5

Item 3 – Toes formation and levelling

Is the levelling to ensure a minimum of 1,3m of new armour stones?

Answer: A layer of 1,3m of new armour stone must be placed after levelling the existing armour stones. The requirements are specified in the tender documents, including tolerances for stone placement.

Question 6

Item 3 – Toes formation and levelling

Is the stone removed during levelling to be recovered and reintroduced into the new stone? If no, should we plan the disposing of the stone?

Answer: The existing armour stone remains in the areas to repair.

Question 7

We would like to visit the site. Is the road accessible at this time of the year (cleared of snow, opened gate)?

Answer: From the access gate, access to the Port of Gros-Cacouna is only possible with an authorization. The gate leading to the authorized access road toward the northern breakwater can be opened as needed. This access road is not cleared of snow. Bidders must provide equipment for access (snowshoes or other).

If necessary, bidders may access the site during the week of April 8 to 12, 2019. They must make an appointment with the Port Director at least 24 hours in advance.

M. Louis D'Amours
Office : 418-867-1784
Cell. : 418-868-9920

Question 8

Is sandstone an accepted stone?

Answer: Only the sandstone present at the site and which meets all the requirements of the tender documents is accepted.

Question 9

Section 3.3.1 of section 35 31 25 of the specifications states that a temporary haul road on the ridge of the breakwater may be considered, but there shall be no contamination of the stone of the Work with non-compliant materials. Is the non-compliance of the materials related to the fact that the stone used for the haul road must be clean so as not to contaminate the breakwater with sediment or that the stone for the haul road must respect the set of criteria of the armour stone of section 35 31 24 of the specification documents?

Answer: Both: the tender documents stipulate the requirements as to the conformity of the materials used and the conformity of the placement of the armour stone.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.