



Procurement Hub – Ottawa Office,
Station 9N089A, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

Tuesday, April 9, 2019

ADDENDUM NO. 2

Subject: ITT Invitation to Tender No. FP802-190027

Title: Iqaluit Rigging work.

Location: Coast Guard Iqaluit Marine Communication and Traffic Services (MCTS) Receiver (Rx) Site in Iqaluit, NU. The coordinates for the site are: 63°46'9.73"N, 68°31'48.73"W.

Closing Date: Tuesday, April 30, 2019 @ 2:00 PM (EDT)

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum #2** is to advise potential bidders of the following changes to this tender call and/or answers to Bidders questions received to date:

In addition, please see below the updated bid closing date.

To Delete:

Thursday, April 11, 2019 at 2:00 PM (EDT)

To Add updated Bid closing date:

Tuesday, April 30, 2019 @ 2:00 PM (EDT)

Question #1:

Are we allowed to use Split 6" conduits for repair or have to use identical conduits same as existing PVC?

Answer # 1:

Split 6" conduit is acceptable for repairs provided it has holes drilled for drainage.



Question #2:

Will All removed materials be scraped or Can we leave them at CCG center?

Answer # 2:

All waste material is to be disposed of in a legal manner at a site approved by local authorities

Question #3:

How long the service down time we are allowed to work on this project?

Answer # 3:

Service interruptions will be granted as needed and a maximum of two days per antenna will be allowed.

All other terms and conditions remain unchanged.

Yours truly,

Ginette Aliaga

Procurement and Contracting Officer
Procurement Hub, Materiel and Procurement Services
Fisheries and Oceans Canada
200 Kent Street, 9N089A
Ottawa, ON, K1A 0E6
Email: Ginette.Aliaga@dfo-mpo.gc.ca