



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Place Bonaventure, portail Sud-Oue

800, rue de La Gauchetière Ouest

7^e étage, suite 7300

Montréal

Québec

H5A 1L6

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada

Place Bonaventure, portail Sud-Oue

800, rue de La Gauchetière Ouest

7^e étage, suite 7300

Montréal

Québec

H5A 1L6

Title - Sujet Achat et instal. mobilier de bureau	
Solicitation No. - N° de l'invitation EF970-192988/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EF970-192988	Date 2019-04-15
GETS Reference No. - N° de référence de SEAG PW-SMTA-160-15291	
File No. - N° de dossier MTA-8-41405 (160)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-05-10	
Time Zone Fuseau horaire Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Asquino, Carolina	Buyer Id - Id de l'acheteur mta160
Telephone No. - N° de téléphone (514) 348-4129 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

AMENDMENT 001

This amendment is raised to respond to questions received to date on April 15, 2019, and modify Annex A and the plans accordingly. The tender closing date is now Friday, May 10, 2019 at 2 pm

Questions & answers:

Q1. Ergonomic accessories: I do not see ergonomic accessory, please let me know if we need to include it in our presentation. (Monitor arm, keyboard tray)

A1. Those accessories will be purchased separately by the owner but installed by the Contractor of the present contract, see notes on F161.

Q2. Pivoting power data module: Re: 2.7.5. What is the purpose of the pivoting power data module? Our module is in a fixed easily accessible location, is this acceptable?

A2. No, the purpose of the pivoting power data module is to offer more flexibility. See picture below for the design intent.

Please note that the picture is not representative of the number of outlets required.



Q3. Edge finish: Re: 2.7.6.1. Would a 3mm PVC edge be acceptable? (instead of ABS (acrylonitrile butadiene styrene))

A3. Edges can be finished in PVC unless this installation requires the use of adhesives or sealants producing VOC's.

Q4. HPL versus LPL for credenzas: Re: 2.7.8.3. Typically, credenzas at work surface or surface supporting height have only the surface in HPL with doors and chassis in LPL. Will this be acceptable?

A4. Yes, for credenzas, it would be acceptable to have the horizontal top surface in HPL and vertical surfaces for doors and chassis in LPL.

Q5. Outlets for telecom: For the dividing panels, standard size outlets for telecommunication options are provided however the actual module is to be provided by the telecom provider. Please advise this is acceptable.

A5. The telecom module to be provided by others will be a standard size so yes, provide standard size outlets for telecom.

Q6. Number and type of outlets: Can you please get me the number and type of required outlets, plan E06 (electricity) and TI03/TI05 (telecommunication), issued for information.

A6. In your tender proposal, please include the following for every open workstation:

- Electrical: 2 duplex outlets
- Data : 1 double outlets

Q7. Material: On the CAD plans, on page 2, in the SPECIFIC NOTES (point # 3, 4 & 5), is it possible to have those storage units in a combination of metal and plastic laminate instead of exclusively plastic laminate? Considering that metal is more environmentally friendly.

Remark: Notes #3, 4 & 5 relate to credenzas, wardrobes and mobile pedestals.

A7. The design intent is to have a plastic laminate finish for the visible surfaces of storage units, so top, sides and front. It could be possible to have metal for the frame or for elements within the storage units (so not visible).

New drawings issued:

Sheet F160 – Plan d'ameublement / Furniture plan

Sheet A160 is reissued and revised with annotations in red. It is in the attached documents section of this tender.

Modifications to Annex A:

Under article 2.7 "DESKS"

Delete: the following paragraph at 2.7.5:

« Provide pivoting power data modules mounted on desk surfaces, identified as "7" in the plans »

Insert: « Provide pivoting power data modules mounted on desk surfaces, including two (2) electrical outlets and one (1) USB outlet but no data outlet, identified as "7" in the plans »

Under article 2.7.15 Conference tables

Delete: paragraph 2.7.15.4:

“Provide a power and communication module on each work surface. Provide ties for wiring management under work surfaces. “Tie wrap” ties are not acceptable”

Insert: “Provide a power module on each work surface. Provide ties for wiring management under work surfaces. “Tie wrap” ties are not acceptable”

Modifications to drawings:

Sheet F161 – Mobilier de bureau - details / Furniture details

Delete: In the NOTES SPÉCIFIQUES / SPECIFIC NOTES the following note #10:

« COMPTOIRS:
COPIE/IMPR 4.35.05.04 : 2362mm L X 610mm P x 914mm H
COPIE/IMPR 4.35.22 : 2743mm L X 610mm P X 914mm H »

Insert: « COMPTOIRS:

COPIE/IMPR 4.35.05.04 : 2362mm L X 610mm P x **762mm H**
COPIE/IMPR 4.35.22 : 2743mm L X 610mm P X **762mm H** »

Sheet F160 – Plan de mobilier et accessoires / Furniture and accessories plan

Strip of filing cabinets along wall of room #4.35.10:

Those 4 filing cabinets are presently identified F2b.

Modification: The lowest filing cabinet becomes type F2a and the other 3 remain type F2b.

Strip of filing cabinets along exit staircase wall (near gridlines 4A):

Those 2 filing cabinets are presently identified F2b.

Modification: Those 2 filing cabinets become type F2a.

In the LÉGENDE GRAPHIQUE AMEUBLEMENT / GRAPHIC FURNITURE LEGEND :
TABLES DE CONFÉRENCE / CONFERENCE ROOM TABLES

Delete: the description of T1c:

« T1c : 762mm x 1524mm X 737mm H
IN ROOM 4.35.11 (MEETING RM) AND #4.35.14 (VIDEOCONF.)
FLIP TOP ELECTRIFIED CONFERENCE TABLE IN WHITE PLASTIC LAMINATE”

Insert: « T1c : 762mm x 1524mm X 737mm H

IN ROOM 4.35.11 (MEETING RM) AND #4.35.14 (VIDEOCONF.)
FLIP TOP CONFERENCE TABLE IN WHITE PLASTIC LAMINATE”

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.