

JOB No. 90615

C7/195

PRESSURE TRANSMITTER CALIBRATION - SURGE
PROTECTION (FOLLOWING WORKS TEST)

INLET TEMP °C	MAX TGV POSITION DEGREES	SURGE PRESS	
		KPA-ABS	KPA-G
18.93	-10	175	73.7
0	4.13	181.5	80.2
-20	19.01	187.7	86.4
-40	34	194	92.7

