

**ADDENDUM NUMBER:** TWO (02)

**ADDENDUM DATE:** April 05, 2019

**ISSUED BY:** SEPW Architecture Inc.  
102 – 3718 Kinnear Place, SK. S7P 0A6  
PH. (306) 652-6457

**PROJECT:** New Police Building and Residence  
Pelican Narrows, Saskatchewan

This Addendum forms part of the Contract Documents and amends the original Drawings and Specifications dated 2018-10-19, previous Addenda if applicable and as noted below. This Addendum consists of 2 pages.

Ensure that all parties are aware of all items included in this Addendum.

**The following revised or additional Drawings and Specifications accompany and form an integral part of this Addendum:**

Dwg. No.	Title	Date of Issue
Spec. Section No.		

**ARCHITECTURAL**

**A-2-1 ARCHITECTURAL REQUESTS FOR EQUALS**

- Suppliers of approved products are responsible to ensure that the following approved equals fully meet the requirements of the specifications, and that the approved equals do not diminish both the grade of product and appearance to those products specified. The following manufacturers and products listed shall be considered as approved equals to the specified products:

Specification	Specified Product	Approved Equivalent
07 11 13	Carlisle, CCW MiraDrain 6000; Delta Drain	Mel-Drain 5035 by W. R. Meadows
07 21 13	Cavityrock by Roxul	Owens Corning Thermafiber Rainbarrier 45 Insulation
07 27 00	Stego Wrap Vapour Barrier 15min by Stego Industries	Perminator 15 by W. R. Meadows
07 27 00	Henry Company: Bakor Blueskin VP 160	IKO AquaBarrier VP
07 27 00	Henry Company: Bakor Blueskin SA	IKO Aqua Barrier AVB
07 46 13	Cascadia Clip Thermal Spacer System by Cascadia Windows	EA T-Clip and Girt by Engineered Assemblies

07 52 00	Soprema: Soprasmart Board 180	IKO Protectobase 180
09 67 00	Sikafloor Quartzite Boradcast System by Sika; Stonsheild SLT by Stonhard	BASF Mastertop 1234
10 51 13	Police and Crew Series, Double Door Locker by Shanahan's	Hadrian Divided Police Locker Series
10 51 13	Movable Pedestal Locker Room Benches by Shanahan's	Hadrian Hardwood Laminate Pedestal Benches
12 49 00	Hunter Douglas Designer Dual Roller Shade FR	Solarflective Teleshade System

**A-2-2 REF. SPECIFICATION 06 40 00 – ARCHITECTURAL WOODWORK**

1. **Revise:** Article 2.3.1.6.2 to read “*Thermofused Melamine: Panolam W256 Country Maple Satin Texture.*”.
2. **Revise:** Article 2.3.2.5.2 to read “*Thermofused Melamine: Panolam W256 Country Maple Satin Texture.*”.

**A-2-3 REF. SPECIFICATION 08 80 50 – GLAZING**

1. **Revise:** Article 2.8.5.1 to read “*Model 45-115-01-SD1 available from Securingcosmos.com.*”.
2. **Revise:** Article 2.9.1 to read “*Refer to section 10 90 00 article 2.3.*”.

**A-2-4 REF. SPECIFICATION 09 67 00 – FLUID-APPLIED FLOORING**

1. **Add:** Article 2.1.10.3 to read “*Or approved equivalent.*”.

**A-2-5 REF. SPECIFICATION 10 90 00 – MISCELLANEOUS SPECIALTIES**

2. **Revise:** Article 2.3.2 to read “*Base material: 3mm polycarbonate.*”.

**ELECTRICAL**

**E-2-1 REF. DRAWING E3.1 – MAIN FLOOR PLAN POWER & SYSTEMS PLAN**

1. Drawing note 17: The reference to ‘E1.1’ is incorrect; the note should refer to ‘A1.1’.
2. Drawing note 17: Delete the requirement for a key-switch on the exterior overhead door operator pedestal. PTSS will mount OPEN and CLOSE card readers on Batko Housing at the pedestal.

**E-2-2 REF. DRAWING E8.5 – CCTV – ALARM SYSTEMS AND ACCESS CONTROL CONDUIT SITE PLAN**

1. Detail 3: Delete the OPEN and CLOSE card readers (Device 61) and all associated conduit from the Exterior Overhead Door Operator Pedestal for the overhead door at Garage 168.

**END OF ADDENDUM NO. 02**