



RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Groupe de la réception des soumissions

Procurement & Contracting Services / Services d'acquisitions et des marchés.

RCMP-GRC
Bid Receiving/Réception des soumissions
Attn: Suparna Sarker
73 Leikin Drive/promenade Leikin,
Mailstop/ arrêt postal # 15
Ottawa, ON K1A 0R2

Telephone No./no de téléphone: (613) 843-5904

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté l Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone: ()

Facsimile No. – No de télécopieur: ()

Title-Sujet Construction – RCMP Detachment & Housing Pelican Narrows		
Solicitation No. – No. de l'invitation 201903938	Amend. – Modif. No. :2	Date April 15 , 2019
Client Reference No. - No. de Référence du Client 201903938		
GETS Reference No. – No de Référence du SEAG PW-19-00867392		
Solicitation Closes – L'invitation prend fin at – à 2:00 P.M EDT (Eastern Daylight Time) on – May 3, 2019		
F.O.B. - F.A.B. Destination		
Address Enquiries to: - Adresser toute questions à : Suparna.sarker@rcmp-grc.gc.ca		
Telephone No. - No de telephone 613-843-6380	Fax: 613-825-0082	
Destination of Goods - Destinations des biens: See Herein		
Instructions : See Herein / Voir aux présentes		
Delivery Required – Livraison exigée: See Herein		
Name and Title of person authorized to sign on behalf of Vendor/Firm. Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		



Solicitation Amendment: 002

This solicitation amendment has been raised to:

Part 1: Address Changes and Addendums

Part 2: Respond to questions submitted

PART 1 – CHANGES & ADDENDUMS

CHANGE 1:

At the Tender Notice, Date closing:

Delete: 2019/04/23 14:00 Eastern Daylight Time (EDT)

Insert: 2019/05/03 14:00 Eastern Daylight Time (EDT)

CHANGE 2:

At Approval of Alternative Materials on p.2 of the RFP:

Delete: in its entirety

Insert:

APPROVAL OF ALTERNATIVE MATERIALS

In accordance with R2710T (2018-06-21), GI13 Approval of Alternative Materials, when materials are specified by trade names or trademarks, or by manufacturers' or suppliers' names, the bid shall be based on use of the named materials. During the solicitation period, alternative materials may be considered provided full technical data is received in writing by the Contracting Officer **by end of day April 12, 2019**. If the alternative materials are approved for the purposes of the bid, an addendum to the bid documents shall be issued.

CHANGE 3:

At SI01 Bid Documents, section 1.c. :

Insert :

Subsection GI15 Approval of alternative materials:

Delete : at least ten (10) calendar days prior to the solicitation closing date

Insert: by end of day April 12, 2019

CHANGE 4:

At SI02 Enquiries During the Solicitation Period:

Delete:

1. Enquiries regarding this bid must be submitted in writing to the Contracting Authority named on the Invitation to Tender - Page 1 at e-mail address Suparna.sarker@rcmp-grc.gc.ca Except for the approval of alternative materials as described in GI15 of R2710T, enquiries should be received no later than 5 business days prior to the date set for solicitation closing to allow sufficient time to provide a response. Enquiries received after that time may result in an answer NOT being provided.

Insert:

1. Enquiries regarding this bid must be submitted in writing to the Contracting Authority named on the Invitation to Tender - Page 1 at e-mail address Suparna.sarker@rcmp-grc.gc.ca. Except for the approval of alternative materials as described in GI15 of R2710T, enquiries should be received no later than **end of day April 12, 2019** to allow sufficient time to provide a response. Enquiries received after that time may result in an answer NOT being provided.



ADDENDUM 2:

Addendum #2 to the specifications and drawings are hereby amended into this solicitation. Addendum #2 is attached as a separate document under the Tender Notice on BuyandSell.gc.ca.

PART 2 – QUESTIONS & ANSWERS:

Question #4:

Alternative material request for Solarflective Roller Shades as an equivalent product for specifications section 12 49 00 Roller Shades.

Answer#4:

This alternative material request is approved based on the information provided in the request to the project team. Based on the information provided in the request, Solarflective Roller Shades meets the intent of the requirements specified in the specifications section 12 49 00. Reference Addendum #2.

Question #5:

Alternative material request for Mel-Drain 5035 and Perminator 15 as equivalent products for specification sections 07 11 13 and 07 27 00.

Answer #5:

This alternative material request is approved based on the information provided in the request to the project team. Based on the information provided in the request, Mel-Drain 5035 and Perminator 15 meet the intent of the requirements specified in the specifications sections 07 11 13 and 07 27 00. Reference Addendum #2.

Question #6:

Alternative material request for Owens Corning Thermafiber Mineral Wool Insulation as an equivalent product for specification sections 07 21 13.

Answer #6:

This alternative material request is approved based on the information provided in the request to the project team. Based on the information provided in the request, Owens Corning Thermafiber Mineral Wool Insulation meets the intent of the requirements specified in the specifications section 07 21 13. Reference Addendum #2.

Question #7:

Alternative material request for the following as equivalent products:

1. TSL550-16” roof panel instead of Vicwest Prestige 16” panel?
2. Blueskin RF 200 ice and water instead of Grace Product?

Answer #7:

This alternative material request is denied.

1. The TSL550-16” Standing Metal Roofing DOES NOT meet the intent of the specification. We have specified a ribbed panel for rigidity.
2. The Blueskin RF200 DOES NOT meet the intent of the specified product. The Grace Ultra is specified under dark metal roofing to resist high temperatures. The Blueskin does not



appear to be suited to high temperatures.

Question #8:

Alternative material request for SRP AirOutshield SA as an equivalent product for specification section 07 27 00.

Answer #8:

This alternative material request is denied. Based on the information provided in the request to the project team, this product (SRP AirOutshield SA) DOES NOT meet the intent of the specification. The specified product has a higher vapour permeance than the product requested.

Question #9:

Alternative material request for the following as an equivalent product:
09 65 19 – 2.2.9: Tarkett ID55 Inspiration luxury vinyl plank – 2.5mm, micro-bevel, 22mil wear layer.

Answer #9:

This alternative material request is denied. Based on the information provided in the request to the project team, this product (Tarkett I.D. Inspiration 55) DOES NOT meet the intent of the specification. The specified product is thicker than the product requested.

Question #10:

Alternative material request for the following as an equivalent product: 09 67 00 – BASF Mastertop 1234.

Answer #10:

This alternative material request is approved based on the information provided in the request to the project team. Based on the information provided in the request, BASF Mastertop 1234 meets the intent of the requirements specified in the specifications section 09 67 00. Reference Addendum #2.

Question #11:

Alternative material request for the Panolam Hardrock Maple as an equivalent product of Panolam W271 Apple Spice melamine for concealed interiors. Section 6400 2.3.1.6 under Manufactured Units is calling for Panolam W271 Apple Spice melamine for concealed interiors. This product colour is no longer available and is discontinued.

Answer #11:

It does appear that the melamine Panolam W271 Apple Spice has been discontinued, however we DO NOT approve Panolam W290 Hardrock Maple as an alternate. The specifications will be revised via addendum.

Question #12:

Specification Section 10 56 00 Storage Assemblies does not include a specification for cabinets STG11, STG12, & STG13. These units are shown in room 135.

Will there be a specification coming out for them?

Also Rifle Lockers STG4, & STG10 are shown in rooms 129 & 136 but there is no specification for these as well.

Answer #12:

STG4, STG10, STG11, STG12, and STG13 are all specified in Specification Section 10 51 13 – METAL LOCKERS.



Question #13:

Alternative material request for the following as an equivalent product:

1. Engineered Assemblies T-Clip for Specification Section 07 46 13.

Answer #13:

This alternative material request is approved based on the information provided in the request to the project team. Based on the information provided in the request, Engineered Assemblies T-Clip meets the intent of the requirements specified in the specifications section 07 46 13. Reference Addendum #2.

Question #14:

Alternative material request for the following as an equivalent product:

1. Specifications section 10 51 13 - Hadrian Divided Police Locker Series and Hadrian Hardwood Laminate Pedestal.

Answer #14:

This alternative material request is approved based on the information provided in the request to the project team. Based on the information provided in the request, Hadrian Divided Police Locker Series 24'x24" and Hadrian Hardwood Laminate Pedestal Benches meet the intent of the requirements specified in the specifications section 10 51 13. Reference Addendum #2.

Question #15:

Alternative material request for the following as an equivalent product:

1. Halo Exterra Rigid Board Insulation for section 07 21 13 THERMAL INSULATION

Answer #15:

This alternative material request is denied. This product (Halo Exterra Rigid Board Insulation) DOES NOT meet the intent of the specification. We have specified Extruded Polystyrene Insulation and this product is an Expanded Polystyrene product.

Question #16:

Alternative material request for the following as equivalent products for section 07 27 00 and 07 52 00:

1. IKO AquaBarrier AVB,
2. IKO AquaBarrier-VP, and
3. ProtectoBase-180 for the specifications.

Answer #16:

This alternative material request is approved based on the information provided in the request to the project team. Based on the information provided in the request, IKO AquaBarrier AVB and IKO AquaBarrier VP and ProtectoBase 180 meet the intent of the requirements specified in the specifications section 07 27 00 and 07 52 00. Reference Addendum #2.

Question #17:

- a. Does the first nation have equipment for rent? If so what are the rates? Fuel and operator included?
- b. Does the first nation have soil materials for sale? If so what are the rates? What type of materials are available?



Answer #17:

The onus is on the Bidder to research this information in the preparation of their bid.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.