



**RETURN BIDS TO:  
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services  
220 - 4 Avenue S.E., suite 720  
Calgary, AB T2G 4X3

The maximum email file size that Parks Canada is capable of receiving is 6 megabytes. The Bidder is responsible for any failure attributable to the transmission or receipt of the emailed bid due to file size.

**REVISION 002 TO AN  
INVITATION TO TENDER**

**RÉVISION 002 À UNE  
INVITATION À SOUMISSIONNER  
DEMANDE D'OFFRES À  
COMMANDES**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

**Issuing Office - Bureau de distribution :**

Parks Canada Agency  
National Contracting Services  
220 - 4 Avenue S.E., suite 720  
Calgary, AB T2G 4X3

<b>Title - Sujet :</b> Hwy 93S Sinclair Creek Culvert Liner – Kootenay National Park	
<b>Solicitation No. - N° de l'invitation :</b> 5P420-19-0023/A	<b>Date :</b> April 18, 2019
<b>Amendment No. - N° de modification :</b> 002	
<b>Client Reference No. - N° de référence du client :</b> 1079-03	
<b>GETS Reference No.   N° de référence de SEAG :</b> PW-19-00869961	

<b>Solicitation Closes - L'invitation prend fin :</b> <b>At - à :</b> 2 :00 PM <b>On - le :</b> April 24, 2019	<b>Time Zone - Fuseau horaire</b> MDT - HAR
--	--

<b>F.O.B. - F.A.B. :</b> <b>Plant - Usine :</b> <input type="checkbox"/> <b>Destination :</b> <input checked="" type="checkbox"/> <b>Other - Autre :</b> <input type="checkbox"/>		
<b>Address Enquiries to - Adresser toutes demande de renseignements à :</b> Rebecca Chen		
<b>Telephone No. - N° de telephone :</b> (587) 439-3529	<b>Fax No. -N° de télécopieur :</b> (866) 246-6893	<b>Email Address – Courriel :</b> <a href="mailto:rebecca.chen2@canada.ca">rebecca.chen2@canada.ca</a>
<b>Destination of Goods, Services, and Construction - Destination des biens, services, et construction :</b> Kootenay National Park See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE**

<b>Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :</b>	
<b>Address - Adresse :</b>	
<b>Telephone No. - N° de telephone :</b>	<b>Fax No. - N° de télécopieur :</b>
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Signature :</b>	<b>Date :</b>

## **Amendment 002**

This amendment is being raised to distribute questions and answers.

### **A. QUESTIONS AND ANSWERS**

**Q3** In Section 1.6 ENVIRONMENTAL PROTECTION PLAN of the RFP it states the following:

“The EPP should be prepared jointly by a QEP and the Contractor. A final Certification as fit for purpose by the QEP is required prior to submission and implementation. Certification by a QEP is considered incidental to the Works and no additional payment will be made.”

What exactly is meant by “Certification as fit for purpose by the QEP” mean?

**A3** This means the QEP must do a sign-off of the document to confirm it is good enough to do the job it is intended to do.

**Q4** It does not specifically state that the water diversion plan should be developed by a QEP. Is Parks ok with the contractor developing this or is this something that should be included in the Environmental Protection Plan (EPP).

**A4** In section 1.2.2 of the Environmental Protection Plan (Section 01 35 43): “The EPP must include how the Contractor will manage all environmental risks...”. Water diversion should be included in the EPP as potential environmental risks will be involved with that work.

**Q5** We are interested in bidding on the lining of the Hwy 93S Sinclair Creek Culvert using a Spray applied Geopolymer lining system called GeoSpray, manufactured by Milliken Infrastructure Solutions. We are submitting the GeoSpray to be considered as the lining system for the Hwy 93S Sinclair Creek Culvert.

**A5** The product does not appear to meet the specifications required in this contract. We will however keep it in mind when considering future culvert rehabilitation projects. At this time, please bid based on the specifications.

**ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED**