



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Water Supply Upgrades	
Solicitation No. - N° de l'invitation F1700-184138/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1700-184138	Date 2019-04-24
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8585	
File No. - N° de dossier PWY-8-41282 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-04-29	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Atnarko River, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

This Amendment 001 is raised to address questions and to issue Addendum #1.

Questions and Answers

Q1. The installation of both the domestic water and production submersible pump into the same casing. (the diameter of the case will not accommodate these two pumps plus the drop tubes and controls)

Could you please confirm installation?

A1. Please see Addendum #1.

Q2. We would like to spec a Grundfos pump and motor. The turnaround on this pump is 2 days, rather than the normal 2 week delivery. The pump is SS construction.

Also we would like to spec Bore line hose as a replacement to the steel drop pipe. We have used Bore line hose for the past 7 years. We have 100 hp pumps @ 300 ft on 6 and 8 inch hose. 50 year warranty

The pitless adapter is also something we would like to change. Boshart Industries now builds industrial pitless units in Winnipeg Manitoba. Faster delivery and no US dollar exchange.

A2. A boreline flexible drop pipe would not allow for the custom made riser required to accommodate the domestic submersible pump in well 1. It should not be approved.

- A Grundfoss submersible pump could be approved if DFO approves it and if it meets the hydraulic and electrical performance of the proposed Goulds pumps.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

Drawings

- Note 7 on drawing C04 to be replaced by the following:
 - Well 1 and well 2 to be equipped with Goulds 10LHC-2Stage submersible pump, impeller trim 5.31", 200V, 3Ph, 1,800 RPM nominal (duty point 1,500USGPM @35feet TDH) or approved equivalent, marine vesconite bearings, DI VFD rated check valve;
 - Well 1 to be equipped with small submersible pump Grundfoss 10SQE200 for domestic water supply (10 USGPM @200feet), or approved equivalent, c/w power supply and 25mm HDPE riser pipe. Pump to be securely fastened to 200mm SS riser pipe approximately 2m above Goulds pumps. Contractor to provide custom made Ø200mm SS riser pipe to house Grundfoss pump, ensuring the assembly fits in 12" casing. Contractor to provide at least 0.5cm spacing between riser pipe and Grundfoss pump. See picture below for concept – DFO representative to approve prior to installation.
 - Well 1 pitless adapter to be custom made for Ø200mm and Ø25mm riser pipes.