



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions -
TPSGC**

11 Laurier St. / 11, rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau

Québec

K1A 0S5

Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

**Marine Machinery and Services / Machineries et
services maritimes**

11 Laurier St. / 11, rue Laurier

6C2, Place du Portage

Gatineau

Québec

K1A 0S5

Title - Sujet CCGS Samuel Risley Axial Fan	
Solicitation No. - N° de l'invitation F2599-195006/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F2599-195006	Date 2019-04-29
GETS Reference No. - N° de référence de SEAG PW-\$\$ML-062-27280	
File No. - N° de dossier 062ml.F2599-195006	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-05-27	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Roberge-Butcher, Michelle	Buyer Id - Id de l'acheteur 062ml
Telephone No. - N° de téléphone (873) 469-3524 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation Amendment 001 is raised to respond to Bidder's questions, and amend Annex "A" Requirement and Annex "E" Mandatory Technical Criteria, as follows:

Q1:

Can we replace the propellers of the fans currently in aluminium by propellers with synthetic blades of high quality and non-corrosive mounted on an aluminium hub?

A1:

No

Q2:

Can we replace the alloy used for the fan bodies, currently made of hot dipped galvanized steel, by 5083 marine grade aluminium, which is lighter and very resistant to corrosion?

A2:

Yes, 5083 marine grade aluminium is ok, provided it is of equal strength to original fan casings.

Q3:

Due to concerns about production time and for optimization of use, can we replace the 2 speed motor by a variable speed control motor via a dimmer?

This has the advantage of improving performance by perfectly adjusting to the desired flow, in longevity as well as noise.

A3:

No

The revisions to the Solicitation are as follows:

(1) In Annex "A" Requirement, Section 1.3.2 Technical Requirements, page 6 of 7:

DELETE:

1.3.2.5 All fans to be of heavy duty, marine type construction with hot dipped galvanized fan housings.

REPLACE with:

1.3.2.5 All fans to be of heavy duty, marine type construction with hot dipped galvanized or 5083 marine grade aluminum fan housings.

(2) In Annex "E" Mandatory Technical Criteria, M3, page 30 of 32:

DELETE:

M3 The Bidder must demonstrate that the offered fans have housings of heavy duty, marine type construction with hot dipped galvanized steel.

REPLACE with:

M3 The Bidder must demonstrate that the offered fans have housings of heavy duty, marine type construction with hot dipped galvanized steel or 5083 marine grade aluminum of equal strength to existing fan housings.