



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Bâtiment d'équipement de la pointe	
<b>Solicitation No. - N° de l'invitation</b> F1705-190000/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> F1705-190000	<b>Date</b> 2019-05-03
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-039-8587	
<b>File No. - N° de dossier</b> PWY-8-41291 (039)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-05-09</b>	
<b>Time Zone</b> Fuseau horaire Pacific Daylight Saving Time PDT	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Park (PWY), Isabell	<b>Buyer Id - Id de l'acheteur</b> pwy039
<b>Telephone No. - N° de téléphone</b> (604) 365-0073 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Amphitrite Point - Ucluelet, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Les documents français seront disponibles sur demande.**

### **Amendment 003**

This amendment is issued to publish questions and answers.

#### **Questions and Answers:**

QUESTION 1: We have a question regarding the specification for concrete reinforcing. Although there does not seem to be any notes on the drawings indicating the use of galvanized rebar, Specification section 03 20 00 Concrete reinforcing seems to imply that the rebar used on this project is to be Galvanized. Refer to sections, Materials 2.1.7, Preparation 3.1.1 and Field touch-up 3.4. Please confirm if Galvanized rebar is to be used on this project, and if so, is it to be used in all applications, and if not, please specify where it should be used?

RESPONSE 1: There is no galvanized rebar on this project, so Clauses 2.1.7, 3.1.1, and 3.4 are not applicable.

QUESTION 2: In the fire protection package the releasing panel is shown as Notifier and in the electrical package the fire alarm system is shown as Edwards. The releasing panel is also capable of performing single stage fire alarm function. Was it intended to have 2 fire alarm panels by 2 different manufacturers? Is it allowable to use the releasing panel as the building fire alarm panel as well?

RESPONSE 2: Use of the Notifier panel as the only F/A system is acceptable. The Releasing panel may be used as the building fire alarm panel, but it must be capable of all the annunciating and requirements listed in the specifications. Panel manufacture is to be in accordance with the Fire Protection system design.

QUESTION 3: After looking at the warranty, from what I can see it appears to be material warranty. The AIR-SHIELD SMP is a primer less material which is typically applied to the substrate. Is confirmation on ICF application required here?

RESPONSE 3: Confirmation through product documentation of compatibility and adhesion to ICF is required. Additionally, supplier must demonstrate where different products would be used on the assemblies and details shown on drawings. Supplier must show or markup where different products would be used and with what compatible sealants and tapes etc. Substitution of products from those listed in the specifications will not be considered when the supplier does not demonstrate consideration for the adjoining products nor the assembly which they tend to do.

All other terms and conditions remain unchanged.