

ADDENDUM NUMBER: **FOUR (04)**

ADDENDUM DATE: **May 1, 2019**

ISSUED BY: **SEPW Architecture Inc.**
 102 – 3718 Kinnear Place, SK. S7P 0A6
 PH. (306) 652-6457

PROJECT: **New Police Building and Residence**
 Pelican Narrows, Saskatchewan

This Addendum forms part of the Contract Documents and amends the original Drawings and Specifications dated 2018-10-19, previous Addenda if applicable and as noted below. This Addendum consists of 2 pages.

Ensure that all parties are aware of all items included in this Addendum.

The following revised or additional Drawings and Specifications accompany and form an integral part of this Addendum:

Dwg. No.	Title	Date of Issue
Spec. Section No.		

ARCHITECTURAL

- A-4-1 REF. SPECIFICATION 10 90 00 – MISCELLANEOUS SPECIALTIES**
- Clarification:** Article 2.1.1. Where “R+S” is noted, install the rod at 1700mm A.F.F. with the shelf above.
 - Clarification:** Article 2.1.2. Where “3S” is noted, install the top shelf so that it matches the height of the “R+S” shelf, and space the other 2 shelves equally between the top shelf and the finished floor.

STRUCTURAL

- S-4-1 REF. SPECIFICATION 03 35 00 – CONCRETE FINISHING**
- Add:** Article 2.1.3.1 “Alternative penetrating epoxy sealer to be ClovaPrep 83020 by Cloverdale. Surface preparation, mixing requirements, and application parameters set forth by the manufacturer are to be followed closely.”.

ELECTRICAL

- E-4-1 REF. SPECIFICATION 26 50 00 – LIGHTING**
- Revise article 2.5.5.1, fixture Type DD2 shall be wall mounted.
- E-4-2 REF. DRAWING E2.1 – MAIN FLOOR PLAN LIGHTING PLAN**
- Revise fixture Type DD2 in Room 104 to be Type DD.

E-4-3 REF. DRAWING E3.3 – MAIN FLOOR PLAN FIRE ALARM PLAN

1. Add 1 smoke detector to Room 114.
2. Add 1 smoke detector to Room 112.
3. Add 2 smoke detectors to Room 113.

END OF ADDENDUM NO. 04