




1	ISSUED FOR TENDER	03/08 2019
revisions		date
project		projet


RENOUS DIESEL AND ELECTRIC FIRE PUMP REPLACEMENT

SECTIONS AND DETAILS


designed H.C	conçu
date FEB 28, 2018	
drawn J.M	dessiné
date FEB 28, 2018	
approved S.M	approuvé
date SEPT 28, 2018	
Tender R.089981.001	Submission
PWSC Project Manager	Administrateur de projets TFSGC
project number	no. du projet
R.089981.001	
drawing no.	no. du dessin
FP-3	




ELECTRIC FIRE PUMP CONTROLLER SENSING LINE SCHEMATIC 1 FP-3
SCALE : N.T.S.



SLEEVE DETAIL 2 FP-3
SCALE : N.T.S.



FIRE PUMP AND ENGINE ANCHOR DETAIL 3 FP-3
SCALE : N.T.S.



- NOTES:
- CONTRACTOR TO VERIFY EXACT DEPTH OF PIT/OVERALL LENGTH OF PUMP SHAFT IN ORDER TO MEET NFPA MANDATED DISTANCE FROM BOTTOM OF CISTERN
 - CONTRACTOR SHALL ALLOW FOR BASEPLATE AND FLANGED PIPE CONNECTION SEGMENT TO ENSURE NEW PUMP DISCHARGE ALIGNS WITH EXISTING PIPE.

FIRE PUMP INSTALLATION DETAIL 4 FP-3
SCALE : N.T.S.

