



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS Á:**  
 Parks Canada Agency Bid Receiving Unit  
 National Contracting Services  
 Suite 720, 220 – 4<sup>th</sup> Avenue S.E.  
 Calgary, AB T2G 4X3

Bid Fax: 1-866-246-6893

**REQUEST FOR QUOTATION**  
**DEMANDE DE PRIX**  
**AMENDMENT / MODIFICATION**  
**002**

**Tender To: Parks Canada Agency**  
 We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**  
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

**Issuing Office - Bureau de distribution**

Parks Canada Agency  
 National Contracting Services  
 Suite 720, 220 – 4<sup>th</sup> Avenue S.E.  
 Calgary, AB T2G 4X3

<b>Title-Sujet</b> Code Compliance Testing and Maintenance of Sprinkler, Fire pump and Associated Devices – Parks Canada, Manitoba Field Unit		
<b>Solicitation No. - No. de l'invitation</b> 5P420-18-0519/A	<b>Date:</b> May 29, 2019	
<b>GETS Reference No. – No de reference de SEAG</b> PW-19-00869993	<b>Amendment No. - N° de la modif.</b> 002	
<b>Solicitation Closes:</b>		
<b>at – á</b> 14:00	<b>on – le</b> May 30, 2019	<b>Time Zone - Fuseau horaire</b> MDT - HAR
<b>F.O.B. - F.A.B.</b> Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Ryan Taylor - <a href="mailto:ryan.taylor@canada.ca">ryan.taylor@canada.ca</a>		
<b>Telephone No. - No de téléphone</b> (587) 436-5987	<b>Fax No. – No de FAX:</b> 1-866-246-6893	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b> See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b> _____	
<b>Facsimile No. - N° de télécopieur:</b> _____	
<b>Signature</b>	<b>Date</b>

**Amendment number two (02) is raised to:**

- A) Add 5 Year inspection requirement to the Automatic Sprinkler System under Annex A – Statement of Work.**

**A) Amend Annex A – Statement of Work**

Under item 6.2 of the Annex A Statement of Work:

**Insert:**

**Five (5) Year Inspection of the Automatic Sprinkler System:**

The inspection requirements listed below are to be completed at the time of the five (5) year inspection for the Automatic Sprinkler System.

**1.0 Five (5) Year Inspection Requirements:**

In addition to the tasks outlined in the weekly, monthly, quarterly, semi-annual, and annual inspections, the five (5) year inspection, testing and maintenance of the automatic sprinkler system must include, but is not limited to, the following tasks:

- .1 Test all of the gauges.
- .2 For alarm valves and system riser check valves:
  - .1 Complete an Internal inspection.
  - .2 Complete an inspection of all strainers, filters and restriction orifices.
- .3 For check valves:
  - .1 Complete an internal inspection.
  - .2 Complete the maintenance of all internal components.
- .4 For pre-action valves and deluge valves:
  - .1 Complete an internal inspection of the valves that can be reset without the removal of a faceplate.
  - .2 Complete the inspection of all strainers, filters, restricted orifices and diaphragm chambers.
  - .3 Complete the interior maintenance of the preaction or deluge valves that can be reset without the removal of a faceplate.
- .5 For dry pipe valves/ quick-opening devices:
  - .1 Complete the inspection of all strainers, filters, restricted orifices and diaphragm chambers.
- .6 Conduct and complete a Full flow test of all pressure-reducing valves and relief valves.
- .7 Complete an internal inspection of the backflow prevention assemblies.
- .8 Complete the Hydrostatic Testing of the Fire Department connection piping.