

Part 1 General**1.1 REFERENCE STANDARDS**

- .1 American National Standards Institute (ANSI)
 - .1 ANSI/ASSE A10.6-2006 (R2016), Safety and Health Program Requirements for Demolition Operations.
- .2 CSA Group (CSA)
 - .1 CSA S350-M1980 (R2003), Code of Practice for Safety in Demolition of Structures.
- .3 National Fire Protection Association (NFPA)
 - .1 NFPA 241-2019, Standard for Safeguarding Construction, Alteration, and Demolition Operations
- .4 National Research Council Canada (NRC)
 - .1 National Building Code of Canada (NBC).
 - .2 National Fire Code of Canada (NFC).

1.2 DEFINITIONS

- .1 Demolition: rapid destruction of building elements following removal of hazardous materials.
- .2 Hazardous Materials: dangerous substances, dangerous goods, hazardous commodities and hazardous products, may include but not limited to: asbestos PCBs, CFC, HCFCs poisons, corrosive agents, flammable substances, ammunition, explosives, radioactive substances, or other material that can endanger human health or wellbeing or environment if handled improperly.
- .3 Waste Management Coordinator (WMC): Contractor representative responsible for supervising waste management activities as well as coordinating related, required submittal and reporting requirements.
- .4 Construction Waste Management Plan (CWM Plan): Written plan addressing opportunities for reduction, reuse, or recycling of materials prepared in accordance with Section 01 74 19 – Waste Management and Disposal.
- .5 Construction Waste Management Report (CWM Report): Written report identifying actual materials that formed CWM Plan for reduction, reuse, or recycling of materials prepared in accordance with Section 01 74 19 – Waste Management and Disposal

1.3 ADMINISTRATIVE REQUIREMENTS

- .1 Coordination: Coordinate with Departmental Representative for the material ownership including but not limited to:
 - .1 Except for items or materials indicated to be reused, salvaged, reinstalled, or otherwise indicated to remain Departmental Representative's property,

demolished materials shall become Contractor's property and shall be removed from Project site.

- .2 Pre-Demolition Meetings:
 - .1 Convene pre-installation meeting 1 week prior to beginning work of this Section on-site installation, with Departmental Representative.
- .3 Scheduling:
 - .1 Employ necessary means to meet project timelines without compromising specified minimum rates of material diversion.
 - .2 In event of unforeseen delay notify Departmental Representative in writing.

1.4 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Action Submittals: Provide the following submittals before starting any work of this Section:
 - .1 Shop Drawings: Submit drawings stamped and signed by professional engineer registered or licensed in Ontario as follows:
 - .2 Submit in accordance with Section 01 74 19 – Waste Management and Disposal and 01 33 00 – Submittal Procedures.
 - .3 Schedule of Demolition Activities: Coordinate with Section 01 00 10 – General Instructions, “Construction Progress Schedule”.
- .2 Informational Submittals: Provide the following submittals when requested by the Departmental Representative:
 - .1 Qualification Data: Submit information for companies and personnel indicating their capabilities and experience to perform work of this Section including; but not limited to, lists of completed projects with project names and addresses, names and addresses of Consultants and Consultant Representatives, for work of similar complexity and extent.
- .3 Sustainable Design Submittals:
 - .1 Construction Waste Management:
- .4 Submit project Waste Management Plan according to Section 01 74 19 – Waste Management and Disposal.

1.5 QUALITY ASSURANCE

- .1 Regulatory Requirements: Ensure Work is performed in compliance with applicable Federal and Municipal regulations.
- .2 Comply with hauling and disposal regulations of Authority Having Jurisdiction.
- .3 Standards: Comply with ANSI/ASSE A10.6 and NFPA 241.

1.6 SITE CONDITIONS

- .1 Review Designated Substance Report and take precautions to protect environment.
- .2 If material resembling spray or trowel-applied asbestos or other designated substance listed as hazardous be encountered, stop work, take preventative measures, and notify

Departmental Representative immediately. Refer to Section 01 00 10 – General Instructions and Section 01 35 29.06 – Health and Safety Requirements.

- .1 Proceed only after receipt of written instructions have been received from Departmental Representative.
- .3 Notify Departmental Representative before disrupting building access or services.

Part 2 Execution

2.1 EXAMINATION

- .1 Survey existing conditions and correlate with requirements indicated to determine extent of demolition required.
- .2 Inventory and record the condition of items being removed and salvaged.
 - .1 Existing slate flooring
- .3 When unanticipated mechanical, electrical, or structural elements are encountered, investigate and measure the nature and extent of the element.
- .4 Promptly submit a written report to Departmental Representative.
- .5 Engage a professional engineer to perform an engineering survey of condition of building to determine whether removing any element might result in structural deficiency or unplanned collapse of any portion of structure or adjacent structures during demolition operations.

2.2 PREPARATION

- .1 Protection of In-Place Conditions:
 - .1 Prevent movement, settlement, or damage to adjacent parts of building structures, and landscaping features to remain in place. Provide bracing and shoring required.
 - .2 Keep noise, dust, and inconvenience to occupants to minimum.
 - .3 Protect building systems, services and equipment.
 - .4 Provide temporary dust screens, covers, railings, supports and other protection as required.
 - .5 Do Work in accordance with Section 01 35 29.06 – Health and Safety Requirements and Section 01 00 10 – General Instructions, “Temporary Barriers and Enclosures”.
- .2 Demolition/Removal:
 - .1 Demolish items as indicated.
 - .2 Remove parts of existing building to permit new construction.
 - .3 Trim edges of partially demolished building elements to tolerances as defined by Departmental Representative to suit future use.
 - .4 At end of each day’s work, leave Work in safe and stable condition.
 - .5 Protect interiors of parts not to be demolished from exterior elements at all times.
 - .6 Demolish to minimize dusting.

- .3 Remove following materials and equipment and store in location designated by Departmental Representative:

- .1 Existing slate floor tiles

2.3 SITE RESTORATION REPAIRS

- .1 General: Promptly repair damage to adjacent construction caused by demolition operations.
- .2 Where repairs to existing surfaces are required, patch to produce surfaces suitable for new materials.
- .3 Restore exposed finishes of patched areas and extend restoration into adjoining construction in a manner that eliminates evidence of patching and refinishing.

2.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 00 10 – General Instructions, “Cleaning”.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 00 10 – General Instructions, “Cleaning”.
- .3 Refer to demolition drawings and specifications for items to be salvaged for reuse.
- .4 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 19 – Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION

Part 1 General

1.1 SUMMARY

- .1 Comply with requirements of this Section when performing following work:
 - .1 Removal of non-friable asbestos-containing material, if the material is removed without being broken, cut, drilled, abraded, ground, sanded or vibrated.
 - .2 Removal of non-friable asbestos-containing materials if the material is removed by breaking, cutting, drilling, abrading, grinding or vibrating, if the material is wetted to control the spread of dust and fibres, and the work is only done by non-powered hand-held tools.
- .2 Refer to the Specification Section 01 14 25 – Designated Substances for details on asbestos-containing materials.

1.2 RELATED SECTIONS

- .1 Section 01 14 25 – Designated Substances
- .2 Section 02 82 00.02 – Asbestos Abatement – Intermediate Precautions

1.3 REFERENCES

- .1 *Canadian General Standards Board (CGSB).*
 - .1 *CAN/CGSB-1.205-03, Sealer for Application of Asbestos-Fibre Releasing Materials.*
- .2 *Department of Justice Canada (Jus).*
 - .1 *Canadian Environmental Protection Act, 1999 (CEPA).*
- .3 *Health Canada/Workplace Hazardous Materials Information System (WHMIS).*
 - .1 *Material Safety Data Sheets (MSDS).*
- .4 *Transport Canada (TC).*
 - .1 *Transportation of Dangerous Goods Act, 1992 (TDGA).*
- .5 *Ontario Environmental Protection Act, R.R.O 1990,*
 - .1 *General – Waste Management, O. Reg. 347/90, as amended.*
- .6 *Underwriters' Laboratories of Canada (ULC).*
- .7 *National Joint Council (NJC).*
 - .1 *Part XI – Hazardous Substances.*
- .8 *Canada Labour Code Part II, section 124 and 125.*
 - .1 *Canada Occupational Health and Safety Regulations*
- .9 *PSPC Asbestos Management Standard*
- .10 *Ontario Ministry of Labour (MoL).*
 - .1 *Occupational Health and Safety Act, R.S.O 1990, c. O1 (OSHA)*
 - .1 *O.Reg. 278/05 – Designated Substance – Asbestos on Construction Projects and in Buildings and Repair Operations, as amended*

- .2 *Ontario Occupational Health and Safety Act, R.S.O. 1990, Regulation 490/09 "Designated Substances", as amended.*
- .3 *O.Reg. 213/91 - "Construction Projects", as amended.*

1.4 DEFINITIONS

- .1 HEPA vacuum: DOP tested High Efficiency Particulate Air filtered vacuum equipment with filter system capable of collecting and retaining fibres greater than 0.3 microns in any direction at 99.97% efficiency.
- .2 Amended Water: water with non-ionic surfactant wetting agent added to reduce surface tension of water to allow thorough wetting of fibres.
- .3 Asbestos-Containing Materials (ACMs): materials that contain 0.5 percent or more asbestos by dry weight, identified under Existing Conditions including fallen materials and settled dust.
- .4 Asbestos Work Area: area where work takes place which will, or may, disturb ACMs.
- .5 Authorized Visitors: Departmental Representative, and representative(s) of regulatory agencies.
- .6 Competent worker: in relation to specific work, means a worker who:
 - .1 Is qualified because of knowledge, training and experience to perform the work.
 - .2 Is familiar with the provincial laws and with the provisions of the regulations that apply to the work.
 - .3 Has knowledge of all potential or actual danger to health or safety in the work.
- .7 DOP Test: testing method used to determine integrity of unit using Dispersed Oil Particulate (DOP) HEPA-filter leak test.
- .8 Friable material: means material that:
 - .1 When dry, can be crumbled, pulverized or powdered by hand pressure, or is crumbled, pulverized or powdered.
- .9 Hazardous Material Work Plan: A brief report identifying the location and quantities of hazardous materials and the methods that will be used to remove, store, transport and dispose of them.
- .10 Non-Friable Material: material that when dry cannot be crumbled, pulverized or powdered by hand pressure.
- .11 Occupied Area: any area of the building or work site that is outside Asbestos Work Area.
- .12 Polyethylene: rip-proof polyethylene sheeting with tape along edges, around penetrating objects, over cuts and tears, and elsewhere as required to provide protection and isolation.
- .13 Sprayer: garden reservoir type sprayer or airless spray equipment capable of producing mist or fine spray. Sprayer must have appropriate capacity for work.

1.5 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit proof satisfactory to the Departmental Representative that suitable arrangements have been made to dispose of asbestos-containing waste in accordance with requirements of authority having jurisdiction.
- .2 Submit Provincial/Territorial and/or local requirements for Notice of Project Form.
- .3 Submit proof of Contractor's Asbestos Liability Insurance.
- .4 Submit to the Departmental Representative necessary permits for transportation and disposal of asbestos-containing waste and proof that asbestos-containing waste has been received and properly disposed.
- .5 Submit proof that all asbestos workers and/or supervisor have received appropriate training and education by a competent person in the hazards of asbestos exposure, good personal hygiene and work practices while working in Asbestos Work Areas, and the use, cleaning and disposal of respirators and protective clothing.
- .6 Submit proof satisfactory to Departmental Representative that employees have appropriate respirator fitting and testing (fit test certificates). Workers must be fit-tested (qualitative as a minimum) with respirator that is personally issued.
- .7 Asbestos abatement section within Hazardous Material Work Plan.

1.6 QUALITY ASSURANCE

- .1 Regulatory Requirements: comply with Federal, Provincial/Territorial, and local requirements pertaining to asbestos, provided that in case of conflict among these requirements or with these specifications, more stringent requirement applies. Comply with regulations in effect at time Work is performed.
- .2 Health and Safety:
Safety Requirements: worker protection.
 - .1 Protective equipment and clothing to be worn by workers while in Asbestos Work Area include:
 - .1 As a minimum, air purifying half-mask respirator with N-100, R-100 or P-100 particulate filter, personally issued to worker and marked as to efficiency and purpose, suitable for protection against asbestos and acceptable to Provincial Authority having jurisdiction. The respirator to be fitted so that there is an effective seal between the respirator and the worker's face, unless the respirator is equipped with a hood or helmet. The respirator to be cleaned, disinfected and inspected after use on each shift, or more often if necessary, when issued for the exclusive use of one worker, or after each use when used by more than one worker. The respirator to have damaged or deteriorated parts replaced prior to being used by a worker; and, when not in use, to be stored in a convenient, clean and sanitary location. The employer to establish written procedures regarding the selection, use and care of respirators, and a copy of the procedures to be provided to and reviewed with each worker who is required to wear a respirator. A worker is not to be assigned to an operation requiring the use of a respirator unless he or she is physically able to perform the operation while using the respirator.

- .2 Disposable-type protective clothing (high-density polyethylene protective clothing (Tyvek or similar, as approved by Departmental Representative) that does not readily retain or permit penetration of asbestos fibres. Protective clothing to be provided by the employer and worn by every worker who enters the work area, and the protective clothing shall consist of a head covering and full body covering that fits snugly at the ankles, wrists and neck, in order to prevent asbestos fibres from reaching the garments and skin under the protective clothing to include suitable footwear, and to be repaired or replaced if torn.
- .2 Eating, drinking, chewing, and smoking are not permitted in Asbestos Work Area.
- .3 Before leaving Asbestos Work Area, the worker can decontaminate his or her protective clothing by using a vacuum equipped with a HEPA filter, or by damp wiping, before removing the protective clothing, or, if the protective clothing will not be reused, place it in an asbestos waste container.
- .4 Facilities for washing hands and face shall be provided within or close to the Asbestos Work Area.
- .5 Ensure workers wash hands and face when leaving Asbestos Work Area.
- .6 Ensure that no person required to enter an Asbestos Work Area has facial hair that affects seal between respirator and face.

1.7 WASTE MANAGEMENT AND DISPOSAL

- .1 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .2 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .3 Separate for reuse, and recycling and place in designated containers steel, metal, plastic waste in accordance with Waste Management Plan.
- .4 Place materials defined as hazardous or toxic in designated containers. Location and transportation of all on-site waste containers must be approved by Departmental Representative in writing prior to work.
- .5 Handle and dispose of hazardous materials in accordance with the CEPA, TDGA, Regional and Municipal regulations.
- .6 Fold up metal banding, flatten and place in designated area for recycling.
- .7 Disposal of asbestos waste generated by removal activities must comply with Federal, Provincial, Territorial and Municipal regulations. Dispose of asbestos waste in sealed double thickness 0.15 mm thick bags or leak proof drums. Label containers with appropriate warning labels.
- .8 Provide waste manifests describing and listing waste created. Transport containers by approved means to licensed landfill for burial. All waste landfill manifests are to be provided to the Client/Client Representative at the end of the project.

1.8 EXISTING CONDITIONS

- .1 Refer to the Specification Section 01 14 25 – Designated Substances for details on asbestos-containing materials.
- .2 Notify Departmental Representative of asbestos-containing material discovered during Work and not apparent from drawings, specifications, or report pertaining to Work. Do not disturb such material pending instructions from Departmental Representative.

1.9 SCHEDULING

- .1 Hours of Work: perform work involving asbestos abatement located at the Building during hours specified by Departmental Representative. **The work schedule must be approved in writing by the Departmental Representative in advance of work.** Contractor shall be available to work continuously from beginning to end of project.

1.10 PERSONNEL TRAINING

- .1 Before beginning Work, provide Departmental Representative with satisfactory proof that every worker has had instruction and training in hazards of asbestos exposure, in personal hygiene and work practices, and in use, cleaning, and disposal of respirators and protective clothing.
- .2 Instruction and training related to respirators includes, following minimum requirements:
 - .1 Fitting of equipment.
 - .2 Inspection and maintenance of equipment.
 - .3 Disinfecting of equipment.
 - .4 Limitations of equipment.
- .3 Instruction and training must be provided by a competent, qualified person.

Part 2 Products

2.1 MATERIALS

- .1 Drop Sheets:
 - .1 Polyethylene: 0.15 mm thick.
 - .2 FR polyethylene: 0.15 mm thick woven fibre reinforced fabric bonded both sides with polyethylene.
- .2 Wetting Agent: 50% polyoxyethylene ester and 50% polyoxyethylene ether mixed with water in a concentration to provide thorough wetting of asbestos-containing material.
- .3 Waste Containers: contain asbestos waste in two separate containers.
 - .1 Inner container: 0.15 mm thick sealable polyethylene waste bag.
 - .2 Outer container: sealable metal or fibre type where there are sharp objects included in waste material; otherwise outer container may be sealable metal or fibre type or second 0.15 mm thick sealable polyethylene bag.

- .3 Labelling requirements: affix preprinted cautionary asbestos warning in both official languages that is visible when ready for removal to disposal site.

Part 3 Execution

3.1 SUPERVISION

- .1 Minimum of one Supervisor for every ten workers is required inside the asbestos work areas at all times.
- .2 Approved Supervisor must remain within Asbestos Work Area during disturbance, removal, or other handling of asbestos-containing materials.

3.2 PROCEDURES

- .1 Before beginning Work, isolate Asbestos Work Area using, at a minimum, preprinted cautionary asbestos warning signs in both official languages that are visible at access routes to Asbestos Work Area.
 - .1 Remove visible dust from surfaces in the work area where dust is likely to be disturbed during course of work.
 - .2 Use HEPA vacuum, or damp cloths where damp cleaning does not create a hazard and is otherwise appropriate.
 - .3 Do not use compressed air to clean up or remove dust from any surface.
- .2 Prevent spread of dust from Asbestos Work Area using measures appropriate to work to be done.
 - .1 Use FR polyethylene drop sheets over flooring such as carpeting that absorbs dust and over flooring in Asbestos Work Area where dust and contamination cannot otherwise be safely contained.
- .3 Wet materials containing asbestos to be cut, ground, abraded, scraped, drilled, or otherwise disturbed unless wetting creates hazard or causes damage.
 - .1 Use garden reservoir type low - velocity fine - mist sprayer.
 - .2 Perform Work to reduce dust creation to lowest levels practicable.
 - .3 Work will be subject to visual inspection.
 - .4 Contamination of surrounding areas indicated by visual inspection or air monitoring will require complete enclosure and clean-up of affected areas.
- .4 Cutting, shaping, grinding, drilling, abrading or otherwise disturbing non-friable asbestos-containing materials shall be executed using non-powered hand-tools only.
- .5 Clean-Up:
 - .1 Frequently during Work and immediately after completion of Work, clean up dust and asbestos-containing waste using HEPA vacuum or by damp mopping.
 - .2 Place dust and asbestos-containing waste in sealed dust-tight waste bags. Treat drop sheets and disposable protective clothing as asbestos waste; wet and fold these items to contain dust, then place in plastic bags.

- .3 Clean exterior of each waste-filled bag using damp cloths or HEPA vacuum and place in second clean waste bag immediately prior to removal from Asbestos Work Area.
- .4 Seal waste bags and remove from site. Dispose of in accordance with requirements of Provincial and Federal Authority having jurisdiction. Supervise dumping and ensure that dump operator is fully aware of hazardous nature of material to be dumped and that guidelines and regulations for asbestos disposal are followed.
- .5 Perform final thorough clean-up of Work areas and adjacent areas affected by Work using HEPA vacuum.

3.3 INSPECTION

- .1 Perform inspection of Asbestos Work Area to confirm compliance with specification and governing authority requirements. Deviation(s) from these requirements that have not been approved in writing by Departmental Representative may result in Work stoppage, at no cost to Owner.
- .2 Departmental Representative may inspect Work at any time during the project for:
 - .1 Adherence to specific procedures and materials.
 - .2 Final cleanliness and completion.
 - .3 No additional costs will be allowed by Contractor for additional labour or materials required to provide specified performance level.
- .3 When asbestos leakage from Asbestos Work Area has occurred or is likely to occur Departmental Representative may order Work shutdown.
- .4 No additional costs will be allowed by the Contractor for additional labour or materials required to provide specified performance level.

END OF SECTION

PART 1 GENERAL

- .1 Comply with requirements of this Section when performing the following work:
 - .1 The breaking, cutting, drilling, abrading, grinding, sanding, or vibrating of a non-friable asbestos-containing material, if the work is done by means of power tools that are attached to dust collecting devices equipped with HEPA filters.
 - .2 Removing or disturbing one square metre or less of friable asbestos-containing material.
 - .3 Removal of good condition asbestos-containing pipe insulation and pipe fitting insulation using the glovebag method, provided the glovebag seal can be maintained throughout the removal process.
- .2 Refer to the Specification Section 01 14 25 – Designated Substances for details on asbestos-containing material.

1.1 RELATED SECTIONS

- .1 Section 01 14 25 – Designated Substances
- .2 Section 02 82 00.01 – Asbestos Abatement: Minimum Precautions

1.2 REFERENCES

- .1 *Canadian General Standards Board (CGSB).*
 - .1 *CAN/CGSB-1.205-03, Sealer for Application of Asbestos-Fibre Releasing Materials.*
- .2 *Department of Justice Canada (Jus).*
 - .1 *Canadian Environmental Protection Act, 1999 (CEPA).*
- .3 *Health Canada/Workplace Hazardous Materials Information System (WHMIS).*
 - .1 *Material Safety Data Sheets (MSDS).*
- .4 *Transport Canada (TC).*
 - .1 *Transportation of Dangerous Goods Act, 1992 (TDGA).*
- .5 *Ontario Dangerous Goods Transportation Act*
- .6 *Ontario Environmental Protection Act, R.R.O 1990,*
 - .1 *General – Waste Management, O. Reg 347/90, as amended.*
- .7 *Underwriters' Laboratories of Canada (ULC).*
- .8 *National Joint Council (NJC).*
 - .1 *Part XI – Hazardous Substances.*
- .9 *PSPC Asbestos Management Standard*
- .10 *Canada Labour Code Part II*
 - .1 *Canada Occupational Health and Safety Regulations*
- .11 *Ontario Ministry of Labour (MoL).*

- .1 *Occupational Health and Safety Act, R.S.O 1990, c. O1 (OSHA)*
 - .1 *O.Reg. 278/05 – Designated Substance – Asbestos on Construction Projects and in Buildings and Repair Operations, as amended*
 - .2 *Ontario Occupational Health and Safety Act, R.S.O. 1990, Regulation 490/09 “Designated Substances”, as amended.*
 - .3 *O.Reg. 213/91 - “Construction Projects”, as amended.*

1.3 DEFINITIONS

- .1 Amended Water: water with non-ionic surfactant wetting agent added to reduce surface tension of water to allow wetting of fibres.
- .2 Asbestos-Containing Materials (ACMs): materials that contain 0.5 percent or more asbestos by dry weight, identified under Existing Conditions Article, including fallen materials and settled dust.
- .3 Asbestos Work Area: area where work takes place which will, or may disturb ACMs.
- .4 Authorized Visitors: Departmental Representative, and representative(s) of regulatory agencies.
- .5 Competent worker: in relation to specific work, means a worker who:
 - .1 Is qualified because of knowledge, training and experience to perform the work.
 - .2 Is familiar with the provincial laws and with the provisions of the regulations that apply to the work.
 - .3 Has knowledge of all potential or actual danger to health or safety in the work.
- .6 Curtained doorway: arrangement of closures to allow ingress or egress from one room to another while permitting minimal air movement between rooms, typically constructed as follows:
 - .1 Place two overlapping sheets of polyethylene over existing or temporarily framed doorway, secure each along top of doorway, secure vertical edge of one sheet along one vertical side of doorway, and secure vertical edge of other sheet along opposite vertical side of doorway.
 - .2 Reinforce free edges of polyethylene with duct tape and weight bottom edge to ensure proper closing.
 - .3 Overlap each polyethylene sheet at openings not less than 1.5 metres on each side.
- .7 DOP Test: testing method used to determine integrity of Negative Pressure unit using Dispersed Oil Particulate (DOP) HEPA-filter leak test.
- .8 Friable Material: material that when dry can be crumbled, pulverized or powdered by hand pressure and includes such material that is crumbled, pulverized or powdered.
- .9 Hazardous Material Workplan: A brief report identifying the location and quantities of hazardous materials and the methods that will be used to remove, store, transport and dispose of them.

- .10 HEPA vacuum: DOP tested, High Efficiency Particulate Air filtered vacuum equipment with filter system capable of collecting and retaining fibres greater than 0.3 microns in any dimension at 99.97% efficiency.
- .11 Non-Friable Material: material that when dry cannot be crumbled, pulverized or powdered by hand pressure.
- .12 Polyethylene: polyethylene sheeting or rip proof polyethylene sheeting with tape along edges, around penetrating objects, over cuts and tears, and elsewhere as required to provide protection and isolation.
- .13 Occupied Area: any area of building or work site that is outside Asbestos Work Area.
- .14 Sprayer: garden reservoir type sprayer or airless spray equipment capable of producing mist or fine spray. Must have appropriate capacity for scope of work.

1.4 ACTION AND INFORMATION SUBMITTALS

- .1 Submit proof satisfactory to the Departmental Representative that suitable arrangements have been made to dispose of asbestos-containing waste in accordance with requirements of authority having jurisdiction.
- .2 Submit Provincial/Territorial and/or local requirements for Notice of Project Form.
- .3 Submit proof of Contractor's Asbestos Liability Insurance.
- .4 Submit to the Departmental Representative necessary permits for transportation and disposal of asbestos-containing waste and proof that asbestos-containing waste has been received and properly disposed.
- .5 Submit proof that all asbestos workers and/or supervisor have received appropriate training and education by a competent person in the hazards of asbestos exposure, good personal hygiene and work practices while working in Asbestos Work Areas, and the use, cleaning and disposal of respirators and protective clothing.
- .6 Submit proof that supervisory personnel have attended asbestos abatement course, of not less than two days duration, approved by Departmental Representative. Minimum of one supervisor for every ten workers.
- .7 Submit Worker's Compensation Board status and transcription of insurance.
- .8 Submit documentation including test results, fire and flammability data, and Material Safety Data Sheets (MSDS) for chemicals or materials including:
 - .1 encapsulants;
 - .2 amended water;
 - .3 slow-drying sealer.
- .9 Submit proof satisfactory to Departmental Representative that employees have appropriate respirator fitting and testing (fit test certificates). Workers must be fit tested (qualitative as a minimum for Half-face respirator, quantitative for Full-face respirator) with respirator that is personally issued.
- .10 Asbestos abatement section within Hazardous Material Work Plan.

1.5 QUALITY ASSURANCE

- .1 Regulatory Requirements: comply with Federal, Provincial/Territorial and local requirements pertaining to asbestos, provided that in case of conflict among these requirements or with these specifications more stringent requirement applies. Comply with regulations in effect at the time work is performed.
- .2 Health and Safety:
 - .1 Safety Requirements: worker and visitor protection.
 - .1 Protective equipment and clothing to be worn by workers while in Asbestos Work Area include:
 - .1 As a minimum, air purifying respirator with P-100 particulate filter, personally issued to worker and marked as to efficiency and purpose, suitable for protection against asbestos and acceptable to Provincial Authority having jurisdiction. The respirator to be fitted so that there is an effective seal between the respirator and the worker's face, unless the respirator is equipped with a hood or helmet. The respirator to be cleaned, disinfected and inspected after use on each shift, or more often if necessary, when issued for the exclusive use of one worker, or after each use when used by more than one worker. The respirator to have damaged or deteriorated parts replaced prior to being used by a worker; and, when not in use, to be stored in a convenient, clean and sanitary location. The employer to establish written procedures regarding the selection, use and care of respirators, and a copy of the procedures to be provided to and reviewed with each worker who is required to wear a respirator. A worker not to be assigned to an operation requiring the use of a respirator unless he or she is physically able to perform the operation while using the respirator.
 - .2 Disposable-type protective clothing (high-density polyethylene protective clothing (Tyvek or similar, as approved by Departmental Representative) that does not readily retain or permit penetration of asbestos fibres. Protective clothing to be provided by the employer and worn by every worker who enters the work area, and the protective clothing shall consist of a head covering and full body covering that fits snugly at the ankles, wrists and neck, in order to prevent asbestos fibres from reaching the garments and skin under the protective clothing to include suitable footwear, and to be repaired or replaced if torn.
 - .3 Eating, drinking, chewing, and smoking are not permitted in Asbestos Work Area.
 - .4 Before leaving Asbestos Work Area, the worker can decontaminate his or her protective clothing by using a vacuum equipped with a HEPA filter, or by damp wiping, before removing the protective clothing, or, if the protective clothing will not be reused, place it in a container for dust and waste. The container to be dust tight, suitable for asbestos waste, impervious to asbestos, identified as asbestos waste, cleaned with a damp cloth or a vacuum equipped with a HEPA filter

immediately before removal from the work area, and removed from the work area frequently and at regular intervals.

- .5 Ensure workers wash hands and face when leaving Asbestos Work Area. Facilities for washing hands and face shall be provided within or close to the Asbestos Work Area.
- .6 Ensure that no person required to enter an Asbestos Work Area has facial hair that affects seal between respirator and face.
- .7 Visitor Protection:
 - .1 Provide protective clothing and approved respirators to Authorized Visitors to work areas.
 - .2 Instruct Authorized Visitors in the use of protective clothing, respirators and procedures.
 - .3 Instruct Authorized Visitors in proper procedures to be followed in entering into and exiting from Asbestos Work Area.

1.6 WASTE MANAGEMENT AND DISPOSAL

- .1 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .2 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .3 Separate for reuse, and recycling and place in designated containers steel, metal, plastic waste in accordance with Waste Management Plan.
- .4 Place materials defined as hazardous or toxic in designated containers.
- .5 Handle and dispose of hazardous materials in accordance with the CEPA, TDGA, Regional and Municipal regulations.
- .6 Fold up metal banding, flatten and place in designated area for recycling.
- .7 Disposal of asbestos waste generated by removal activities must comply with Federal, Provincial, Territorial and Municipal regulations. Dispose of asbestos waste in sealed double thickness 0.15 mm thick bags or leak proof drums. Label containers with appropriate warning labels.
- .8 Provide manifests describing and listing waste created. Transport containers by approved means to licenced landfill for burial.

1.7 EXISTING CONDITIONS

- .1 Refer to the Specification Section 01 14 25 – Designated Substances for details on asbestos-containing materials.
- .2 Notify Departmental Representative of asbestos-containing material discovered during Work and not apparent from drawings, specifications, or report pertaining to Work. Do not disturb such material pending instructions from Departmental Representative.

1.8 SCHEDULING

- .1 Hours of Work: perform work involving asbestos abatement located at the Building during hours specified by Departmental Representative. **The work schedule must be approved in writing by the Departmental Representative in advance of work.** Contractor shall be available to work continuously from beginning to end of project.

1.9 PERSONNEL TRAINING

- .1 Before beginning Work, provide Departmental Representative satisfactory proof that every worker has had instruction and training in hazards of asbestos exposure, in personal hygiene and work practices, and in use, cleaning, and disposal of respirators and protective clothing.
- .2 Instruction and training related to respirators includes, at minimum:
 - .1 Fitting of equipment.
 - .2 Inspection and maintenance of equipment.
 - .3 Disinfecting of equipment.
 - .4 Limitations of equipment.
- .3 Instruction and training must be provided by competent, qualified person.

PART 2 PRODUCTS

2.1 MATERIALS

- .1 Drop and Enclosure Sheets.
 - .1 Polyethylene: 0.15 mm thick.
 - .2 FR polyethylene: 0.15 mm thick woven fibre reinforced fabric bonded both sides with polyethylene.
- .2 Wetting Agent: 50% polyoxyethylene ester and 50% polyoxyethylene ether mixed with water in concentration to provide thorough wetting of asbestos-containing material.
- .3 Waste Containers: contain waste in two separate containers.
 - .1 Inner container: 0.15 mm thick sealable polyethylene bag
 - .2 Outer container: sealable metal or fibre type where there are sharp objects included in waste material; otherwise outer container may be sealable metal or fibre type or second 0.15 mm thick sealable polyethylene bag.
 - .3 Labelling requirements: affix preprinted asbestos warning, in both official languages, that is visible when ready for removal to disposal site.
- .4 Tape: tape suitable for sealing polyethylene to surfaces under both dry and wet conditions using amended water.
- .5 Slow - drying sealer: non-staining, clear, water - dispersible type that remains tacky on surface for at least 8 hours and designed for the purpose of trapping residual asbestos fibres.
 - .1 Sealer: flame spread and smoke developed rating less than 50.
- .6 Encapsulant: penetrating type conforming to CAN/CGSB-1.205.

PART 3 EXECUTION

3.1 SUPERVISION

- .1 Minimum of one Supervisor for every ten workers is required.
- .2 Approved Supervisor must remain within Asbestos Work Area during disturbance, removal, or other handling of asbestos-containing materials.

3.2 PROCEDURES

- .1 Before beginning Work, at each access to Asbestos Work Area, install warning signs in both official languages in upper case 'Helvetica Medium' letters reading as follows, where number in parentheses indicates font size to be used: 'CAUTION ASBESTOS HAZARD AREA (25 mm) / NO UNAUTHORIZED ENTRY (19 mm) / WEAR ASSIGNED PROTECTIVE EQUIPMENT (19 mm) / BREATHING ASBESTOS DUST MAY CAUSE SERIOUS BODILY HARM (7 mm)'.
 - .2 Before beginning Work remove visible dust from surfaces in work area where dust is likely to be disturbed during course of work.
 - .1 Use HEPA vacuum, or damp cloths where damp cleaning does not create hazard and is otherwise appropriate.
 - .2 Do not use compressed air to clean up or remove dust from any surface.
 - .3 Prevent spread of dust from Asbestos Work Area using measures appropriate to work to be done.
 - .1 Use FR polyethylene drop sheets over flooring such as carpeting that absorbs dust and over flooring in work areas where dust or contamination cannot otherwise be safely contained.
 - .2 Erect enclosure of polyethylene sheeting around indoor work areas, shut off mechanical ventilation system serving work area, and seal ventilation ducts to and from work area.
 - .4 Remove loose material by HEPA vacuum; thoroughly wet friable material containing asbestos to be removed or disturbed before and during Work unless wetting creates hazard or causes damage.
 - .1 Use garden reservoir type low - velocity sprayer or airless spray equipment capable of producing mist or fine spray.
 - .2 Perform Work in a manner to reduce dust creation to lowest levels practicable.
 - .5 Work is subject to visual inspection and air monitoring. Contamination of surrounding areas indicated by visual inspection or air monitoring will require complete enclosure and clean-up of affected areas at no additional costs to Departmental Representative.
 - .6 Clean-up:
 - .1 Frequently during Work and immediately after completion of work, clean up dust and asbestos-containing waste using HEPA vacuum or by damp mopping.
 - .2 Place dust and asbestos-containing waste in sealed dust-tight waste bags. Treat drop sheets and disposable protective clothing as asbestos waste and wet and fold to contain dust and then place in waste bags.

- .3 Immediately before their removal from Asbestos Work Area and disposal, clean each filled waste bag using damp cloths or HEPA vacuum and place in second clean waste bag.
- .4 Seal and remove double-bagged waste from site. Dispose of in accordance with requirements of Provincial/Territorial and Federal authority having jurisdiction. Supervise dumping and ensure that dump operator is fully aware of hazardous nature of material to be dumped and that guidelines and regulations for asbestos disposal are followed.
- .5 Perform final thorough clean-up of Asbestos Work Areas and adjacent areas affected by Work using HEPA vacuum.

3.3 AIR MONITORING

- .1 From beginning of Work until completion of cleaning operations, the Departmental Representative may collect air samples daily inside the Asbestos Work Area enclosures to ensure worker respiratory protection factors are not exceeded, in accordance with Provincial/Federal requirements.
- .2 From beginning of Work until completion of cleaning operations, the Departmental Representative will collect air samples on a daily basis in the clean room and outside the enclosure(s).
- .3 If air monitoring shows that areas outside work area enclosures or clean room are contaminated, enclose, maintain, and clean these areas in same manner as that applicable to Asbestos Work Areas:
 - .1 Stop work and clean areas outside of Asbestos Work Areas and Clean Room when Phased Contrast Microscopy measurements exceed 0.05 fibres per cubic centimetre (f/cc) and correct procedures.
 - .2 All required cleaning, re-cleaning, additional air testing and/or inspections will be performed at no extra charge.
- .4 The Departmental Representative will collect clearance air samples inside the enclosure following a final visual inspection of the Asbestos Work Area by the Departmental Representative. Samples will be analyzed and compared to applicable regulations.
 - .1 Final air monitoring results must show fibre levels of less than 0.01 fibres per cubic centimetre (f/cc).
 - .2 If air monitoring shows that areas inside the Asbestos Work Area enclosures are contaminated; enclose, maintain and clean these areas in same manner as that applicable to Asbestos Work Area at no additional cost.
 - .3 Repeat as necessary until fibre levels are less than 0.01 f/cc
 - .4 No additional costs will be allowed by Contractor for additional labour or materials required to provide specified performance level.

END OF SECTION