



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Klemtu Float Reconstruction	
<b>Solicitation No. - N° de l'invitation</b> F1571-198000/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> F1571-198000	<b>Date</b> 2019-06-14
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-004-8599	
<b>File No. - N° de dossier</b> PWY-9-42018 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-06-20</b>	<b>Time Zone Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Mestry, Ruth (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy004
<b>Telephone No. - N° de téléphone</b> (778) 995-4613 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Klemtu Small Craft Harbour - Klemtu, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

June 14, 2019

## ADDENDUM NO.2

Page 1 of 1

**THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY. THIS ADDENDUM WILL FORM PART OF THE TENDER/CONTRACT DOCUMENTS.**

Addendum 002 is raised to:

1) Provide answers to bidder questions.

**Q1)** Are the Floatation Billets considered as part of a float kit for this project?

**A1)** Flotation billets will be supplied by the Owner as part of the float module kits.

**Q2)** Can the consultant give us an brief introduction for the optional work in terms of material?

**A2)** All materials required for the optional work item, as shown on the drawings, are to be supplied by the Contractor.

**Q3)** Are the bolts and nails included with the float module kits supplied by DFO for this project?

**A3)** All materials listed in the Float Assembly Drawings FM9-END-200, FM9-END-201, FM9-ST-000, FM9-ST-001, FM9-ST-002, FM9-ST-003, FM12-END-200, FM12-END-201, FM12-ST-000, FM12-ST-001, FM12-ST-002, FM12-ST-003 will be supplied by the Owner.

**Q4)** On DWG 004 for the Klemtu project, Float Detail 2/03 shows the float connection detail to be a 27.4m chain - that seem excessive for a +/- 300mm connection link (I understand the anchor chain being that length in detail 4/03. Please confirm.

**A4)** The Contractor shall supply chain for float connections to allow for installation of float connector clip to be set back minimum 900mm from the float end.

**Q5)** Please confirm that in addition to fastenings, rub boards and decking are / are not included with the owner supplied float kits.

**A5)** All materials listed in the Float Assembly Drawings FM9-END-200, FM9-END-201, FM9-ST-000, FM9-ST-001, FM9-ST-002, FM9-ST-003, FM12-END-200, FM12-END-201, FM12-ST-000, FM12-ST-001, FM12-ST-002, FM12-ST-003 will be supplied by the Owner.

**Q6)** Please confirm that the existing float C is on anchors and that if the optional anchor replacement isn't utilized will the new float will simply reconnect to the existing anchors.

**A6)** Existing Float C is on anchors. If the Optional item is not awarded the Contractor shall reconnect to the existing anchors.

**All other terms and conditions remain unchanged**

\*\*\*\*\*

**ENGLISH DOCUMENTS WILL BE PROVIDED UPON REQUEST**

**Les documents français seront disponibles sur demande.**

June 14, 2019

## ADDENDUM NO.2

Page 1 of 1

**THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY. THIS ADDENDUM WILL FORM PART OF THE TENDER/CONTRACT DOCUMENTS.**

Addendum 002 is raised to:

1) Provide answers to bidder questions.

**Q1)** Are the Floatation Billets considered as part of a float kit for this project?

**A1)** Flotation billets will be supplied by the Owner as part of the float module kits.

**Q2)** Can the consultant give us an brief introduction for the optional work in terms of material?

**A2)** All materials required for the optional work item, as shown on the drawings, are to be supplied by the Contractor.

**Q3)** Are the bolts and nails included with the float module kits supplied by DFO for this project?

**A3)** All materials listed in the Float Assembly Drawings FM9-END-200, FM9-END-201, FM9-ST-000, FM9-ST-001, FM9-ST-002, FM9-ST-003, FM12-END-200, FM12-END-201, FM12-ST-000, FM12-ST-001, FM12-ST-002, FM12-ST-003 will be supplied by the Owner.

**Q4)** On DWG 004 for the Klemtu project, Float Detail 2/03 shows the float connection detail to be a 27.4m chain - that seem excessive for a +/- 300mm connection link (I understand the anchor chain being that length in detail 4/03. Please confirm.

**A4)** The Contractor shall supply chain for float connections to allow for installation of float connector clip to be set back minimum 900mm from the float end.

**Q5)** Please confirm that in addition to fastenings, rub boards and decking are / are not included with the owner supplied float kits.

**A5)** All materials listed in the Float Assembly Drawings FM9-END-200, FM9-END-201, FM9-ST-000, FM9-ST-001, FM9-ST-002, FM9-ST-003, FM12-END-200, FM12-END-201, FM12-ST-000, FM12-ST-001, FM12-ST-002, FM12-ST-003 will be supplied by the Owner.

**Q6)** Please confirm that the existing float C is on anchors and that if the optional anchor replacement isn't utilized will the new float will simply reconnect to the existing anchors.

**A6)** Existing Float C is on anchors. If the Optional item is not awarded the Contractor shall reconnect to the existing anchors.

**All other terms and conditions remain unchanged**

\*\*\*\*\*

**ENGLISH DOCUMENTS WILL BE PROVIDED UPON REQUEST**

**Les documents français seront disponibles sur demande.**