



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Shielded Enclosure	
Solicitation No. - N° de l'invitation W355B-195380/B	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client W355B-19-5380	Date 2019-06-19
GETS Reference No. - N° de référence de SEAG PW-\$HAL-104-5884	
File No. - N° de dossier HAL-8-80098 (104)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-07-02	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Nowakowski, Leanne	Buyer Id - Id de l'acheteur hal104
Telephone No. - N° de téléphone (902) 403-7112 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 001 is being issued to provide questions and answers to date.

Questions and Answers:

Question Number	Relevant Section(s)	Question	Answer
1	Annex A-7g	Can fiberoptic waveguides be used to pass fiber cables through the shielded enclosure?	Yes.
2	Annex A-7g	How many strands of fiber are required for each fiber optic cable?	Unknown until installation of vendor supplied equipment.
3	Annex-A-7g	For the 12 coax connectors, what is the connector type? Ex. SMA, N-type, BNC, etc.	BNC preferred.
4	Annex-A-7g	With respect to the "one 230V 3 phase 20A power cable" can power filters be used and an appropriate receptacle be located on the inside of the shield. For example, a 15-20R receptacle?	Power filters can be used with termination in a junction box within the shield for future equipment hook-up.
5	Annex-A-7g	With respect to the "1 phase, 230 V, 15 A power cable" can power filters be used and an appropriate receptacle be located on the inside of the shield. For example, a 6-15R receptacle?	Power filters can be used with termination in a junction box within the shield for future equipment hook-up.
6	Annex-A-7g	Are you able to provide more detail on the type of multi-pin connectors (25 pin). Is there a specific communication protocol?	Unknown until installation of vendor supplied equipment.
7	Annex-A-7e	What size of vents are required?	2' x 2'

8	Annex-A-7h/8f	In 7h, there is mention of two cat 6 communications. In 8f, each raised floor service box must be capable of housing 2 voice/data outlets. Are the two cat6 communications to be split among the four raised floor service boxes, or are more communication lines required? Or do the floor service boxes need to be capable of housing the 2 voice/data, but only one box will be connected?	Only 2 cat.6 communications cables are required.
9	Annex-A-9	Power supply is listed as three phase 480 V. My assumption is 277/480V. How will typical electrical outlets (15 A, 120V) be supplied?	277/480V is correct. Step down transformer / distribution panel will be provided in separate fit-up.
10	Annex-A	Are there any specific requirements for lighting?	Lighting will be provided in separate fit-up.
11	Annex-A	With only one door, if it is opened, the integrity of the shielded enclosure is compromised. Is a 2-door vestibule required?	No, one door only.
12	Annex-A	The specification in Annex A is not accurate. The document requests the shielded enclosure to measure 16' x 22' x 9' and conform to FCC Standard Part 15; yet in order to meet FCC Part 15 the enclosure will need to be at least 25' x 17' x 19' (LxWxH) and have absorbing material. The specification cannot be met as written. Please clarify this requirement.	There is no requirement for the shield to be larger than what is specified. No sound absorbing material is required.