



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Waterton Signs, Guardrails	
Solicitation No. - N° de l'invitation EP922-200063/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client Parks - EP922-200063	Date 2019-06-19
GETS Reference No. - N° de référence de SEAG PW-\$PWU-023-11636	
File No. - N° de dossier PWU-9-42017 (023)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-06-25	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Taylor (RPC), Ian	Buyer Id - Id de l'acheteur pwu023
Telephone No. - N° de téléphone (780) 566-9487 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This solicitation amendment has been raised to answer questions received:

Question 1

Section 31 23 22 Common Excavation was added to the specifications. There is no payment line in the form of tender. What are your intentions with this? If its incidental, we need a quantity.

Answer 1

A unit and quantity was included in the combined price schedule . Common Excavation consists of excavation, hauling, and disposal of excavated materials, and pre-existing loose rock and soil material from roadway ditch along the north side of Red Rock Parkway between approximate Station 4+000 to 4+500, and/or as directed by the Departmental Representative.

Question 2

It was discussed during site visit that roadway may require widening. Is road widening required?

Answer 2

The only road widening will including minor shoulder stripping, common excavation, subgrade preparation, grading, gravel placement, compaction and ditch cleaning at various locations. There are some areas that have no shoulders and we will make efforts to construct a 0.5 m shoulder where feasible. Unit rates have been added to cover this work.

Question 3

Is shoulder material required before guide rail installation?

Answer 3

Placement and compaction of the shoulder material can occur prior to or after guardrail installation.

Question 4

Gabion Baskets section 31 36 00 has been added. There is nothing in the drawings to indicate gabion work. And there is no payment line item for this. What is required?

Answer 4

A unit and quantity was added to the updated price shedule. This item generally includes 0.5m x 0.5m Gabions to be installed along south roadway shoulder in areas exhibiting higher erosion, at the locations directed by the department representative. Gabions to be wrapped in non-woven geotextile and placed between the new guardrail deep posts and edge of existing asphalt, with the top of gabion at 0.1m below the existing asphalt surface.

Question 5

Excavation section 31 23 33.01 has been added. What is required?

Answer 5

This section mainly covers the required minor excavation and backfilling work to install the guardrails and signs.

Question 6

Where do I find the enhanced 3.66m post in the tender. All post are explained as deep post 2.74m but no mention of enhanced.

Answer 6

A unit has been added. The enhanced deep post is described in section 34 71 13.25.

Question 7

Section 34 71 13.25 Vehicle W-Beam Guide Rail Part 1 Reference Standards 1.2.1.2 CSA G164-M – Hot Dipped Galvanizing of Irregularly Shaped Articles. CSA G164-M is obsolete as it does not meet the ASTM A123/ A653 type II coating requirements now standard with Alberta Transportation. Galvanizers do not use this method.

Answer 7

Hot dip galvanization shall be completed in accordance with the current version of the applicable Alberta Transportation Standards and Specifications.

Question 8

Section 34 71 13.25 Vehicle W-Beam Guide Rail Part 2 Products Materials 2.1.1.8 Rails & terminal elements shall be hot dipped galvanized after fabrication, in accordance with CSA-G164-M. Alberta Transportation offers galvanizing either before or after fabrication for w-beam and thrie beam. Will before fabrication be acceptable?

Answer 8

Yes, galvanizing either before or after fabrication is acceptable.

All other terms and conditions of the Invitation to Tender remain unchanged.

BID AND ACCEPTANCE FORM (BA)

BA01 IDENTIFICATION

Project Title: Sinclair Canyon Electrical Upgrade and Site Rehabilitation, BC.

Project Number: R.079636.001

Project Location: Kootenay National Park, BC.

BA02 BUSINESS NAME AND ADDRESS OF BIDDER

Name: _____

Address: _____

Telephone: _____ Fax: _____ PBN: _____

BA03 THE OFFER

The Bidder offers to Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the Total Bid Amount of

\$ _____ excluding applicable taxes.
(amount in numbers)

BA04 BID VALIDITY PERIOD

The bid shall not be withdrawn for a period of 30 (thirty) days following the date of solicitation closing.

BA05 ACCEPTANCE AND CONTRACT

Upon acceptance of the Contractor's offer by Canada, a binding Contract shall be formed between Canada and the Contractor. The documents forming the Contract shall be the contract documents identified in Contract Documents (CD).

BA06 CONSTRUCTION TIME

The Contractor shall perform and complete the Work within 40 (forty) weeks from the date of notification of acceptance of the offer.

BA07 BID SECURITY

The Bidder is enclosing bid security with its bid in accordance with GI08 - Bid Security Requirements of R2710T - General Instructions - Construction Services - Bid Security Requirements.

BA08 SIGNATURE

Name and title of person authorized to sign on behalf of Bidder (Type or print)

Signature

Date