



SECTION A-A

- GEN NOTES**
1. ALL EGPT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURERS & CLASSIFICATION SOCIETIES INSTRUCTIONS & RECOMMENDATIONS, GOOD ENGINEERING PRACTICE.
 2. REFER TO APPLICABLE ITEMS OF GEN NOTES IN DWG NO. R-106-1433-CD4.
 3. REFER TO SHIP DWGS FOR EGPT DETAILS.
 4. CONTROL DAMPERS SHALL BE N.C. & CLOSED ON PAN DOWN AT SHORT DELAY WHICH SHALL BE OBTAINED FROM OUTSIDE THE FAN ROOM.
 5. FAN & EGPT SEATING REFER TO DRAWING NO. R-106-1433-CD-8.

NO	REVISION	DATE	BY
1	AS-FITTED	MAY 21/80	CL
2	FR DURING REARRANGED QA IN AREA AFFECTED	NOV 23/80	SO
3	TO CORRECT APPROVAL REQ'S TO NAVAL ARCHITECTS REQ'S	AUG 27/80	CL

SCALE: 1/10 APPROVED BY: DRAWN BY: SO
 DATE: 23 NOV 80 REVISED:
 WITO STEEL BOATS & BARGE CONSTRUCTION LTD.
 TYPE 1050 NAVAL VESSEL DRAWING NUMBER: 11766-1433-28-2