


NOTES-TECHNICAL REQUIREMENTS			INDEX	REVISIONS
Nº	REF. SH. Nº	DESCRIPTION	SHEET Nº1	INDEX NOTES - TECHNICAL REQUIREMENTS NOTES - QUALIFICATIONS REVISIONS
1	2+3	SWITCHBOARD INSTRUMENTATION, GENERATOR EXCITATION EQUIPMENT, CIRCUIT BREAKER AND PROTECTIVE RELAYING SHALL BE PER OWNER'S SPECIFICATIONS AND APPLICABLE REGULATIONS.		
2	GENL.	ALL CABLES FORMING PART OF THE 600 V. POWER SYSTEM SHALL BE CANADA WIRE + CABLE TYPE "MARINEX - XB1" SPEC. Nº PES - 302 OR APPROVED EQUAL.	SHEET Nº2	SHAFT GENERATOR SWITCHBOARDS #1 AND #2 SHAFT GENERATOR MCC.
			SHEET Nº3	SHIPS SERVICE SWITCHBOARD EMERGENCY SWITCHBOARD SHORE CONNECTION
3	4	A. SEQUENTIAL STARTING TO PREVENT OVERLOADING OF THE EMERGENCY GENERATOR IS REQUIRED FOR: EMERGENCY FIRE PUMP BILGE PUMP REDUCTION GEAR STANDBY L.O.PUMPS PORT AND STBD.	SHEET Nº4	600V. ESSENTIAL MCC #1 600V. ESSENTIAL MCC #2 600V. EMERGENCY MCC
	⚠	B. SEQUENTIAL STARTING IS REQUIRED FOR: FWD. GROUP HYDRAULIC PUMP MOTORS TOWING WINCH HYDRAULIC PUMP MOTORS AFT GROUP HYDRAULIC PUMP MOTORS STERN THRUSTER SYSTEM	SHEET Nº5	600V. SEMI-ESSENTIAL MCC #1 600V. SEMI-ESSENTIAL MCC #2
4	⚠		SHEET Nº6	600V. NON-ESSENTIAL MCC #1 600V. NON-ESSENTIAL MCC #2 600V. NON-ESSENTIAL MCC #3
5	⚠		SHEET Nº7	120V. EMERGENCY DISTR.N CENTER 120V. SEMI-ESSENTIAL DISTR.N CENTER 240V. NON-ESSENTIAL DISTR.N CENTER #1 240V. NON-ESSENTIAL DISTR.N CENTER #2
6	⚠		SHEET Nº8	LIST OF SYMBOLS. MODES OF GENERATOR OPERATION AND INTERLOCKING REQUIREMENTS.
7	⚠			
8	⚠	WHENEVER S.S.GENERATORS REACH 105% RATED LOAD, THE FOLLOWING ITEMS SHALL BE SUBJECTED TO LOAD DUMPING: ⚠ 600V. NON-ESSENTIAL MCC'S Nºs 1, 2+3. ⚠ 240V. TRANSFORMER- ACCOMODATION RE-HEATERS.		
9	⚠	WHENEVER THE EMERGENCY GENERATOR FEEDS INTO THE SS. SWITCHBOARD AND REACHES 105% RATED LOAD, CIRCUIT-BREAKERS CB2+3 SHALL OPEN AND DUMP THE S.S.LOADS.		
10	⚠	A LOW VOLTAGE SENSING DEVICE SHALL TRIP AND PREVENT CLOSURE OF CB3 AT LOW VOLTAGE CONDITIONS OF 85% SYSTEM VOLTAGE (= 450V) OR LESS. SUFFICIENT TIME DELAY SHALL BE PROVIDED TO PREVENT TRIPPING OF CB3 ON MOMENTARY VOLTAGE DIPS. THE TRIPPING OF CB3 SHALL CAUSE THE EMERGENCY GENERATOR TO START.		
11	⚠			
12	4,5+6	CIRCUIT BREAKERS FITTED IN 600V. MCC'S ARE NOT TO BE LESS THAN 30 KA SYM.RMS INTERRUPTING RATING DESPITE PROSPECTIVE SHORT CIRCUIT CURRENTS BEING SIGNIFICANTLY LESS.		
13	7	CIRCUIT BREAKERS FITTED IN 120V. AND 240V. MCC'S ARE NOT TO BE LESS THAN 18 KA SYM.RMS INTERRUPTING RATING DESPITE PROSPECTIVE SHORT CIRCUIT CURRENTS BEING SIGNIFICANTLY LESS.		
14				
15	7	EXCEPT NAVIGATION LIGHTS PANEL, ALL 120V. AND 240V. DISTRIBUTION PANELS ARE 3-PHASE / 3-WIRE AND SUPPLY SINGLE PHASE CIRCUITS UTILIZING TWO (2) POLE CIRCUIT BREAKERS. PHASE BALANCE TO BE IN ACCORDANCE WITH TP127.		
16	2	WHEN CB5 (S.S.GEN.R #1) AND / OR CB6 (S.S.GEN.R #2) ARE CLOSED, INTERLOCKING SHALL PREVENT THE OPERATION OF THE TOWING WINCH HYDRAULIC MOTORS. THE INTERLOCKING SHALL BE DEFEATED WHENEVER THE SHAFT GENERATOR MCC IS ENERGIZED FROM ONE OF THE SHAFT GENERATORS.		
17				
18	2+3	ALL AIR CIRCUIT BREAKERS SHALL HAVE AN INTERRUPTING RATING OF NOT LESS THAN 40 KA SYM.RMS. AND ALL SWITCHBOARD MOUNTED MOULDED CASE CIRCUIT BREAKERS SHALL HAVE AN INTERRUPTING RATING OF NOT LESS THAN 30 KA SYM.RMS.		

3	AS FITTED	7/6/85
2	GENERAL REVISION	11/1/84
⚠	GENERALLY REVISED	JULY 24 1984
Rev. No.	Revisions	Date
App'd/ App'n		
Date		
Contractor/ Entrepreneur	STEEL BOAT & BARGE CONSTRUCTION LTD.	
	VITO	
	 Canadian Coast Guard / Garde ctiere canadienne	
Rev. No.	1050 NAV-AID VESSEL	
File No.	EL.POWER ONE LINE SCHEMATIC	
Drawn by/ Checked by/ Designer/ Engineer	N/A	
Inspector/ Inspector	481-803-1 OF 8	