

Addendum 001

This Addendum consists of 2 pages and no attachments. This Addendum is to clarify items in the tender documents.

The Tender Documents are hereby **amended** as follows:

1. SECTION 01 11 00 - SUMMARY OF WORK

- 1.1. Replace sentence 2.3.1 with the following: "Applies to Roof Sections 1.2A, 1.2B, 0.1, 0.2, 0.3 and **0.4.**"

2. SECTION 01 52 00 – CONSTRUCTION FACILITIES

- 2.1. Add sentence 1.1.5 as follows. "On grade staging for Contractor equipment will be permitted on a section of asphalt paving beside the building on the north side (back) of the building, identified by the Departmental Representative."

3. SECTION 01 35 13.04 – INTERIOR PROTECTION FOR ROOFING

- 3.1. Delete Part 3 – Execution, with the exception of Part 3.2 – Contractor Acknowledgement.

4. SECTION 07 52 16 – MODIFIED BITUMINOUS MEMBRANE ROOFING

- 4.1. Replace sentence 2.3.2 with the following: "Self-adhesive SBS modified bitumen vapour retarder, to meet requirements of manufacturer's twenty (20) year Full System Labour, Material and Workmanship Warranty."
- 4.2. Delete sentence 3.9.1, "Install sumps around drains prior to base insulation.". All tapered insulation, including at drains and scuppers, shall be installed on top of the base insulation.

5. DRAWINGS

- 5.1. On Drawings R1, R2 and R3, remove "250gm" from SBS Mod. Bit. Cap Sheet, and "180gm" from SBS Mod. Bit. Base Sheet.
- 5.2. On Detail R1-7: Replace "No.8 Galvanized Screws" with "No.12 Galvanized Screws".

Note: This Addendum shall form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all work contained herein shall be included in the Contract Price. The following revisions supersede the information contained in the original drawings and specifications issued for the above named project. Acknowledge receipt of this Addendum in the Bid Form.

END OF ADDENDUM NO. 1