

Amendment 003- Questions and Answers

1. We were told the scope of work will include the duct work cover replacement , but on the tender documents it doesn't mention it . could you please confirm it ?

Answer: This requirement is specified on drawing M-01, note 1.

2. Do the duct work cover thermal insulation contain asbestos , it doesn't state clearly on the report.

Answer: The insulation materials did not contain asbestos. Results can be found on page 91-93 from the tender document (Chapter 4 – Observations and results of Arcadis report)