



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Réception des soumissions - TPSGC / Bid Receiving -  
PWGSC

1550, Avenue d'Estimauville

1550, D'Estimauville Avenue

Quebec

Quebec

G1K 4K1

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

TPSGC/PWGSC

1550 Avenue d'Estimauville

Québec

Québec

G1J 0C7

<b>Title - Sujet</b> Floating docks and accessories	
<b>Solicitation No. - N° de l'invitation</b> F3731-180141/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> F3731-180141	<b>Date</b> 2019-06-27
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$QCV-004-17679	
<b>File No. - N° de dossier</b> QCV-8-41236 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-07-05</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Heure Avancée de l'Est HAE
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> DeBlois, Vincent	<b>Buyer Id - Id de l'acheteur</b> qcv004
<b>Telephone No. - N° de téléphone</b> (418) 649-2712 ( )	<b>FAX No. - N° de FAX</b> (418) 648-2209
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Voir doc.	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**Please amend the above mentioned bidding solicitation documents with the changes below:**

---

This modification 002 is intended to:

- A) Modify the tender closing date. See on the front page of the Invitation to Tender.
  - B) Answer questions from suppliers received up to now:
- 

**Question 3:**

Regarding the dimensions of the sections of the pieces of wood that appear at the drawings, are they nominal dimensions or net dimensions? For example, does a piece of wood specified as 152mm x 152mm means a net section of 140mm x 140mm or the intention of the drawings is really to obtain a net section of 152mm x 152mm?

**Answer 3:**

Size is as dimensions. Rough wood is used.

\*\*\*\*\*

**Question 4:**

Page 4 of the specifications for the cleats T-19 at lot 1= 20, lot 2= 20 and lot 3 =20 still giving a total of 60 X T-19 for the 3 lots. On the drawings, 40 is indicated for lot 3. Quantity to be clarified.

**Answer 4:**

Please use quantities indicated on the drawings.

\*\*\*\*\*

**Question 5:**

T-23 Landing plate -the drawings are showing 5 and the statement of Requirement shows 3. Quantity to be clarified

**Answer 5:**

The quantity required is 5

\*\*\*\*\*

**Question 6:**

T-20 shows on the drawings lot 123 20-20-20 and at the Statement of Requirement shows 40 for lot 3. Quantity to be clarified.

**Answer 6:**

See question and answer of number 4

\*\*\*\*\*

**Question 7:**

We would like to know if a bid bond is required, and if it is at the level of 10% of the bid?

**Answer 7:**

A bid bond is not required for this call for Tender.

\*\*\*\*\*

---

**Question 8:**

Does a bid submission form exist other than the form that appear in the Call for Tender?

**Answer 8:**

Please refer to paragraph 4.1, as well as its sub-sections to submit your bid.

\*\*\*\*\*

**Question 9:**

No specification with regards to the insurances is indicated at the Invitation to Tender. Are there any specific requirements?

**Answer 9:**

Please refer to paragraph 7.7 of the Invitation to Tender.

\*\*\*\*\*

**Question 10:**

A Procurement Business Number (PBN) is required with the bid in the Integrity Form. Do we need a PBN to submit an offer?

**Answer 10:**

Please refer to paragraph 02 of the 2003 (2018-05-22)

Suppliers are required to have a Procurement Business Number (PBN) before contract award. Suppliers may register for a PBN online at [Supplier Registration Information](#). For non-Internet registration, suppliers may contact the InfoLine at 1-800-811-1148 to obtain the telephone number of the nearest Supplier Registration Agent.

\*\*\*\*\*

**Question 11 :**

I noticed on the tender form that there are separate line items for the delivery of the floating docks to Cap-Aux-Meules and Sainte Therese-de-Gaspe. Can a bidder bid on one, but not the other?

**Answer 11:**

No, only one contract will be awarded. A proposal must indicate a price for each line items to be considered receivable.

\*\*\*\*\*

**Question 12:**

«.... steel fabricators ask if it is imperative that the aluminum fabrication be carried out by certified aluminum welding companies. Their argument is that it is not a structural thing so shouldn't be an issue. They can weld aluminum very well, they just aren't certified.»

**Answer 12:**

Canada is removing the requirement to detain certifications CSA W47.2 as well as CSA W59.2. The only item concerned are overlap plates and they will be accepted upon inspection.

\*\*\*\*\*

Solicitation No – N° de l'invitation  
F3731-180141/A  
Client Ref No. – N° de réf. du client  
F3731-180141

Amd. No. – N° de la modif.  
002  
File No. – N° du dossier  
QCV-8-41236

Buyer ID – id de l'acheteur  
qcv 004

---

**Question 13:**

...regarding awarding and commencement of the work, in the contract they ask of FIVE (5) days after to start, would it possible to have TWO (2) WEEKS instead...?

**Answer 13:**

No, the requirement remains unchanged

\*\*\*\*\*

**Question 14:**

Where is the electronic version of Annex A?

**Answer 14:**

Following Annex C of the original version of the invitation to tender documentation available on BuyandSell.

---

**All other clauses and conditions from the bidding solicitation remain the same.**