



NOTES

- UNINSTALL ALL THE LIGHT FIXTURES SHOWN ON THE PLAN (EXCEPT THOSE WITH AC INDICATION). THE CIRCUITS FOR THE UNINSTALLED ITEMS WILL GENERALLY BE REUSED FOR NEW INSTALLATIONS. ENSURE CONTINUITY OF THESE CIRCUITS.
- ENSURE CONTINUITY OF CIRCUITS DURING DEMOLITION.
- IF AN OUTLET TO BE REMOVED IS ON A WALL THAT IS TO BE KEPT, A FULL COVERAGE FACEPLATE MUST BE USED.



LEVEL 6
PLAN VIEW
SCALE 1:50

FOR TENDER	JMP	2019-01-18	
Révision	Description	Par/By	Date
A	A: Numéro du détail Detail no.	A	A
B	B: Feuille sur laquelle le détail est référencé Location drawing no.	B/C	B/C
C	C: Feuille sur laquelle le détail est dessiné Drawing no.		
Toute modification doit être rapportée à: All modification must be reported to:			
Biens Immobiliers, Environnement, Sécurité et Santé 104, Dalhousie, Québec, Qc G1K 7Y7			
Dossier: File:			
MONT-JOLI MAURICE-LAMONTAGNE BUILDING RENOVATION GIST/SPC			
Dessin: Drawing:			
OUTLETS AND SERVICES DEMOLITION OF LEVEL 6, BUILDING A			
Conçu par: Designed by:		Date	
P-L Jean		2018-03-12	
Dessiné par: Drawn by:		Date	
J-M Potvin		2018-03-12	
Vérifié par: Verified by:		Date	
F. Jean		2018-05-08	
Approuvé par: Approved by:		Date	
P-L Jean		2018-05-08	
No. dossier: File no.:		Echelle: Scale:	
F3766-170169		Indicated	
No. dessin: Drawing no.:		No. feuille: Sheet no.:	
		E16 OF 19	